

Regulation Compliance Monthly Report June, 2003

Date of Report Generation: 7/7/2003

QSE	Avg SCE (1min)	Avg Reg CF	Monthly Compliance	Avg SCE (10min)	Adjusted L10 (10min)	L10 Monthly Compliance	PASS	FAIL	% PASS
AMERICAN ELECTRIC POWER SERVICE CORP	30.4740	4.7524	FAIL	28.4824	6.6167	FAIL	426	955	30.85
ANP FUNDING I LLC	16.5741	0.6796	PASS	16.6001	10.7954	FAIL	3	16	15.79
AUTOMATED POWER EXCHANGE	66.5330	10.3418	FAIL	65.4465	10.6665	FAIL	339	328	50.82
BPTX (SQ2)	19.0284	0.4283	PASS	18.0451	13.6465	FAIL	3198	1069	74.95
BTU QSE SERVICES INC	8.2209	0.5851	PASS	7.8798	9.2254	FAIL	2957	1304	69.40
CALPINE POWER MANAGEMENT LP	42.3032	0.9063	PASS	39.2111	16.6758	FAIL	2660	1582	62.71
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	30.2747	0.4113	PASS	28.2817	21.0365	FAIL	3155	1102	74.11
CITY OF GARLAND (QSE)	3.0069	0.3050	PASS	2.5549	5.9023	PASS	4115	153	96.42
CONSTELLATION POWER SOURCE INC	19.2130	2.3092	FAIL	18.5471	7.1870	FAIL	815	469	63.47
DYNEGY POWER MARKETING INC	11.8922	-0.5693	PASS	11.4329	8.9812	FAIL	809	606	57.17
LOWER COLORADO RIVER AUTHORITY (QSE)	13.8693	0.5247	PASS	10.9164	19.5511	FAIL	3753	515	87.93
MIRANT AMERICAS ENERGY MARKETING LP	20.4980	1.2564	FAIL	19.0548	10.5372	FAIL	1841	1909	49.09
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	4.1164	0.6307	PASS	3.8029	4.0603	FAIL	3433	807	80.97
TEXAS GENCO LP (QSE)	111.9659	0.1232	PASS	107.2699	29.5236	FAIL	3190	1072	74.85
TXU PORTFOLIO MANAGEMENT COMPANY LP (C	65.6000	0.5625	PASS	51.1702	32.7802	FAIL	2629	1638	61.61