

Regulation Compliance Monthly Report July, 2003

Date of Report Generation: 8/4/2003

QSE	Avg SCE (1min)	Avg Reg CF	Monthly Compliance	Avg SCE (10min)	Adjusted L10 (10min)	L10 Monthly Compliance	PASS	FAIL	% PASS
AMERICAN ELECTRIC POWER SERVICE CORP	20.1733	3.1901	FAIL	17.4060	11.8029	FAIL	433	213	67.03
AUTOMATED POWER EXCHANGE	23.7468	-0.9260	PASS	23.9557	16.7523	FAIL	553	240	69.74
BPTX (SQ2)	14.7729	0.3354	PASS	13.4697	26.2609	FAIL	3927	498	88.75
BTU QSE SERVICES INC	7.1445	0.3360	PASS	6.8126	17.1563	PASS	4055	357	91.91
CALPINE POWER MANAGEMENT LP	20.8381	0.3269	PASS	17.1517	34.5705	FAIL	3923	492	88.86
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	27.4164	0.3541	PASS	25.4448	31.7586	FAIL	3735	688	84.44
CITY OF GARLAND (QSE)	2.0436	0.2405	PASS	1.6372	10.7849	PASS	4361	47	98.93
CONSTELLATION POWER SOURCE INC	8.3501	0.2269	PASS	8.2232	17.4122	FAIL	391	83	82.49
DYNEGY POWER MARKETING INC	8.4480	-0.1014	PASS	7.9577	18.8812	FAIL	1318	210	86.26
FPL ENERGY POWER MARKETING	73.3273	-1.7827	PASS	67.1282	22.9120	FAIL	80	50	61.54
FPLE PMI BASTROP FPL ENERGY POWER MARKE	22.8742	-0.6654	PASS	23.8782	24.8456	FAIL	60	11	84.51
LOWER COLORADO RIVER AUTHORITY (QSE)	11.9322	0.4706	PASS	9.3140	31.7062	PASS	4251	174	96.07
MIRANT AMERICAS ENERGY MARKETING LP	15.4410	1.0052	FAIL	14.1008	19.4149	FAIL	3104	840	78.70
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	4.9209	0.6655	PASS	4.6879	7.5622	FAIL	3247	512	86.38
TEXAS GENCO LP (QSE)	30.1327	0.2903	PASS	24.9615	53.2469	PASS	4149	275	93.78
TXU PORTFOLIO MANAGEMENT COMPANY LP (C	66.5839	0.5403	PASS	51.0661	60.1233	FAIL	3459	962	78.24