

**SCE and Regulation Compliance Monthly Report
December, 2003**

Date of Report Generation: 2/2/2004

QSE	Avg SCE (1min) All Intervals	REGULATION PERFORMANCE			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score	Unadj Score %	Adj. Score
AMERICAN ELECTRIC POWER SERVICE CORP	25.8	115.9		61.4	72.8
ANP FUNDING I LLC	4.2				
AUTOMATED POWER EXCHANGE	16.0				
BPTX (SQ1)	13.1				
BPTX (SQ2)	12.2	168.5		91.4	
BRAZOS ELECTRIC POWER CO OP INC	7.8				
BTU QSE SERVICES INC	5.9	164.5		95.0	
CALPINE POWER MANAGEMENT LP	18.4	142.4		91.7	
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	11.2	161.4		96.1	
CITY OF GARLAND (QSE)	4.5	164.1		91.4	
CONSTELLATION POWER SOURCE INC A	1.1				
CONSTELLATION POWER SOURCE INC C	9.6				
CORAL POWER LLC	16.6				
CORAL POWER LLC (SQ2)	13.6				
DYNEGY POWER MARKETING INC	5.2	185.4		91.9	
EXELON POWER TEAM	7.2	155.2		90.8	
FPL ENERGY POWER MARKETING	27.3				
FPLE PMI BASTROP FPL ENERGY MARKETING, INC	23.1				
FPL_WIND_FPL ENERGY MARKETING, INC	27.3				
FRONTERA GENERATION LIMITED PARTNERSHIP (QSE)	2.5				
FULCRUM POWER SERVICES LP	0.0				
LOWER COLORADO RIVER AUTHORITY (QSE)	10.7	165.7		97.6	
MIRANT AMERICAS ENERGY MARKETING LP	0.0				
MPOWER QSE LP (QSE)	0.5				
RELIANT ENERGY ELECTRIC SOLUTIONS (QSE)	5.6				
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	2.9	145.6		96.5	
TENASKA POWER SERVICES CO	12.5				
TEXAS GENCO LP (QSE)	27.1	163.3		95.4	
TRACTEBEL ENERGY MARKETING INC	21.4				
TXU PORTFOLIO MANAGEMENT COMPANY LP (QSE)	52.8	134.5		82.3	86.8

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6