

**SCE and Regulation Compliance Monthly Report
October, 2004**

Date of Report Generation: 11/7/2004

QSE	Avg SCE (1min) All Intervals	REGULATION PERFORMANCE			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score	Unadj Score %	Adj. Score
AMERICAN ELECTRIC POWER SERVICE CORP	13.9	100.7	122.7	87.5	91.3
ANP FUNDING I LLC	5.2	182.3	182.4	92.8	97.3
AUTOMATED POWER EXCHANGE (SQ2)	5.2				
AUTOMATED POWER EXCHANGE (SQ3)	4.7				
BPTX (SQ1)	9.5				
BPTX (SQ2)	10.0	164.4	164.9	93.8	94.0
BRAZOS ELECTRIC POWER CO OP INC	7.9	51.2	116.6	86.9	93.5
BTU QSE SERVICES INC	5.5	180.8	195.4	93.6	96.7
CALPINE POWER MANAGEMENT LP	20.6	159.0	168.9	91.5	93.5
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	16.7	137.9	138.8	94.0	94.7
CITY OF GARLAND (QSE)	2.6	197.2	199.3	98.7	99.2
CONSTELLATION POWER SOURCE INC A	3.6	201.9	202.0	91.7	95.0
CONSTELLATION POWER SOURCE INC C	6.4				
CORAL POWER LLC	12.9				
CORAL POWER LLC (SQ2)	14.1				
DYNEGY POWER MARKETING INC	5.7	172.4	172.5	92.2	96.3
EXELON POWER TEAM	9.7	149.5	149.5	92.7	96.4
FPL ENERGY POWER MARKETING	39.2	177.0	177.0	77.5	78.7
FPLE_WIND_FPL ENERGY MARKETING, INC	22.2				
FRONTERA GENERATION LIMITED PARTNERSHIP (QSE)	2.2	182.3	182.3	89.2	93.0
FULCRUM POWER SERVICES LP	4.9	178.1	178.1	92.3	94.9
LOWER COLORADO RIVER AUTHORITY (QSE)	13.3	158.2	158.8	97.6	97.9
MIRANT AMERICAS ENERGY MARKETING LP	0.9				
MPOWER QSE LP (QSE)	1.4	172.9	172.9	98.1	99.3
RELIANT ENERGY ELECTRIC SOLUTIONS (QSE)	8.0				
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	3.3	163.6	163.6	94.8	96.2
TENASKA POWER SERVICES CO	6.4	159.2	159.2	94.2	97.2
TENASKA-OXY POWER SERVICES LP (TOPS) (SQ2)	6.5				
TEXAS GENCO LP (QSE)	24.6	168.4	169.6	94.5	94.9
TRACTEBEL ENERGY MARKETING INC	-46.7	145.2	80.5	85.0	90.4
TXU PORTFOLIO MANAGEMENT COMPANY LP (QSE)	37.5	72.8	125.6	82.2	85.7

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6