

**SCE and Regulation Compliance Monthly Report
March, 2005**

Date of Report Generation: 4/7/2005

QSE	Avg SCE (1min) All Intervals	REGULATION PERFORMANCE			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score	Unadj Score %	Adj. Score
AMERICAN ELECTRIC POWER SERVICE CORP	17.0	225.7	225.7	71.4	71.4
ANP FUNDING I LLC	6.8	173.5	173.5	97.2	98.5
BPTX (SQ1)	7.4				
BPTX (SQ2)	10.2	153.8	154.1	95.6	95.7
BRAZOS ELECTRIC POWER CO OP INC	4.0	132.1	134.3	77.5	93.7
BTU QSE SERVICES INC	3.9	149.0	149.1	94.0	97.4
CALPINE POWER MANAGEMENT LP	23.2	158.4	158.5	91.3	91.3
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	11.1	157.3	157.8	96.8	97.0
CITY OF GARLAND (QSE)	2.8	202.6	203.0	98.1	98.3
CONSTELLATION ENERGY COMMODITIES GROUP INC	18.5	-136.6	173.0	83.2	94.4
CONSTELLATION ENERGY COMMODITIES GROUP C INC	5.5				
CORAL POWER LLC	13.4				
CORAL POWER LLC (SQ2)	9.8				
DYNEGY POWER MARKETING INC	5.2	181.3	181.3	97.4	98.3
EXELON POWER TEAM	8.1	175.0	175.0	97.7	97.7
FPL ENERGY POWER MARKETING	20.9	173.6	173.7	93.5	94.0
FPLE_WIND_FPL ENERGY MARKETING, INC (SQ2)	45.3				
FULCRUM POWER SERVICES LP	2.5	188.6	188.6	99.9	100.0
LOWER COLORADO RIVER AUTHORITY (QSE)	12.9	166.5	166.7	98.4	98.4
MPOWER QSE LP (QSE)	0.0	191.8	191.8	99.3	100.0
RELIANT ENERGY ELECTRIC SOLUTIONS (QSE)	4.1				
SEMPRA TEXAS SERVICES LP	6.0				
SEMPRA TEXAS SERVICES LP (SQ1)	2.4				
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	2.7	191.8	191.9	97.8	98.3
SUEZ ENERGY MARKETING NA INC	13.2	157.7	157.7	95.9	99.0
TENASKA POWER SERVICES CO	9.7	192.8	192.8	96.1	97.2
TENASKA-OXY POWER SERVICES LP (TOPS) (SQ2)	9.3				
TEXAS GENCO II LP (QSE)	13.9	164.8	165.1	94.9	95.0
TXU PORTFOLIO MANAGEMENT COMPANY LP (QSE)	25.3	131.4	131.6	92.5	92.9

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6