

**SCE and Regulation Compliance Monthly Report
November, 2005**

Date of Report Generation: 12/7/2005

QSE	Avg SCE (1min) All Intervals	REGULATION PERFORMANCE			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score	Unadj. Score %	Adj. Score
AMERICAN ELECTRIC POWER SERVICE CORP	19.5				
ANP FUNDING I LLC	12.7	198.5	198.5	85.7	88.5
BPTX (SQ1)	2.0				
BPTX (SQ2)	6.3	182.6	182.6	96.9	97.1
BRAZOS ELECTRIC POWER CO OP INC	3.9	344.3	344.3	76.3	91.6
BTU QSE SERVICES INC	4.7	176.4	176.4	96.3	96.3
CALPINE POWER MANAGEMENT LP	19.7	176.1	176.1	93.2	93.3
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	10.9	179.2	179.2	94.7	94.8
CITY OF GARLAND (QSE)	2.1	170.0	171.9	98.2	98.3
CONSTELLATION ENERGY COMMODITIES GROUP INC	8.6	162.3	165.3	93.0	93.6
CONSTELLATION ENERGY COMMODITIES GROUP C INC	16.4				
CORAL POWER LLC	11.2				
CORAL POWER LLC (SQ2)	18.9				
DIRECT ENERGY LP WTU (SQ2)	3.8				
DYNEGY POWER MARKETING INC	6.6	199.8	199.8	96.2	97.3
EXELON POWER TEAM	5.3	143.8	143.8	96.4	98.7
FORMOSA UTILITY VENTURE LTD (QSE)	0.3	164.1	195.5	87.5	96.9
FPL ENERGY POWER MARKETING	15.0	189.0	189.0	91.0	92.2
FPLE PMI (SQ1)	55.5				
FPLE_WIND_FPL ENERGY MARKETING, INC (SQ2)	25.6				
FULCRUM POWER SERVICES LP	7.1	188.4	188.4	95.9	96.1
LOWER COLORADO RIVER AUTHORITY (QSE)	9.4	182.5	182.5	99.2	99.2
MIRANT AMERICAS ENERGY MARKETING LP	4.1				
MPOWER QSE LP (QSE)	1.8	181.7	181.7	95.8	97.9
RELIANT ENERGY ELECTRIC SOLUTIONS (QSE)	6.2				
SEMPRA TEXAS SERVICES LP	6.3				
SEMPRA TEXAS SERVICES LP (SQ1)	1.6				
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	1.9	162.3	170.2	97.5	97.8
SUEZ ENERGY MARKETING NA INC	11.6				
TENASKA POWER SERVICES CO	11.2	179.5	179.5	92.1	95.0
TENASKA-OXY POWER SERVICES LP (TOPS) (SQ2)	3.9				
TEXAS GENCO II LP (QSE)	14.7	175.6	175.6	97.7	97.9
TXU PORTFOLIO MANAGEMENT COMPANY LP (QSE)	29.0	149.1	149.1	93.4	93.6

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6