

SCE Compliance Monthly Report
August, 2007

Date of Report Generation: 9/4/2007

QSE	Avg SCE (1min) All Intervals	SCE PERFORMANCE CRITERIA			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score %	Unadj. Score %	Adj. Score %
AMERICAN ELECTRIC POWER SERVICE CORP	6.9	152.4	152.4	95.5	95.5
AMERICAN ELECTRIC POWER SERVICE CORP (SQ3)	10.5	185.7	185.7	62.7	62.7
ANP FUNDING I LLC	7.0	203.1	203.1	99.4	99.5
BPTX (SQ1)	2.6	204.9	204.9	99.7	99.7
BPTX (SQ2)	4.4	199.2	199.2	97.5	97.5
BPTX (SQ3)	3.0	179.1	179.1	97.9	97.9
BRAZOS ELECTRIC POWER CO OP INC (QSE)	7.2	193.3	193.3	89.3	90.1
BTU QSE SERVICES INC	5.0	143.7	143.7	97.3	97.3
BTU SQ1	2.5	155.6	155.6	98.6	98.7
CALPINE POWER MANAGEMENT LP	14.6	148.6	148.6	92.8	92.9
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	11.8	169.5	169.5	94.9	95.8
CITY OF GARLAND (QSE)	2.2	180.2	180.2	98.4	98.4
CITY OF SAN ANTONIO CITY PUBLIC SERVICE (QSE)	14.5	174.3	174.3	91.7	92.6
CITY OF SAN ANTONIO CITY PUBLIC SERVICE CPS WIND (SQ1)	53.9	148.2	148.2	15.0	15.0
CONSTELLATION ENERGY COMMODITIES GROUP INC (QSE)	3.8	176.6	176.6	98.4	98.4
CONSTELLATION ENERGY COMMODITIES GROUP INC C (QSE)	4.4	226.7	226.7	97.6	97.7
CORAL POWER LLC	5.8	212.2	212.2	96.7	96.9
CORAL POWER LLC (SQ2)	12.2	211.7	211.7	93.0	93.0
DIRECT ENERGY LP	7.2	212.0	212.0	96.6	97.0
DIRECT ENERGY LP WTU (SQ2)	50.8	99.7	99.7	19.5	19.5
DYNEGY POWER MARKETING INC	8.2	171.2	171.2	96.2	96.3
EAGLE ENERGY PARTNERS I LP (QSE)	11.4	158.1	158.1	86.8	90.0
EXELON GENERATION COMPANY LLC	10.7	172.8	172.8	89.3	91.3
FORMOSA UTILITY VENTURE LTD (QSE)	2.3	201.8	201.8	96.4	96.4
FPL ENERGY POWER MARKETING	18.8	142.4	142.4	90.9	90.9
FPL ENERGY POWER MARKETING INC (SQ3)	47.5	156.0	156.0	20.1	20.1
FPLE PMI (SQ1)	25.4	159.9	159.9	31.7	31.8
FPLE_WIND_FPL ENERGY POWER MARKETING INC.(SQ2)	20.7	212.0	212.0	38.7	38.7
FULCRUM POWER SERVICES LP	6.2	201.4	201.4	94.0	94.0
IPA MARKETING INC (SQ1)	4.9	196.3	196.3	96.9	96.9
LOWER COLORADO RIVER AUTHORITY (QSE)	7.8	187.8	187.8	98.5	98.6
NRG TEXAS LP (QSE)	17.2	172.2	172.2	91.8	91.8
OCCIDENTAL POWER SERVICES INC	3.3	186.7	186.7	98.0	98.0
RELIANT ENERGY POWER SUPPLY LLC	7.9	180.9	180.9	93.2	93.3
RIO NOGALES POWER PROJECT LP (QSE)	4.5	188.0	188.0	96.9	96.9
SCURRY COUNTY WIND LP (QSE)	16.3	187.1	187.1	47.4	47.4
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	1.9	192.7	192.7	99.0	99.0
SUEZ ENERGY MARKETING NA INC	7.5	151.2	151.2	93.6	93.7
TENASKA POWER SERVICES CO	6.3	171.9	171.9	97.6	98.2
TOPAZ POWER MANAGEMENT LP (SQ1)	1.7	180.8	180.8	99.9	99.9
TXU PORTFOLIO MANAGEMENT COMPANY LP (QSE)	27.8	143.0	143.0	92.2	93.2
TXU PORTFOLIO MANAGEMENT COMPANY LP (SQ1)	62.8	120.8	120.8	12.1	12.1

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6