

SCE Compliance Monthly Report November, 2007

Date of Report Generation: 12/5/2007

QSE	Avg SCE (1min) All Intervals	SCE PERFORMANCE CRITERIA			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score %	Unadj. Score %	Adj. Score %
FULCRUM POWER SERVICES LP (SQ1)	0.3	200.7	200.7	99.9	99.9
BPTX (SQ1)	3.2	207.8	207.8	99.6	99.6
BTU SQ1	1.6	149.6	149.6	99.3	99.3
TOPAZ POWER MANAGEMENT LP (SQ1)	1.4	189.2	189.2	99.0	99.0
LOWER COLORADO RIVER AUTHORITY (QSE)	9.6	182.3	182.3	98.8	98.8
TENASKA POWER SERVICES CO	5.2	177.8	177.8	98.6	98.6
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	2.2	186.0	186.0	98.4	98.4
BPTX (SQ2)	4.2	197.7	197.7	98.3	98.3
FPL ENERGY POWER MARKETING	9.9	178.5	178.5	98.1	98.1
RIO NOGALES POWER PROJECT LP (QSE)	5.2	202.4	202.4	98.1	98.1
CONSTELLATION ENERGY COMMODITIES GROUP INC C (QSE)	6.1	220.6	220.6	97.9	97.9
ENERGYCO MARKETING AND TRADING LLC (QSE)	2.5	206.6	206.6	97.7	97.7
CORAL POWER LLC	6.8	214.1	214.1	97.6	97.6
BPTX (SQ3)	4.0	177.4	177.4	97.6	97.6
CONSTELLATION ENERGY COMMODITIES GROUP INC (QSE)	1.7	217.6	217.6	97.5	97.5
OCCIDENTAL POWER SERVICES INC	4.5	169.4	169.4	97.2	97.2
FORMOSA UTILITY VENTURE LTD (QSE)	4.0	200.9	200.9	97.1	97.1
BTU QSE SERVICES INC	4.7	133.5	133.5	97.0	97.0
EXELON GENERATION COMPANY LLC	4.0	195.5	195.5	96.9	96.9
CORAL POWER LLC (SQ2)	12.0	209.9	209.9	96.5	96.5
IPA MARKETING INC (SQ1)	5.3	178.5	178.5	96.3	96.3
CITY OF GARLAND (QSE)	2.9	187.7	187.7	96.2	96.2
DIRECT ENERGY LP	9.0	207.8	207.8	95.8	95.8
ANP FUNDING I LLC	6.3	199.9	199.9	95.4	95.4
NRG TEXAS POWER LLC (QSE)	15.0	158.1	158.1	95.2	95.2
EAGLE ENERGY PARTNERS I LP (QSE)	4.8	186.4	186.4	94.0	94.0
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	11.6	174.1	174.1	93.8	93.8
RELIANT ENERGY POWER SUPPLY LLC	9.6	209.1	209.1	88.2	93.0
CITY OF SAN ANTONIO CITY PUBLIC SERVICE (QSE)	11.2	171.2	171.2	92.9	92.9
CALPINE POWER MANAGEMENT LP	17.9	164.2	164.2	92.2	92.2
AMERICAN ELECTRIC POWER SERVICE CORP	9.7	168.9	168.9	90.4	90.4
LUMINANT ENERGY COMPANY LLC (QSE)	25.7	157.7	157.7	90.0	90.0
TRQ1 (SQ1)	5.8	204.6	204.6	88.7	89.8
BRAZOS ELECTRIC POWER CO OP INC (QSE)	7.2	182.2	182.2	89.0	89.6
SUEZ ENERGY MARKETING NA INC	24.9	194.8	194.8	78.1	79.7
Wind Only					
SWEETWATER WIND 5 LLC (QSE)	8.2	198.8	198.8	71.0	71.0
AMERICAN ELECTRIC POWER SERVICE CORP (SQ3)	11.4	183.3	183.3	59.0	59.0
SCURRY COUNTY WIND LP (QSE)	19.0	192.8	192.8	51.4	51.4
FPLE PMI (SQ1)	32.5	188.0	188.0	32.8	32.8
FPLE_WIND_FPL ENERGY POWER MARKETING INC.(SQ2)	24.7	180.3	180.3	26.0	26.0
FPL ENERGY POWER MARKETING INC (SQ3)	64.4	184.8	184.8	20.7	20.7
DIRECT ENERGY LP WTU (SQ2)	52.2	112.1	112.1	17.4	17.4
CITY OF SAN ANTONIO CITY PUBLIC SERVICE CPS WIND (SQ1)	64.6	133.8	133.8	12.7	12.7
LUMINANT ENERGY COMPANY LLC (SQ1)	81.1	106.4	106.4	11.4	11.4

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6