

**Seasonal Assessment of Resource Adequacy for the ERCOT Region  
Winter 2011-2012**

Draft 1 – Released December 1, 2011

**SUMMARY**

The ERCOT Region should have sufficient installed generating capacity for the Winter 2011/2012 season to cover peak demands resulting from normal or extreme weather conditions with a historically-typical amount of generation outages. However, if extreme weather results in a significantly-higher than normal number of forced generation outages and high electrical demand, the ERCOT system could have insufficient resources available to serve that demand. This insufficiency would result in the need for rotating outages to maintain the integrity of the system as a whole.

In addition, the continuing drought has resulted in the water sources for over 11,000 MW of generation to be at historically-low levels. Low water levels could result in some portion of this generating capacity becoming unavailable during the winter. Such unavailability would reduce the severity of forced outages or demand at which rotating outages could be required.

**Seasonal Assessment of Resource Adequacy for the ERCOT Region**

**Winter 2011-2012**

Draft 1 - Released December 1, 2011

**Range of Likely Risks**


Installed Capacity, MW	64,363	Based on current Seasonal Maximum Sustainable Limits reported through Registration process	
Planned Units (not wind) with Signed IA and Air Permit, MW	30	Based on in-service dates provided by developers of generation resources	
Capacity from Private Networks, MW	4,390	Based on actual net PUN output during non-EEA periods of August 2011	
Switchable Units, MW	3,168	Installed capacity of units that can switch to other Regions	
less Switchable Units Unavailable to ERCOT, MW	(317)	Based on survey response of Switchable Unit owners	
RMR Units to be under Contract, MW	-		
Effective Load-Carrying Capability (ELCC) of Wind Generation, MW	834	Based on 8.7% of installed capacity (Effective Load Carrying Capability) of wind per Planning Guide Section 8	
ELCC of Planned Wind Units with Signed IA, MW	-	Based on in-service dates provided by developers of generation resources	
50% of Non-Synchronous Ties, MW	553	Based on 50% of installed capacity of ties, per Planning Guide Section 8	
<b>a Total Resources, MW</b>	<b>73,021</b>		
<b>b Winter Peak Demand, MW</b>	<b>53,562</b>	Updated 50% Probability forecast based on recent Moody's economic forecast and revised weather profile including 2011 impacts	
<b>c Reserve Capacity (a -b), MW</b>	<b>19,459</b>		
		<b>Extreme</b>	<b>Extreme/ Full</b>
	<b>Base Case</b>	<b>Conditions</b>	<b>Drought Impact *</b>
			* - Column added due to current drought risk
Extreme Load Range	-	6,427	6,427
Typical Maintenance Outages	5,268	5,268	5,268
90th Percentile Maintenance Outages	-	4,244	4,244
Typical Forced Outages	3,759	3,759	3,759
90th Percentile Forced Outages		2,645	2,645
Forced Outages due to Drought (minimum)	24	24	
Forced Outages due to Drought (maximum)	-		11,464
<b>d Total Uses of Reserve Capacity</b>	<b>9,051</b>	<b>22,367</b>	<b>33,807</b>
<b>e Capacity Available for Operating Reserves (c-d), MW</b>	<b>10,408</b>	<b>(2,908)</b>	<b>(14,348)</b>
Less than 2300 MW indicates risk of EEA1			

**Seasonal Assessment of Resource Adequacy for the ERCOT Region  
Winter 2011-2012**

Draft 1 - Released December 1, 2011

**Analysis of All Sensitivities**

Installed Capacity, MW	64,363	Based on current Seasonal Maximum Sustainable Limits reported through Registration process										
Planned Units (not wind) with Signed IA and Air Permit, MW	30	Based on in-service dates provided by developers of generation resources										
Capacity from Private Networks, MW	4,390	Based on actual net PUN output during non-EEA periods of August 2011										
Switchable Units, MW	3,168	Installed capacity of units that can switch to other Regions										
less Switchable Units Unavailable to ERCOT, MW	(317)	Based on survey response of Switchable Unit owners										
RMR Units to be under Contract, MW	-											
Effective Load-Carrying Capability (ELCC) of Wind Generation, MW	834	Based on 8.7% of installed capacity (Effective Load Carrying Capability) of wind per Planning Guide Section 8										
ELCC of Planned Wind Units with Signed IA, MW	-	Based on in-service dates provided by developers of generation resources										
50% of Non-Synchronous Ties, MW	553	Based on 50% of installed capacity of ties, per Planning Guide Section 8										
<b>a Total Resources, MW</b>	<b>73,021</b>											
<b>b Winter Peak Demand, MW</b>	<b>53,562</b>	Updated 50% Probability forecast based on recent Moody's economic forecast and revised weather profile including 2011 impacts										
<b>c Reserve Capacity (a - b), MW</b>	<b>19,459</b>											
	1	2	3	4	5	6	7	8	9	10	11	12
	Expected Load, No Drought Impact			Extreme Load, No Drought Impact			Expected Load, Full Potential Drought Impact			Extreme Load, Full Potential Drought Impact		
	Typical Forced and Planned Outages	High Forced Outages	High Forced and Planned Outages	Typical Forced and Planned Outages	High Forced Outages	High Forced and Planned Outages	Typical Forced and Planned Outages	High Forced Outages	High Forced and Planned Outages	Typical Forced and Planned Outages	High Forced Outages	High Forced and Planned Outages
	19,459	19,459	19,459	19,459	19,459	19,459	19,459	19,459	19,459	19,459	19,459	19,459
Extreme Load Range	-	-	-	6,427	6,427	6,427	-	-	-	6,427	6,427	6,427
Typical Maintenance Outages	5,268	5,268	5,268	5,268	5,268	5,268	5,268	5,268	5,268	5,268	5,268	5,268
90th Percentile Maintenance Outages			4,244			4,244			4,244			4,244
Typical Forced Outages	3,759	3,759	3,759	3,759	3,759	3,759	3,759	3,759	3,759	3,759	3,759	3,759
90th Percentile Forced Outages		2,645	2,645		2,645	2,645		2,645	2,645		2,645	2,645
Forced Outages due to Drought (minimum)	24	24	24	24	24	24	24	24	24	24	24	24
Forced Outages due to Drought (maximum)							11,464	11,464	11,464	11,464	11,464	11,464
<b>d Total Uses of Reserve Capacity, MW</b>	<b>9,051</b>	<b>11,696</b>	<b>15,940</b>	<b>15,478</b>	<b>18,123</b>	<b>22,367</b>	<b>20,491</b>	<b>23,136</b>	<b>27,380</b>	<b>26,918</b>	<b>29,563</b>	<b>33,807</b>
<b>e Capacity Available for Operating Reserves (c-d), MW</b>	<b>10,408</b>	<b>7,763</b>	<b>3,519</b>	<b>3,981</b>	<b>1,336</b>	<b>(2,908)</b>	<b>(1,032)</b>	<b>(3,677)</b>	<b>(7,921)</b>	<b>(7,459)</b>	<b>(10,104)</b>	<b>(14,348)</b>
Less than 2300 MW indicates risk of EEA1												



**Winter Inputs**

**2012**

**Load Forecast:**

Total Summer Peak Demand, MW	53,562																			
less Energy Efficiency Programs (per SB1125)	119																			
less LAARs Serving as Responsive Reserve, MW	1,038																			
less Emergency Interruptible Load Service	420																			
Firm Load Forecast, MW	51,985																			

**Resources:**

Installed Capacity, MW	64,363																			
Capacity from Private Networks, MW	4,390																			
ELCC* of Wind Generation, MW	834																			
RMR Units to be under Contract, MW	-																			
Operational Generation, MW	69,587																			
Non-Synchronous Ties, MW	553																			
Switchable Units, MW	3,168																			
Available Mothballed Generation, MW	496																			
Planned Units (not wind) with IA and Air Permit, MW	30																			
ELCC* of Planned Wind Units with Signed IA, MW	-																			
Total Resources, MW	73,834																			
less Switchable Units Unavailable to ERCOT, MW	317																			
less future Unit Retirements, MW	-																			
Resources, MW	73,517																			

**Reserve Margin** (Resources - Firm Load Forecast)/Firm Load Forecast **41.42%**

Updated 50% Probability forecast based on recent Moody's economic forecast and revised weather profile including 2011 impacts  
 Projected based on SB1125 assuming that 50% of the energy efficiency target is included in the model  
 Projected based on Planning Guide Section 8  
 Projected based on Planning Guide Section 8

Based on current Seasonal Maximum Sustainable Limits reported through Registration process  
 Based on actual net PUN output during non-EEA periods of August 2011  
 Based on 8.7% of installed capacity (Effective Load Carrying Capability) of wind per Planning Guide Section 8

Based on 50% of installed capacity of ties, per Planning Guide Section 8  
 Installed capacity of units that can switch to other Regions  
 Based on sum of Installed Capacity of each Mothballed Unit times Probability of Return to Service from survey response by owner of the Unit  
 Based on in-service dates provided by developers of generation resources  
 Based on in-service dates provided by developers of generation resources

Based on survey response of Switchable Unit owners

\*Effective Load-Carrying Capability

<b>Scenario Inputs</b>	Expected Load Adder	-	
	Extreme Load Adder	6,427	Based on load forecast using actual extreme weather year (2011) temperatures
	Typical Maintenance Outages	5,268	Based on average of historic planned outages for hour ending 7-10 of Dec,Jan,Feb weekdays
	90th Percentile Maintenance Outages	4,244	Based on historic planned outages for hour ending 7-10 of Dec,Jan,Feb weekdays
	Typical Forced Outages	3,759	Based on average of historic forced and maint-level outages for hour ending 7-10 of Dec,Jan,Feb weekdays
	90th Percentile Forced Outages	2,645	Based on historic forced and maint-level outages for hour ending 7-10 of Dec,Jan,Feb weekdays
	Low Wind		
	Forced Outages due to Environmental Restrictions		Monticello 1&2 mothballing already included in Installed Capacity
	Forced Outages due to Drought (minimum)	24	Current unavailability
	Forced Outages due to Drought (maximum)	11,464	MW of generation with water sources that are currently at historic lows
<b>Total Uses of Reserves</b>			

## Seasonal Assessment of Resource Adequacy for the ERCOT Region

### Background

The Seasonal Assessment of Resource Adequacy (SARA) report is a deterministic approach to considering the impact of potential variables that may impact the sufficiency of installed resources to meet the peak electrical demand on the ERCOT System during a particular season.

The standard approach to assessing resource adequacy for one or more years into the future is to account for projected load and resources on a normalized basis and to require sufficient reserves (resources in excess of peak demand, on this normalized basis) to cover the uncertainty in peak demand and resource availability to meet a one-in-ten-years loss-of-load event criteria on a probabilistic basis.

For seasonal assessments that look ahead less than a year, specific information may be available (such as seasonal climate forecasts or anticipated common-mode events such as drought) which can be used to consider the range of resource adequacy in a more deterministic manner.

The SARA report is intended to illustrate the range of resource adequacy outcomes that might occur. Several sensitivity analyses are developed by varying the value of certain parameters that affect resource adequacy. The variation in these parameters is either based on historic values of these parameters, adjusted by any known or expected change.