



Compliance Update

June 2006

Control Performance Highlights


❑ NERC CPS1 Performance

- ERCOT's May's score was 146.1
- May has typically been ERCOT's poorest performing month
- ERCOT's CPS1 scores show significant improvement over the same month for the past three years with the exception of January since the implementation of PRR525.


❑ PRR 525 Performance

- 27 passed / 5 non-wind-only QSEs failed the measure in April
 - 28 passed / 5 non-wind-only QSEs failed the measure in May (preliminary)
 - Scores posted on the ERCOT Compliance Web Page
 - Performance of Wind-Only QSEs appears to be declining
-


ERCOT CPS1 Performance Comparison




ERCOT's CPS1 Monthly Trend



ERCOT CPS1 by Interval




QSE PRR525 10-Minute Interval Scoring



SCE Performance Monitoring

- SCE Performance Monitoring scores for all QSEs are published on the Compliance Website
 - [SCE Performance Scores](#)
-

525 Passing 10-Min Interval Percentage Trends



ERCOT Compliance Process

□ Current Timeline

- May 12th – ERCOT files new redline
 - May 22nd – Replies to ERCOT redline (include redlines if any)
 - May 31st – Workshop to review all redlines and get consensus on most or all of document – all day if necessary
 - June 6th – ERCOT files revisions
 - June 13th – Deadline for filing hearing request
 - June 27th – Pre-hearing conference if necessary
-

NERC ERO Filing Developments

- ❑ ERCOT Compliance is continuing to collect contact information from ERCOT Entities responsible for NERC Reliability Standards. This is in support of NERC's filing to be the Electric Reliability Organization (ERO).
 - ❑ NERC is asking each Region to supply a draft Regional Delegation Agreement by August 1, 2006
-