



CREZ Transmission Challenges




Cost of 3000 MW Transmission Alternatives



Note: Transmission line and substation costs based on Frontier Line transmission subcommittee and NTAC unit cost data.




Cost of 6000 MW Transmission Alternatives



Note: Transmission line and substation costs based on Frontier Line transmission subcommittee and NTAC unit cost data.



Cost of 6000 MW Transmission Alternatives




Note: Transmission line and substation costs based on Frontier Line transmission subcommittee and NTAC unit cost data.




Transmission Alternatives Loss Comparison

Loss Comparison for 3000 MW Transmission



Post-Contingency Capacity – 3000 MW Base




N-1 = Loss of one circuit or pole, excluding loss of tower

N-2 = Loss of two circuits, one double circuit or bipolar line




Post-Contingency Capacity – 6000 MW Base




N-1 = Loss of one circuit or pole, excluding loss of tower

N-2 = Loss of two circuits, one double circuit or bipolar line


Generator Outlet HVDC, Sink-Link EHVAC




Panhandle Outlet HVDC, Central Outlet UHV AC




Generator Outlet HVDC, Sink-Link EHVAC



HVDC Light On/Off Ramps to UHV AC



HVDC Light – Add Offshore CREZ



Cost Benefit Screening Analysis Example

TOTAL SYSTEM			
Trans Option No.	T4	Installed Cost (\$Million)	1,302
		Capacity (MW)	3,000
Description	Panhandle - DFW 500 kV DC bipole		
Line Utilization	41%		

Note: Example makes use of Frontier Economic Analysis Screening Tool


	(\$/MWh)	Regional Difference			Annual Benefits (\$Million)	Annual Cost (\$Million)
		Source (\$/MWh)	Sink (\$/MWh)	Diff (\$/MWh)		
Line Cost	12.8					137
Power Cost		52.5	73.9	21.3	229	
GHG Adder		0.0	23.2	23.2	249	
CO2 for EOR		0.0	0.0	0.0	0	
Renewable Credit		0.0	0.0	0.0	0	
System Integration		3.0	0.0	-3.0	-32	
Prod Tax Credit		0.0	0.0	0.0	0	
Losses		2.5		-2.5	-27	
Grid Eff		0.0		0.0	0	
Dependable Cap Value			-5.0	-5.0	-54	*
TOTAL		58.0	92.0	34.0	365	137
Benefit to Cost Ratio	2.66					

Source: 3500 MW Wind @35% CF
Sink: 2400 MW fossil mix

*Accounting for dependable capacity difference? Yes

- Export transmission and S/S costs only – does not include collector system costs or receiving system reinforcements.
- Transmission distance of 400 miles to account for practical line route
- Transmission capacity deemed firm, i.e., no congestion
- Screening tool only – not production cost simulation

BC Ratio Break-Even Curve



Cost Benefit Screening Analysis Comparison

Texas Panhandle to Dallas-Ft Worth 3000 MW Transmission Alternative					
Scenario		T1	T2	T3	T4
Source	Coal - PC				
	Coal - CCS				
	Wind	3,500	3,500	3,500	3,500
Sink	Gas CC	900	900	900	900
	Gas CT	1,000	1,000	1,000	1,000
	Coal - PC	500	500	500	500
Net Line Capacity	MW	3,000	3,000	3,000	3,000
Line Segments		2 x 345 KV (AC) dbl ckt	1 x 500 KV (AC) dbl ckt	1 x 765 KV (AC) single ckt	1 x 500 KV (DC) bipole
Line + S/S Costs	\$ Million	\$2,081	\$1,717	\$1,802	\$1,302
Line + S/S Losses		10.2%	7.4%	5.6%	4.8%
Financing		Utility	Utility	Utility	Utility
GHG Adder		\$40	\$40	\$40	\$40
Dependable Capacity		Yes	Yes	Yes	Yes
GWH		10,731	10,731	10,731	10,731
		T1	T2	T3	T4
Results					
B/C Ratio		1.58	1.98	1.95	2.66
Benefits (\$MM)		\$334	\$350	\$360	\$365
Costs (\$MM)		\$212	\$177	\$185	\$137
Savings (\$MM)		\$122	\$173	\$175	\$228
Value (\$/MWh)		\$11.37	\$16.12	\$16.31	\$21.25

- Export transmission costs only – does not include collector system costs or receiving system reinforcements.
- Transmission distance of 400 miles to account for practical line route
- Transmission capacity deemed firm, i.e., no congestion
- Screening tool only – not production cost simulation



Line Loading Capability

Line Type	Voltage kV	Conductor kcmil	Thermal Limit of Line GW	Thermal Limit of Terminal Equipment GW	SIL GW	1.5 x SIL GW	Req'd no. of lines - EHVAC at 1.5 x SIL		Charging per 100 mi MVar
							8 GW	12 GW	
EHVAC - UHVAC	345	2 x 954	1.2	2.4	0.4	0.6	14	21	80
	500	2 x 2312	2.9	3.5	0.8	1.3	7	10	180
	765	5 x 795	6.0	4.0	2.3	3.5	3	4	460
	1000	8 x 795	12.5	5.2	3.9	5.9	2	3	800
HVDC	±500	3 x 2515	5.3	4.0	n.a.	n.a.	2	3	n.a
	±600	3 x 2515	6.3	4.8	n.a.	n.a.	2	3	n.a
	±800	5 x 795	7.6	6.4	n.a.	n.a.	2	2	n.a

- More lines are needed with lower transmission voltage. Loadability increases and number of ac lines can be reduced by series compensation.
- Potential issues with induction generation and series compensation.
- Fewer lines and less need for series compensation with UHV. More shunt compensation is needed at light load to absorb excess charging.
- Larger contingency impact with fewer lines or circuits – savings v SPS
- Conventional HVDC converters are subject to minimum short circuit capacities relative to transmitted power – ac voltage stability issue
- Reactive power compensation issues: AC – distributed, DC - local
- Interconnection issues are similar – the collector and receiving networks must be able to handle the power

