



# System Planning Report


Bill Bojorquez – VP of Planning

Dan Woodfin – Director of System Planning

- ERCOT is currently tracking 233 active generation interconnection requests totaling over 103,000 MW. This includes almost 46,000 MW of wind generation
- New Interconnect Agreements signed in February:
  - Sherbino Mesa Wind Farm (06INR0012) for 300 MW in Pecos County
  - Coyote Run Wind Farm (07INR0036) for 184 MW in Borden County
- Regional Planning Group is currently reviewing proposed transmission improvements with a total cost of \$180 million
- Final Wind Impact Study presented to the ROS Wind Impact Task Force on Feb. 27 (discussed further in this report)
- CREZ Transmission Optimization (CTO) study is under way (discussed further in this report)

# Tyler Grande Project

# Description of Recommendation



- Use a spare 345/138 kV auto at the Tyler Grande Switching Station (Southeast)  
**Cost: \$3,665,000**
- Install 4-ohm 138 kV switchable series reactors on the Tyler Grande autotransformer  
**Cost: \$1,500,000**
- Rebuild the Tyler Grande – Tyler South 138 kV line so that the Rate B is 326 MVA. The circuit will be rebuilt for double circuit operation with one circuit being the circuit from Tyler Grande – Tyler Elkton and the other circuit being a radial feed to Tyler South.  
**Cost: \$2,750,000**
- Upgrade the Tyler Northeast – Tyler East 138 kV line so that the Rate B is 326 MVA  
**Cost: \$1,900,000**
- Upgrade the Tyler GE – Tyler Omen Road 138 kV line so that the Rate B is 326 MVA  
**Cost: \$1,300,000**
- **TOTAL COST: \$11,115,000**

- The Stakeholder review period for this project was held in September 2007
- There were no dissenting comments on this package and Oncor & Luminant resolved all questions
- Scheduled in-service prior to Summer 2009


- **Reliability Justified Projects** – lowest cost solution to alleviate unserved energy caused by overloads on two 138 kV lines and the Elkton 345/138 kV autotransformer
  - Addition of the 345/138 kV autotransformer using a spare 493 MVA autotransformer
  - Rebuild of the Tyler Grande – Tyler South 138 kV line so that the Rate B is 326 MVA
- **Economically Justified Projects** – expected production cost savings over 2009-2012 period of ~\$38 million for capital cost of \$4.7 million
  - Upgrade the Tyler Northeast to Tyler East 138 kV line so that the Rate B is 326 MVA
  - Upgrade the Tyler GE to Tyler Omen Road 138 kV line so that the Rate B is 326 MVA
  - Addition of the 138 kV series reactors on the Tyler Grande autotransformer

- ERCOT recommends that the project be endorsed by the ERCOT Board Of Directors.

# Competitive Renewable Energy Zone (CREZ) Transmission Optimization Study Update





# Designated Zones and Scenario Wind Levels




Capacity of New CREZ Wind by Scenario (MW)				
Wind Zone	Scen. 1	Scen. 2	Scen. 3	Scen. 4
Panhandle A	1,422	3,191	4,960	6,660
Panhandle B	1,067	2,393	3,720	0
McCamey	829	1,859	2,890	3,190
Central	1,358	3,047	4,735	5,615
Central West	474	1,063	1,651	2,051
<b>Total*</b>	<b>12,053</b>	<b>18,456</b>	<b>24,859</b>	<b>24,419</b>
* Assumes 6,903 MW of existing wind capacity				

# Scope of Study




# Study Approach

- Develop a number of significantly different core concepts and test their performance
- Variations on the concepts with best performance will be developed and tested
- The best performing plan will be selected for the scenario



# Study Approach

- May use the same core concepts as bases for significantly different plans in different scenarios



- But a different core concept may provide the basis for the preferred plan for a different scenario

- **Will develop a preferred plan that is optimized for each of the four scenarios**
- **Will provide expansion path of what elements in each of these plans should be built first if that Scenario is selected (except for Scenario 1)**
  - Use lower scenarios as basis
- **Will develop an expansion path from the preferred plan for the lower scenarios, so as to allow for consideration of future expandability of those plans**
  - Using next higher scenario as basis

# Staging and Expandability



- **To be updated**

- **Performed by General Electric consulting group with input from ERCOT Staff and a task force of stakeholders from the Reliability and Operations Subcommittee (ROS)**
- **Studied need for additional or modified ancillary services to meet reliability requirements, based on:**
  - 2008 load level and installed thermal generation
  - Four scenarios of installed wind generation, distributed among potential CREZ areas
    - 5,000 MW; 10,000 MW; 10,000 MW with different geographic distribution; and 15,000 MW
  - Used actual 2006 load pattern and used 2006 weather patterns to drive simulation of wind generation that would occur if these amounts of wind generation were installed



- **Need to implement state-of-the-art wind power production forecast**
  - Protects against under-commitment due to predictable changes in wind (reliability issue)
  - Protects against over-commitment (economic issue)
  - Acceleration of nodal project on wind forecasting
- **Present ERCOT methodology for determining regulation requirement remains effective if adjusted for increasing installed wind capacity (increase is linear)**
- **Regulation requirements (average, annual) increase linearly with increase in installed wind generation, up to 20-23% for 15,000MW**
  - Requirements vary by season and time of day

- **Daily swings in net load (load-wind) increase significantly with increasing wind**
- **Occasional down regulation exhaustion may occur with base load generation at bottom and all cycling units offline for >5000MW of wind generation**
  - Several alternatives to resolve this issue, including wind curtailment
  - Added volatility will demand faster response from offline units (i.e. startup) and more ramping capability in non-wind generation
- **Extreme wind power increases and decreases will occur infrequently (up to 20% within 30 mins), but are predictable with wind forecast**
  - Increase responsive and/or non-spin reserves during these periods
- **Localized convective events are less predictable; large concentrations of wind increases vulnerability but CREZ geographic diversity helps**

Questions?