

# **April 2008 Grid Operations**

## ERCOT Board of Directors 17 June 2008


Kent Saathoff

## Content

- Peak Demands: Actual vs. Forecast On-line Resources: Total at Peak and Wind
- Load Forecast Performance
- Out of Merit Capacity Order (OOMC) & Reliability Must Run (RMR) Purchases
- Zonal Congestion
- Significant System Incidents
- Advisories, Alerts and EECPs
- Other Items
- 2008 ERCOT Hurricane Drill



#### Daily Peak Demands: Hourly Average Actual vs Forecast Resource Plan: On-line Capacity at Peak






Note: Preliminary data obtained from EMS hourly averages.

3

## Monthly Peak Demands: Actual






	Mean Absolute Percent Error (MAPE) for Mid-Term Load Forecast (MTLF) Run at 16:00 Day Ahead					
	2005 MAPE	2006 MAPE	2007 MAPE	2008 MAPE (YTD)	April 2008 MAPE	
Average Annual MAPE	4.56	3.79	3.55	3.16	2.45	



#### Capacity Purchases for RMR OOMC & RORS to Manage Local Congestion in April 2008



CSC	April 08 Days	April 07 Days	Last 12 Months Total Days
North – Houston	<b>15</b> Apr – 1-4,7-11,15,23-26,30	12	106
North – West	North – West 4 Apr – 6,12-14		60
West – North	<b>26</b> Apr – 1,4-12,14-17,19-30	5	118
South – North	<b>11</b> Apr – 1-5,14,18,25,28-30	0	34
North - South	<b>16</b> Apr – 2,3,5,7,10,14,15,17,20-27	N/A	41



## Significant System Incidents in April 2008

- April 3<sup>rd</sup> Simultaneous loss of Oklaunion Bowman & Abilene Mulberry Creek 345 kV lines and 345/138 kV Autotransformer (Auto) at Oklaunion
  - Due to flashover on a contaminated insulator.
- April 9<sup>th</sup> Simultaneous loss of Graham Breckenridge & Leon Switch 138 kV lines and one 138/69 kV Auto at Breckenridge
  - Due to tornado in the area.
- April 10<sup>th</sup> DCS Event

Simultaneous loss of one unit and the East DC Tie totaling 1083 MW, Venus #2 Bus and 345/138 kV Auto at Venus

– Due to storms in North Texas.



## **Advisories and Alerts in April 2008**

- Advisories issued for Adjusted Responsive Reserve (ARR) below 3000 MW.
  - Issued 1 Day.
- No alerts issued for ARR below 2500 MW.
- No Transmission Alerts.
- No EECPs implemented.



### **Other Items**

- Held the following intervals due to interconnect errors between market databases, issues have been fixed since April 22<sup>nd</sup>:
  - April 13<sup>th</sup> Interval Ending (IE) 08:45
  - April 14<sup>th</sup> IE 08:30
  - April 18<sup>th</sup> IE 18:15
- April 12<sup>th</sup>
  - Held IE 23:00 due to input error in offset calculation.
- April 21<sup>st</sup>
  - Held IE 08:45 09:15 & IE 11:00 12:15 due to storage array failure.
- April 24<sup>th</sup>
  - Held IE 16:45 due to no Energy Schedules for a QSE.



- Conducted by the ERCOT System Operations training group on May 12 - 14 to simulate a category 4 Hurricane along the Texas coast making landfall at San Antonio Bay causing multiple transmission outages and generation shortages.
- ERCOT Operations along with 286 operators and energy schedulers from 16 TDSPs and 27 QSEs across the ERCOT region participated. The PUCT observed the drill from the Centerpoint control center.
- Backup emergency plans and communications with ERCOT were tested as well as simulated restoration activities.
- Overall feedback from the participants of the drill was positive. A summary will be presented to working groups of the Reliability and Operations Subcommittee to review the results and effectiveness as well as recommend changes if necessary.
- The next drill is the Winter Storm drill planned for the fall of 2009.



## **Questions?**