




Climate &  
Renewables

# CRE criteria refinement: CRE fitness (regression) test result

May 28, 2009

Peter Son, Ph.D, MBA, PE

Director, Transaction Analysis & Congestion Management



1. Introduction
2. CRE fitness test method
3. CRE fitness test sample
4. CRE fitness test result (Individual, Distribution)
5. Result comparison
6. Conclusion

- **Correlation of CRE is not a new measure, already defined in Protocol**

### 7.2.3 Determining Closely Related Elements (CREs)

For each year, ERCOT staff shall identify potential CREs using, at a minimum, the following process:

- (1) Determine the Zonal Average Shift Factor for a particular CSC ( $X_z$ ) for each Zone ( $z$ ).
- (2) Determine the zonal average Shift Factor for the candidate CRE ( $Y_z$ ) for each Zone  $z$  using the same generation weighting as in (1) but ignoring Boundary Generation Resource buses that would cluster into a different Congestion Zone with respect to the CRE.
- (3) Determine positive “a” applying least-square curve fitting to the following equation:

$$Y_z = a (X_z) + b_z \quad \text{for all Zones } z.$$

- (4) Using “a” from (3), determine the maximum absolute value of  $b_z$ .
- (5) Also determine the total capacity (MW) of Boundary Generation Resources that would cluster into a different Congestion Zone.
- (6) If the maximum absolute value of  $b_z$  is less than a threshold set by the appropriate TAC subcommittee, not to exceed 0.2, and the total capacity of Boundary Generation Resources that would cluster into a different Congestion Zone is less than 1,500 MW, then the element is a CRE for the particular CSC.

**Threshold for CRE fitness**


Not to exceed  
0.2

**傳家寶刀 Triumph Card  
(never verified later)**

- **Is 0.2 threshold a reasonable one? Then why? Never challenged before?**

- Data set: Most recent 2009 Fall Steady state case
- Analysis tool:
  - Luminant's analysis template (reviewed by CMWG)
  - PowerWorld - power flow analysis for calculating generation shift factor
- Approach
  - Selecting and testing good samples & bad samples for West to North CRE
  - Good samples (Current CREs) & Bad samples (Local lines not relevant to West to North CSC)
  - Reviewing the analysis result to see if the current threshold can filter out bad samples
  - Recommending a better threshold if any

# CRE fitness test sample (West to North)




- 12 Good Samples: Current CREs (in Blue)
- 13 Bad Samples: Local lines (in Pink)
  - DFW local lines (138 kV & 345 kV)
  - South local lines (138 kV)
  - Different directional lines (138 kV)


-  Current CSC
-  Bad Sample
-  Good Sample

# CRE fitness test result I (Individual line fitness)

The current threshold of **0.2** is too generous!



# CRE fitness test result II (Distribution)




**Recommendation: reasonable threshold is 0.05**

# Result comparison

## "Luminant's fitness test result"

Aggregation of Luminant's test results in April and May at CMWG/CRE meeting  
(Sample set includes all the lines considered for all zones)



**Recommendation: reasonable threshold is 0.05**



- **The current threshold cannot filter out clearly bad examples**
  - **As an example, if we follow the current threshold, ERCOT might manage DFW area local congestion by zonal bid stacks**
- **We recommend a **reasonable threshold of 0.05** found by the test**