



# **Reliability Analysis Update**

**Long Term Study Task Force**

**May 3rd, 2011**

- **Identify cost effective transmission solutions to maintain reliability for the 2030 ERCOT System under:**
  - N-1 Contingency
  - G-1 Contingency
  - Extreme Weather / Demand (2030 +5%)
- **Establish a workable case to identify economic transmission solutions**
- **Evaluation conducted using steady-state AC powerflow analysis on a peak load case**

# Reliability Screen – Resource Additions

- **Generic resources were added to serve increased load.**
- **Not related to the *separate* Generation Expansion scenarios used in the Economic Analysis portion.**
- **Analysis methodology decouples results from specific selected resource locations:**
  - Generators sited distant from area of study.
  - Different dispatches tested.
  - G-1 analysis performed, and in some cases groups of generator outages.
- **These considerations put focus of analysis on the import / transfer / load serving capability of the transmission system, rather than on deliverability of specific resources.**

# Reliability Analysis

## Steps in Reliability Analysis


1. **2030 Load: Base case and contingency analysis.**
2. **2030 + 5% Load: Load increased by 5% in the area of study. Base case and contingency analysis.**
3. **Generator contingency analysis.**
4. **Reactive needs analysis.**
5. **Combinatory generator outages.**

### Voltage and Loading Criteria


|     | Voltage (pu)                        | Branch Loading         |
|-----|-------------------------------------|------------------------|
| N-0 | $\geq 0.97$                         | $\leq 100\%$ of Rate A |
| N-1 | $\geq 0.93$ urban; $\geq 0.9$ rural | $\leq 100\%$ of Rate B |

# 2030 Loads

Non-coincident peak load  
2016: 76,551 MW  
2030: 93,304 MW



# Process



- **Voltage issues and thermal limitations are corrected where necessary**
  - Reactive support is applied at the most extreme busses in an iterative approach to correct voltage to .98 PU (N-0)
  - Address thermal overloads, as well as voltage collapse for (N-1)
- **Current status: Cases are stable, documentation of the reliability assessment is underway**
  - Includes N-1, G-1 stress testing of the steady-state model
  - NERC C & D criteria will be tested with proposed solutions

# Large Load Centers Currently in Study

- **DFW Metro Area**
- **Houston Metro Area**
- **Lower Rio Grande Valley**



- **Voltage deficiencies are significant and not correctable from incremental reactive resources (~7,500MVar of switched shunt compensation required for N-0).**
- **Limited 345kV/138kV transformer capacity yields significant overloads for the N-0 state**
- **Loading in the DFW Area represents almost 1/3 of the entire ERCOT load as modeled, and exceeds the current capability of the local 345kV infrastructure**


# Low Voltages and Transformer Overloads

| Station Name   | V(pu)  |
|----------------|--------|
| Anna           | 0.957  |
| Renner         | 0.958  |
| Collin         | 0.959  |
| Royse          | 0.962  |
| Allen          | 0.963  |
| Tyler Grande   | 0.9633 |
| Farmersville   | 0.967  |
| Elkton         | 0.9678 |
| Plano Tennyson | 0.9682 |

| 345/138 Auto   | N-0 % OL |
|----------------|----------|
| Eagle Mountain | 141      |
| Carrolton      | 123      |
| Collin         | 119      |
| Renner         | 111      |
| Liggett        | 109      |
| Roanoke        | 109      |
| Plano Tennyson | 108      |
| Anna           | 107      |
|                |          |

- **Heavy system loading and limited transformer capacity called for addition 345kV injection points**
- **Physical space limitations made new 345kV substations more practical than 2<sup>nd</sup> or 3<sup>rd</sup> transformers at existing 345kV substations in the Dallas / Fort Worth Metro Area**
- **The enhanced 345kV system, introducing a new 345kV “ring”, required less reactive support to maintain voltages within acceptable ranges**

# New 345kV Lines



| FROM        | TO           | LENGTH |
|-------------|--------------|--------|
| PARKER_5    | HANDLEY345   | 30     |
| HICKS_SW1_5 | SAGINAW345   | 20     |
| SAGINAW345  | HANDLEY345   | 15     |
| HANDLEY345  | EULESS345    | 20     |
| HACKBRY1_5  | EULESS345    | 10     |
| ANNASW_5    | ALLEN345     | 10     |
| ALLEN345    | PL_WEST345   | 10     |
| COLLINSS1_5 | CRLT         | 20     |
| PL_WEST345  | CRLT         | 7      |
| FARMVLSW_5  | ALLEN345     | 20     |
| ALLEN345    | COL_CRLT_345 | 20     |
| LEWISVLSW5  | COL_CRLT_345 | 20     |

## Other Changes to Base Case [N-0]

- Switched Shunts added for solving base case low voltage issues –

| Bus                | MVar Addition |
|--------------------|---------------|
| ROYSE SWITCH 345   | 800           |
| TYLER GRANDE 345   | 400           |
| EAGLE MOUNTAIN 138 | 600           |

- Line Changes to alleviate branch overloading -


| FROM        | TO       | LENGTH | Action                     |
|-------------|----------|--------|----------------------------|
| COLLINSS1_5 | ANNASW_5 | 13.2   | Re-conductor               |
| COLLINSS1_5 | ANNASW_5 | 13.2   | Added 2 <sup>nd</sup> ckt. |

# Conclusion for Dallas Fort Worth region

- **Significant local system needs identified in 2030 timeframe:**
  - Import paths are insufficient to accommodate load growth.
  - Large reactive deficiencies.
- **These are complex problems that will require continued ERCOT / TSP analysis.**
- **Studied solutions:**
  - 202 miles of new 345 kV, some extending into areas of high urban density.
  - Significant amounts of reactive support (switched shunts, SVCs); complete reactive solution may also require new import paths and/or rebuilding 138 kV → 345 kV.
  - New 345 / 138 kV connection points.

- **As modeled, 2030 Houston area load represents almost 25% of the entire ERCOT load.**
- **With considerable urban generation resources (Wharton, Parish, and several self-serve units), Houston is less reliant on imported power than Dallas and thus has far fewer import paths.**
- **Assuming all future load growth is met with resources outside Houston, the existing import paths are insufficient.**
- **More import paths would likely be needed (in addition to the planned Fayette – Zenith line).**
- **Analysis was conducted using two different dispatches: Heavy North Imports (HNI) and Heavy South/West Imports (HSWI).**

# N-1 Overloads – Heavy north imports




|                        |       |
|------------------------|-------|
| Singleton – Zenith     | 53 mi |
| Singleton – Kuykendahl | 47 mi |
| Zenith – THW           | 15 mi |
| Zenith – Obrien        | 17 mi |
| THW – Addicks          | 11 mi |
| WAP – Bellaire         | 25 mi |






# N-1 Overloads Heavy Southwest Imports

|                |       |
|----------------|-------|
| Zenith – THW   | 15 mi |
| THW – Addicks  | 11 mi |
| WAP – Bellaire | 25 mi |
| SoTex – WAP    | 68 mi |




# High Imports → Excessive Reactive Losses

*N-1 Reactive Losses shown for both High North Imports (HNI) and High Southwestern Imports (HSWI)*



- **Huge reactive losses on several import paths.**
- **Shunt capacitance alone is not a practical solution.**
- **Upgrading conductors provides little support.**
- **One solution: New import paths.**


# New Import Paths



## Some Options:

- **Lufkin – Canal (>100 mi)**
- **Salem – North Tie (>60 mi)**
- **Others?**

# New Import Path: Lufkin – Canal




➔ Under HNI, Lufkin – Canal is effective, reducing contingency overload and reactive losses on Singleton – Zenith.

➔ Under HSWI, Lufkin - Canal is ineffective and carries almost no power.

# Salem – North Belt: 2030+5% Heavy North Imports

High North Imports



→ This solution is effective for either dispatch: It greatly alleviates flow and losses on Fayette – Zenith as well as Singleton – Zenith.

## Lufkin – Canal

- **Helpful under high imports from North but not from S/W**
- **Reduces N-1 reactive losses on Singleton – Zenith from 3,500 MVAR to 2,000 MVAR. (N-0 decreases 1060 → 700 MVAR.)**
- **However, N-1 reactive losses on Lufkin – Canal: 1,130 MVAR.**

## Salem – North Tie

- **Helpful under both high imports from N and from S/W.**
- **Reduces N-1 reactive losses on Singleton – Zenith 3500 → 1320 MVAR. (N-0 decreases 1060 → 450 MVAR.)**
- **Reduces N-1 reactive losses on Fayette – Zenith 1600 → 1040 MVAR.**

# Houston Area 2030 Study Summary

- **Large amounts of shunt reactive compensation, some of it dynamic, appears necessary.**
- **Many existing 345 kV lines require upgrading before 2030 (about 240 miles). Most of these are still needed even if new import paths are added.**
- **From reliability analysis, at least one new import path needed by 2030.**
- **In progress / to do:**
  - Other import paths?
  - Economic evaluation of new import paths by scenario.


# Rio Grande Valley Study

- **Recent events highlight the need for significant reinforcements.**
- **Long Term Planning is working with Near Term Planning and TOs in ERCOT to find a solution that meets near term needs and is expandable for long term needs.**

| Load Assumptions (MW)                               |      |      |         |
|---|------|------|---------|
|   | 2020 | 2030 | 2030+5% |
| <b>South WZ</b>                                     | 6339 | 7325 | 7691    |
| <b>Starr,<br/>Hildago,<br/>Cameron<br/>counties</b> | 3348 | 3870 | 4063    |



# Import Limitations




Loss of this line exceeds import stability limit under 2020 and 2030 load levels.

Loss of this line exceeds stability limit under 2030 load levels.


Suggested recently in RPG

# Possible Solution for 2020

Make existing 345kV lines double circuit



# Possible Solution for 2030+5%



## Other Solutions Being Evaluated

- **Other transmission configurations, such as:**
  - Laredo – Caballo or Laredo – Corpus Christi.
  - Miguel – Caballo – Del Sol.
- **Technologies that reduce stability limit issues (e.g. 765 kV or HVDC).**
- **Local resources that would also reduce need for additional transmission**

- **Map the simplified transmission model to Promod**
- **Remove and replace any generation added for stability with generation fuel / location derived from Promod results.**
- **Perform a Promod run, identifying LMP values at each bus**
- **Evaluate cost-effectiveness of transmission options**

# Questions?