



Operations Analysis of the ERCOT Capacity, Demand and Reserves (CDR) Report

Bill Blevins

Generation Adequacy Task Force Meeting
August 1, 2011

Goal of Operations in analyzing the CDR

- Reconcile the CDR report in Real Time
- Identify impacts of Outages related to Capacity in the CDR and the impact to Reliability Margins
- Identify areas to focus on for improvement in the Operating Horizon(Current or upcoming season)

2011 Report on the Capacity, Demand, and Reserves in the ERCOT Region

Summer Summary

| Load Forecast: | | REAL TIME | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
|--|--|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| Total Summer Peak Demand, MW | | 62353 | 63,898 | 65,665 | 67,757 | 70,540 | 72,591 | 74,198 | 75,365 | 76,654 | 77,866 | 79,274 |
| less LAARs Serving as Responsive Reserve, MW | | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 |
| less LAARs Serving as Non-Spinning Reserve, MW | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| less Emergency Interruptible Load Service | | 421 | 421 | 463 | 509 | 560 | 616 | 678 | 745 | 820 | 902 | 992 |
| less Energy Efficiency Programs (per SB1125) | | 128 | 128 | 259 | 395 | 536 | 681 | 829 | 980 | 1133 | 1289 | 1448 |
| Firm Load Forecast, MW | | 60,742 | 62,286 | 63,880 | 65,790 | 68,381 | 70,231 | 71,628 | 72,576 | 73,638 | 74,612 | 75,771 |
| Resources: | | REAL TIME | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 |
| Installed Capacity, MW | | 56,244 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 |
| Capacity from Private Networks, MW | | 3,935 | 5,023 | 5,071 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 |
| Effective Load-Carrying Capability (ELCC) of Wind Generation, MW | | 1,378 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 |
| RMR Units to be under Contract, MW | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Operational Generation, MW | | 61,557 | 69,704 | 69,752 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 |
| 50% of Non-Synchronous Ties, MW | | 625 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 |
| Switchable Units, MW | | 2,830 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 |
| Available Mothballed Generation, MW | | 0 | 0 | 110 | 146 | 164 | 181 | 198 | 198 | 198 | 198 | 198 |
| Planned Units (not wind) with Signed IA and Air Permit, MW | | 0 | 260 | 1,940 | 1,940 | 2,720 | 4,880 | 5,500 | 6,780 | 6,780 | 6,780 | 6,780 |
| ELCC of Planned Wind Units with Signed IA, MW | | 70 | 13 | 65 | 113 | 131 | 131 | 131 | 131 | 131 | 131 | 131 |
| Total Resources, MW | | 65,082 | 73,492 | 75,382 | 75,469 | 76,284 | 78,461 | 79,099 | 80,379 | 80,379 | 80,379 | 80,379 |
| less Switchable Units Unavailable to ERCOT, MW | | 317 | 317 | 317 | 317 | 317 | 317 | 317 | 0 | 0 | 0 | 0 |
| less Retiring Units, MW | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Resources, MW | | 64,765 | 73,175 | 75,065 | 75,152 | 75,967 | 78,144 | 78,782 | 80,379 | 80,379 | 80,379 | 80,379 |
| Reserve Margin | | 6.6% | 17.5% | 17.5% | 14.2% | 11.1% | 11.3% | 10.0% | 10.8% | 9.2% | 7.7% | 6.1% |
| (Resources - Firm Load Forecast)/Firm Load Forecast | | | | | | | | | | | | |

Comparison July 14 2011 at 5:00 PM


2011 Report on the Capacity, Demand, and Reserves in the ERCOT Region

Summer Summary

| Load Forecast: | REAL TIME | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
|--|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| Total Summer Peak Demand, MW | 64180 | 63,898 | 65,665 | 67,757 | 70,540 | 72,591 | 74,198 | 75,365 | 76,654 | 77,866 | 79,274 |
| less LAARs Serving as Responsive Reserve, MW | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 | 1,063 |
| less LAARs Serving as Non-Spinning Reserve, MW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| less Emergency Interruptible Load Service | 421 | 421 | 463 | 509 | 560 | 616 | 678 | 745 | 820 | 902 | 992 |
| less Energy Efficiency Programs (per SB1125) | 128 | 128 | 259 | 395 | 536 | 681 | 829 | 980 | 1133 | 1289 | 1448 |
| Firm Load Forecast, MW | 62,568 | 62,286 | 63,880 | 65,790 | 68,381 | 70,231 | 71,628 | 72,576 | 73,638 | 74,612 | 75,771 |
| Resources: | REAL TIME | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 |
| Installed Capacity, MW | 57,094 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 | 63,859 |
| Capacity from Private Networks, MW | 3,581 | 5,023 | 5,071 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 | 5,074 |
| Effective Load-Carrying Capability (ELCC) of Wind Generation, MW | 2,065 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 | 822 |
| RMR Units to be under Contract, MW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Operational Generation, MW | 62,740 | 69,704 | 69,752 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 | 69,755 |
| 50% of Non-Synchronous Ties, MW | 731 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 | 553 |
| Switchable Units, MW | 2,861 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 | 2,962 |
| Available Mothballed Generation, MW | 0 | 0 | 110 | 146 | 164 | 181 | 198 | 198 | 198 | 198 | 198 |
| Planned Units (not wind) with Signed IA and Air Permit, MW | 0 | 260 | 1,940 | 1,940 | 2,720 | 4,880 | 5,500 | 6,780 | 6,780 | 6,780 | 6,780 |
| ELCC of Planned Wind Units with Signed IA, MW | 92 | 13 | 65 | 113 | 131 | 131 | 131 | 131 | 131 | 131 | 131 |
| Total Resources, MW | 66,424 | 73,492 | 75,382 | 75,469 | 76,284 | 78,461 | 79,099 | 80,379 | 80,379 | 80,379 | 80,379 |
| less Switchable Units Unavailable to ERCOT, MW | 317 | 317 | 317 | 317 | 317 | 317 | 317 | 0 | 0 | 0 | 0 |
| less Retiring Units, MW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Resources, MW | 66,107 | 73,175 | 75,065 | 75,152 | 75,967 | 78,144 | 78,782 | 80,379 | 80,379 | 80,379 | 80,379 |
| Reserve Margin | 5.7% | 17.5% | 17.5% | 14.2% | 11.1% | 11.3% | 10.0% | 10.8% | 9.2% | 7.7% | 6.1% |
| (Resources - Firm Load Forecast)/Firm Load Forecast | | | | | | | | | | | |

Operations Capacity and CDR comparison


0627 vs. 0714 vs. CDR Capacity



06/27/2011 1,500 MW of the Capacity was not submitted in the Outage Scheduler as a forced outage per Nodal Protocol 3.1.4.6 provisions but has been included in the forced outage category because the Resources tripped,

Summary for GATF

- The CDR Reserve margin in ERCOT typically will accommodate normal Forced Outage/Derate and load variation above normal. This margin can be consumed if both conditions occur simultaneously.
- Installed Capacity MW- Outages and Derates are consuming the capacity.
- Capacity from Private Networks are lower ERCOT is considering revising the questions sent to Private Networks to better capture expected output to the grid.
- Effective Load-Carrying Capability (ELCC) of Wind Generation, MW is producing higher and could be counted more in the CDR.
- Planned Units (not wind) with Signed IA and Air Permit, MW- Resource is delayed and is expected to be on in the fall.
- If in the next month the current Resource Forced Outage/Derate of capacity continues and ERCOT experiences loads above 66,500 MW then ERCOT would possibly be in an Energy Emergency Alert (EEA) level 1 or higher.



Thank U !!