



# Workshop on Factors Affecting Pricing during Reliability Deployments by ERCOT

John Dumas

Director Wholesale Market Operations

**PUCT Workshop on Factors Affecting Pricing during  
Reliability Deployments by ERCOT**

**August 22, 2011**

# Outline of Presentation

---

- **Review of Non-Spinning Reserve Deployments**
- **Review of Operating Days with Non-Spinning Reserve Deployments (July 13 and July 18)**
- **Review RUC Process**
- **Summary**

## **1. If 5 minute dispatch room is less than 200 MW then deploy Non-Spinning Reserve**

- Deploy half of Non-Spinning Reserve if total remaining offers in SCED are projected to be less than 1000 MW
- Deploy all Non-Spinning Reserve if total remaining offers in SCED are projected to be less than 500 MW

## **2. If Physical Responsive Capability (PRC) < 2500 MW**

- deploy enough to recover PRC to 2500 (Partial deployment of Non-Spin)

## **3. If Physical Responsive Capability (PRC) < 2300 MW**

- deploy ALL Non-Spin. (Full deployment of Non-Spin)

# July 13, 2011: Non-Spin Deployment

Non-Spin deployed at 14:39 in the amount of 2035 MW (ALL) and recalled at 19:30

- Between 13:40 and 14:35 the projected 30 minute SCED dispatch room went to 143 MW and then went negative (nearly -1000 MW)
- Between 14:30 and 14:40 the 5 minute dispatch room was (-7 MW@14:35).
- Load Forecast for HE 15 = 62798 MW
- Load Forecast for HE 16 = 64255 MW
- @14:35 System Lambda=\$2999.99
- @14:55 System Lambda=\$76.79
- PRC went below 2500 between 15:32 and 15:38
- Load increase from 14:35 to 14:55 = 540 MW
- LSL injection from off line non-spin (OFFNS) resources including offline non-spin quick starts (QSGR) not offered in SCED from 14:35 to 14:55 =  
 $219 \text{ ("OFFNS" QSGR)} + 104 \text{ ("OFFNS" Non-QSGR)} = 323 \text{ MW}$


# July 13 Non-Spin Deployment

<b>@14:35</b>	<b>LSL</b>	<b>Non-Spin Responsibility</b>
<b>“ON” Non-QSGR</b>	2247	649
<b>“OFFNS” Non-QSGR</b>	104	251
<b>“ON” QSGR</b>	433	844
<b>“OFFNS” QSGR</b>	219	291
<b>“OFF” Non-QSGR that came online by 14:55 not carrying ancillary reserve</b>	56	0
<b>“OFF” QSGR that came online by 14:55 not carrying ancillary reserve</b>	144	0

- Note 1: All are telemetry values at 14:35 (before Non-Spin Deployment)
- Note 2: Load increase from 14:35 to 14:55 = 540 MW
- Note 3: LSL injection from OFFNS resources from 14:35 to 14:55 =  
 $219 \text{ (“OFFNS” QSGR)} + 104 \text{ (“OFFNS” Non-QSGR)} = 323 \text{ MW}$
- Note 4: The total HSL from “OFF” Generation Resources that came online = 248 MW

# July 13, 2011: Non-Spin Deployment (continued)

Aggregated Energy Offer Curves (EOC) of Online Non-Spinning Reserve (excluding quick start resources) which is released to SCED upon deployment of Non-Spinning Reserve



RT Aggregate Offer Curve (Linear Plot)

20110713



- All OFFNS resources were offering an aggregate of 520 MW below \$100/MWh
- Offline Non-Spinning Reserve Resource offers are released to SCED upon deployment of Non-Spinning Reserve
- Off-Line generation providing Non-Spin must be On-Line at an output level at least equal to the Resource's LSL within 25 minutes
- Must be able to dispatch to its Non-Spin Resource Responsibility within 30 minutes of the Dispatch Instruction.

# Scenarios for SCED Re-Run with different “floors”


- **For “ON” Generation Resources (Online Non-Spin) release offers to SCED before Non-Spinning Reserve Deployment.**
- **Re-Run SCED with modified EOC for Generation Resources having Non-Spin Responsibility as per the following:**

	Low Floor	Medium-1 Floor	Medium-2 Floor	High Floor
<u>ONLINE Non-Spin</u>	18*FIP  July13=\$79.38 July 18=\$80.01	\$500	\$1000	\$3000
<u>ONLINE QSGR providing Non-Spin:</u>	18*FIP  July13=\$79.38 July 18=\$80.01	\$500	\$1000	\$3000
<u>OFFNS :offline Non-Spin Resources</u>	15*FIP+\$120  July13=\$186.15 July 18=\$186.675	\$500	\$1000	\$3000



# Results of SCED Re-Run for different "floor" scenarios


## July 13 : 13:00 – 20:00



GTBD = Generation to be dispatched  
 HASL = represents releasing online non spin offers early

# Results of SCED Re-Run for different "floor" scenarios

- July 18 : 13:00 – 20:00**



GTBD = Generation to be dispatched

HASL = represents releasing online non spin offers early

# System Lambda Before and After Non-Spin Deployment

Deployment Start Time	$\lambda$ at time of deployment	$\lambda$ 30 minutes after deployment	# of SCED Intervals greater than \$2999 during NS deployment
7/6 12:22	\$47.99	\$52.13	0
7/13 14:39	\$2,999.99	\$68.86	1
7/14 14:47	\$234.56	\$64.76	0
7/18 15:22	\$267.75	\$63.35	0
7/21 15:21	\$2,760.57	\$69.36	0
7/27 15:56	\$67.64	\$66.19	0
7/28 15:52	\$91.46	\$79.38	0
7/31 16:13	\$346.75	\$59.98	0
8/1 14:16	\$3,001.00	\$3,001.00	7
8/2 14:13	\$428.38	\$428.37	27
8/3 13:57	\$1,000.00	\$2,999.99	44
8/4 13:25	\$3,001.00	\$3,001.00	40
8/5 14:11	\$798.66	\$799.97	26
8/8 14:56	\$725.83	\$62.17	1
8/10 15:56	\$616.88	\$572.92	0

# RUC Process

# RUC Commitments

- **RUC Process recommends commitments or de-commitments of Generation Resources**
  - Ensure that there is enough Resource and Ancillary Service capacity
  - Committed in the right locations in order to maintain transmission security
- **Current Methodology subtracts net load forecast error (i.e. bias) from the load forecast and purchases the biased amount in additional non-spinning reserve**
- **Commitments are not made until necessary. Example: At 10 am RUC software suggests we need unit X for hour 16 and 17. Start up time is 1 hour. Operator does not commit at 10 am.**

# Review of Bias subtracted from Load forecast

<b>Month</b>	<b>Average Bias Subtracted from the MTLF (All Hours)</b>	<b>Average Bias Subtracted from the MTLF (HE 15-20)</b>
December 2010	46	144
January 2011	0	0
February 2011	0	0
March 2011	96	0
April 2011	415	746
May 2011	160	336
June 2011	147	291
July 2011	324	565
August 2011	537	1259

# Review of RUC Commitment Instructions May-July

<b>For Peak Hours (15-20)</b>	<b>May '11</b>	<b>June '11</b>	<b>July '11</b>
<b>Number of Days that Resources were RUCed for Capacity Issues</b>	12	11	15
<b>Number of Days that Resources were RUCed and NSRS was Deployed for Capacity Issues</b>	3	2	5
<b>Average Capacity Committed when both Resources were RUCed and NSRS was Deployed for Capacity Issues</b>	1093.94	436.67	290.67
<b>Average Capacity Committed for Capacity Issues During Days with Only RUCs</b>	455.85	390.43	109.92

# Summary

- **Reviewed three operating Days with Non-Spinning Reserve deployments in detail.**
- **Non-Spinning Reserve was provided from online, offline and quick-start resources all three days.**
- **Quick-Start generation was dispatched by SCED based on offers prior to Non-Spinning Reserve Deployments all three days.**
  - Because QSGRs were online non-spinning reserve deployments are significantly less than total obligation
- **Load increase exceeded Low Sustainable Limit (LSL) of offline non-spinning resources all three days.**
- **LMPs decreased after non-spinning reserve deployments all three days due to non-spinning reserve offers from online non-spin and offline non-spin all three days.**



# Summary continued

- **Reviewed Non-Spinning Reserve deployment procedure**
  - Discussed making additional offers available to SCED earlier. This will possibly reduce the number of deployments.
  - Releasing online Non-Spinning Reserve sooner may mitigate the magnitude of price reversals after deployment of non-spinning reserve.
- **Reviewed Ancillary Service Methodology for Non-Spinning Reserve**
  - Current Methodology subtracts net load forecast error (i.e. bias) from the load forecast and purchases the biased amount in additional non-spinning reserve.
  - RUC commitments are based on a reduced load forecast with the intention of leaning on Non-Spinning Reserve.