

ERCOT

METROPOLITAN BREAKFAST CLUB November 9, 2011

Trip Doggett
President & CEO
ERCOT

CONTENT

Overview of ERCOT

- History
- ERCOT as a North American Electric Reliability Corporation (NERC) interconnect
- ERCOT as an Independent System Operator
- "Old" World vs. "New" World

ERCOT Major Roles

- Grid Operations
- Capacity Planning
- Market Operations
- Growth of Wind Generation
- Future
 - Advanced Metering and Demand Response



HISTORY - ACT 1

- ERCOT stands for The Electric Reliability Council of Texas, Inc.
- 1941 Utilities Band Together to Aid War Effort
 - At the beginning of World War II, several electric utilities in Texas banded together as the Texas Interconnected System (TIS) to support the war effort. They sent their excess power generation to industrial manufacturing companies on the Gulf Coast to provide reliable supplies of electricity for energy-intensive aluminum smelting.
 - Recognizing the reliability advantages of remaining interconnected, the TIS members continued to use and develop the interconnected grid and established two monitoring centers, one in North Texas and one in South Texas.
- 1970 TIS Forms ERCOT to Comply with North American Electric Reliability Requirements
 - ERCOT was staffed by two retired employees from utilities.
- 1981 ERCOT Assumes Central Operating Coordinator Role
 - TIS members transferred all operating functions to ERCOT, and ERCOT became the central operating coordinator for Texas. ERCOT opened its first office in 1986 and hired four full-time employees.



HISTORY – ACT 2

1995 – Texas Legislature Votes to Deregulate Wholesale Generation

- The Texas Legislature amended the Public Utility Regulatory Act to deregulate the wholesale generation market. The Public Utility Commission of Texas (PUCT) began the process of expanding ERCOT's responsibilities to enable wholesale competition and facilitate efficient use of the power grid by all market participants.

• 1996 - ERCOT Becomes First ISO in US

 On August 21, 1996, ERCOT become the first Independent System Operator (ISO) in the US. Their job was to ensure an impartial, third-party organization was overseeing equitable access to the power grid among the competitive market participants.




HISTORY - ACT 3

- 1999 Legislature Votes to Deregulate Retail Electric Market
- 2001 Ten Control Centers Merged into One Control Center
 - On July 31, 2001, the existing 10 control areas in the ERCOT region were consolidated into a single control area.
- 2002 Retail Electric Market Opens, Enabling Customer Choice for 6.1 Million
- 2010 ERCOT implements Nodal Markets
- 2011 ERCOT has over 600 employees and an annual budget of over \$170M

NORTH AMERICAN INTERCONNECTED GRIDS

ERCOT 'directs traffic' on the grid to maintain reliability and ensure supply of electricity:


- 75% of Texas land
- 85% of Texas load
- More than 40,000 miles of transmission lines
- 550+ generation units
- Physical assets that are owned by transmission providers and generators
- 68,379 MW Summer peak demand (set August 3, 2011)
- 57,315 MW Winter peak demand (set February 10, 2011)



ERCOT AS INDEPENDENT SYSTEM OPERATOR


❖ ERCOT IS ONE OF 10 NORTH AMERICAN ISOS/RTOS

- ISOs/RTOs serve
 67% of U.S.
 population
- Goal: Reliability, Efficiency, Transparency & Impartiality




THE OLD WORLD: PRE-2002

Each utility was vertically integrated, from generation to customer service.



THE NEW WORLD: TEXAS COMPETITIVE MODEL




ERCOT ROLES: GRID OPERATIONS

ELECTRIC GRID OPERATIONS


- ERCOT 'directs traffic' on the grid to maintain reliability and ensure supply of electricity:
 - Coordinates scheduling of power by market participants
 - Analyzes grid conditions continuously in real-time
 - Dispatches generation to ensure power production matches load at all times
 - Balancing Energy Service
 - Load Frequency Control
 - Secures available generation capacity to meet reliability requirements including contingencies
 - Coordinates planned outages of generators and transmission lines
 - Relieves transmission system congestion
 - Coordinates emergency actions & recovery
 - Operates markets to meet regional energy & capacity requirements not met through bilateral arrangements



SUMMER PEAK DAY LOAD SHAPE WITH FUEL MIX



WINTER PEAK DAY LOAD SHAPE WITH FUEL MIX




ERCOT ROLES: CAPACITY PLANNING

RESERVE MARGINS: PROJECTING ADEQUACY OF SUPPLY

- Target reserve margin for the ERCOT Region is 13.75%
- Defined as:
 - Percentage difference between available generating capacity and forecasted peak system load
- Ensures (but does not guarantee) adequate electric supply will be available in case of contingency need
 - Unexpected weather extremes or loss of major generation units
- Available capacity includes:
 - Gas, coal and nuclear fuel units accounted at their season operating limit level (unless scheduled to retire or mothball)
 - Hydro plants and wind farms at their "high confidence summer peak" level
 - Planned units (with signed transmission interconnection agreements and required permits)
 - Loads Acting as Resources Large customers registered and bidding to provide capacity services in market-based load participation programs
 - DC Ties capacity that can be imported through DC links from neighboring grids




ERCOT RESERVE MARGINS – 2000-2020






Generation Interconnection Activity



ERCOT ROLES: MARKET OPERATIONS

NODAL MARKET OPERATIONS EFFECTIVE DECEMBER 1, 2010



NODAL MARKET BENEFITS

Improved price signals

 More granular pricing will encourage additional generation and/or transmission investment in the proper locations


Improved dispatch efficiencies

 Dispatching at the resource level will yield a lower overall cost of power supply and more efficient congestion management

More direct assignment of local congestion


Settlement prices are based on locational marginal costs

ERCOT BUSINESS PROCESS



ENERGY COST COMPARISON SUMMARY

- Resource specific offers and dispatch are more efficient in serving demand and managing congestion
- Co-Optimization of Ancillary Services and energy results in a reduction of overall system cost




^{*} Graph revised July 5, 2011




GROWTH OF WIND GENERATION

WIND GENERATION






COUNTY LOCATION OF PLANNED GENERATION WITH INTERCONNECTION REQUESTS (WIND) SEPTEMBER 2011






SCENARIO 2 TRANSMISSION PLAN (18GW)





DAILY WIND GRAPH AT PEAK





CHALLENGES RELATED TO INCREASED WIND RESOURCES IN ERCOT

Wind is not as controllable or predictable as traditional generation

- Highly dependent on weather conditions
- Cannot be dispatched (with exceptions)
- Voltage control and reactive coordination are difficult

Works best in conjunction with other generation in same area

- Conventional resources available to provide regulation & responsive reserve services
- Possible ancillary service impacts

Creates new challenges in system design & operation

- Difficultly in coordination of transmission outages and construction, i.e., system off peak = wind peak production
- Development of standard software stability models for operations
 & planning environment




FUTURE: ADVANCED METERING & DEMAND RESPONSE

ADVANCED METERING

- Part of "Smart Grid" efforts
- Remote meter reading
- Informed Consumers
- Time of Day pricing
- Demand Response Programs
 - Decrease Consumption
 - Increase Consumption

TODAY WE'RE SETTLING MORE THAN TWO MILLION ADVANCED METERS

Advanced Meter Deployment Plan



Advanced meters give customers the data they need to make educated decisions about their electricity usage.

DEMAND RESPONSE POTENTIAL IN ERCOT

- FERC estimates >18 GW of DR potential in Texas by 2019
 - Attributed to high peak demand
 - This would represent 20-25% of total ERCOT peak





Figure 16: Top Ten States by Achievable Potential in 2019 (GW)

Source: FERC 2009 National Assessment of DR, page 42




OFF-PEAK VS. ON-PEAK LOAD



Moderate day, low A/C load

10-11 AM, March 31, 2010


■ Business IDR Required ■ Business non-IDR Required ■ Residential



Hot day, high A/C load



■ Business IDR Required ■ Business non-IDR Required ■ Residential



- **Both days were Wednesdays**
- Customer class breakdown is for competitive choice areas only
- IDR meters are required at >700kW

QUESTIONS?