

PDCWG Report to ROS

David Kee
CPS Energy

June 6th meeting


- 16 members attended representing 10 companies, ERCOT, TRE.
- Discussion of challenges when calculating and communicating HSL for Combustion Turbines
 - Shared successes
 - Recommend weather telemetry to be provided from generation resources to QSE's to allow correction of HSLs using real data.
 - Proposal of additional telemetry points
 - **Duct burner status, available capacity, output power**

June 6th meeting


- Reviewed Primary Frequency Response data of Combined Cycle Steam Turbines
 - Preview of results (slides 4-20)
 - Received feedback
 - Will update data and methodology

Performance of ST of a CCY during Frequency Disturbance Events


Governor Response by Generation Type 05-07-2012@17:49




Governor Response by Generation Type 05-09-2012@10:07 AM



CCY Performance when RRS is carried by CTs



CCY Performance when most of the RRS is carried by ST and Power Augmentation



5/07/2012@17:49 PM – All ST


ALL ST RESPONSE

Spinning Reserve: 1885.5

MW @A:	8236.12
MW @B:	8250.3
MW @B+30:	8231.99

Expected Governor Response	
@B:	284.77
@B+30:	201.24

Actual Governor Response	
PU@B:	0.05
PU@B+30:	-0.02



5/07/2012@17:49 PM – All ST


ST Response RRS

RRS : 738.6

MW @A:	1751.01
MW @B:	1753.24
MW @B+30:	1753.04

Expected Governor Response	
@B:	64.96
@B+30:	45.91

Actual Governor Response	
PU@B:	0.03
PU@B+30:	0.04



4/4/2012@07:17 AM – All ST


ALL ST RESPONSE

Spinning Reserve: 2108.92

MW @A:	5542.97
MW @B:	5557.26
MW @B+30:	5547.44

Expected Governor Response	
@B:	463.23
@B+30:	429.05

Actual Governor Response	
PU@B:	0.03
PU@B+30:	0.01



4/03/2012@02:07 AM-All ST


ALL ST RESPONSE

Spinning Reserve: 2077.52

MW @A:	4210.44
MW @B:	4209.65
MW @B+30:	4215.33

Expected Governor Response	
@B:	483.47
@B+30:	468.83

Actual Governor Response	
PU@B:	0
PU@B+30:	0.01



4/03/2012@02:07 AM 488 MW RRS ST


ST Response RRS

RRS: 488

MW @A: 670.97
MW @B: 671.16
MW @B+30: 673.93

Expected Governor Response
@B: 70.24
@B+30: 68.11

Actual Governor Response
PU@B: 0
PU@B+30: 0.04



4/2/2012@17:54 PM – All ST


ALL ST RESPONSE

Spinning Reserve: 1323.67

MW @A:	5813.23
MW @B:	5830.02
MW @B+30:	5825.63

Expected Governor Response	
@B:	666.61
@B+30:	589.69

Actual Governor Response	
PU@B:	0.03
PU@B+30:	0.02



3/30/2012@14:56 PM 257 MW RRS ST


ST Response RRS

RRS : 257

MW @A:	341.44
MW @B:	341.87
MW @B+30:	345.79

Expected Governor Response	
@B:	39.75
@B+30:	34.9

Actual Governor Response	
PU@B:	0.01
PU@B+30:	0.12



3/30/2012@14:56 PM -All ST


ALL ST RESPONSE

Spinning Reserve: 1643.47

MW @A:	6101.65
MW @B:	6100.53
MW @B+30:	6102.95

Expected Governor Response	
@B:	629.98
@B+30:	553.07

Actual Governor Response	
PU@B:	0
PU@B+30:	0



3/22/2012 @03:36 AM – All ST


ALL ST RESPONSE

Spinning Reserve: 2276.89

MW @A:	2574.23
MW @B:	2577.18
MW @B+30:	2587.3

Expected Governor Response	
@B:	535.37
@B+30:	470.82

Actual Governor Response	
PU@B:	0.01
PU@B+30:	0.03



3/9/2012@16:52 PM – All ST


ALL ST RESPONSE

Spinning Reserve: 1670.89

MW @A:	5485.49
MW @B:	5493.81
MW @B+30:	5487.3

Expected Governor Response	
@B:	588.54
@B+30:	486.02

Actual Governor Response	
PU@B:	0.01
PU@B+30:	0



3/6/2012 @01:11 AM – All ST


ALL ST RESPONSE

Spinning Reserve: 2528.85

MW @A:	1927.86
MW @B:	1935.55
MW @B+30:	1933.83

Expected Governor Response	
@B:	542.97
@B+30:	527.78

Actual Governor Response	
PU@B:	0.01
PU@B+30:	0.01



Issue and Action

- RRS capacity provided by the ST (intentional or accidental) of a Combined Cycle generator does not provide the same level of response as other units providing RRS.
- Not advocating an NPRR or NOGRR at this time to limit RRS capacity on Combined cycles
 - Instead continue to grade the configuration against an achievable and realistic performance metric.
 - Compliance risk is on Generation Resource Owner and QSE to manage and perform to their respective RRS obligations based on current rules.
 - PDCWG will keep this an open issue and actively work to form solutions for ERCOT and ROS to endorse and implement
 - If desired by ROS or PDC, the PDC will form a task force, open to all market participants, to examine issue and recommend solutions
- ERCOT will continue compliance actions to address and follow up.
- Add ICCP telemetry to help determine expected response from online units?
- Add duct burner total capacity, status, and actual MW point over ICCP?
 - Will also benefit the PRC calculation

June 6th meeting


- Reviewed 3 frequency disturbance events
 - 1 event system response passed (good response carried through event)
 - 1 event system response was squelched (good initial response, did not sustain through event)
 - 1 event system response failed (low response)
- Review of PFR metrics
 - Working on NOGRR for revisions to PFR example calculations
- TRE technical workshop June 13th to review metrics
 - Expecting to identify additional NPRRs & NOGRRs

June 6th meeting

- Control metrics (following slides)
 - Frequency distribution deviation continues
 - Frequency distribution changes may warrant new metric
- Next meeting July 3rd meeting cancelled.


ERCOT CPS1 By Day - May-2012

ERCOT Monthly CPS1 = **158.66**



ERCOT CPS2 By Day - May-2012


ERCOT Monthly CPS2 = **94.47**




ERCOT CPS1 15 Minute Average - Monthly Score

May-2012

CPS 1 = 158.66




ERCOT CPS1




ERCOT CPS2 Score*


*ERCOT as a single control area is exempt from CPS2. These scores are For Information Only




Daily RMS1 of ERCOT Frequency




Daily RMS1 of ERCOT Frequency



Daily RMS1 of ERCOT Frequency




Comparing May 2010 vs May 2012 profile of frequency in 5 mHz bins




ERCOT Frequency Profile Comparison


January through December of each Year



ERCOT Total Energy



ERCOT Total Energy from Wind Generation



ERCOT %Energy from Wind Generation

