

**Seasonal Assessment of Resource Adequacy for the ERCOT Region  
Fall 2012**

Released September 4, 2012

**SUMMARY**

The ERCOT Region is expected to have sufficient installed generating capacity to serve forecasted peak demands with a historically typical amount of generation outages in the upcoming fall season. While it is always possible for unique conditions (such as much higher than expected peak demands or higher than normal forced generation outages) to occur that would require ERCOT to declare an Energy Emergency Alert (EEA), ERCOT does not anticipate calling for rotating outages.

Persistent drought conditions in ERCOT do not pose a threat to generation operations this fall.

Notifications of Suspension of Operations placing a combined 613 MW into mothball status have been received for four units: SR Bertron 3 and 4, Applied Energy G1, and Whitney Dam 1.

The Eagle Pass DC Tie of 36 MW has now been returned to service resulting in an 18 MW increase in the 50% of Non-Synchronous Ties, MW category

In addition, the 26 MW Sam Rayburn G3 unit has been removed from the Total Mothballed Resources section due to its retirement.

**Seasonal Assessment of Resource Adequacy for the ERCOT Region  
Fall 2012**

Release Date: September 4, 2012

**Forecasted Resources and Demand**

Installed Capacity, MW	65,879	Based on current Seasonal Maximum Sustainable Limits reported through Registration process		
Planned Units (not wind) with Signed IA and Air Permit, MW	-	Based on in-service dates provided by developers of generation resources		
Capacity from Private Networks, MW	4,390	Based on actual net PUN output during non-EEA periods		
Switchable Units, MW	3,138	Installed capacity of units that can switch to other Regions		
less Switchable Units Unavailable to ERCOT, MW	(317)	Based on survey response of Switchable Unit owners		
RMR Units to be under Contract, MW	-			
Effective Load-Carrying Capability (ELCC) of Wind Generation, MW	873	Based on 8.7% of installed capacity (Effective Load Carrying Capability) of wind per Planning Guide Section 8		
ELCC of Planned Wind Units with Signed IA, MW	-	Based on in-service dates provided by developers of generation resources		
50% of Non-Synchronous Ties, MW	553	Based on 50% of installed capacity of ties, per Planning Guide Section 8		
<b>a Total Resources, MW</b>	<b>74,516</b>			
<b>b Peak Demand, MW</b>	<b>53,227</b>	Updated 50% Probability forecast based on expected Fall 2012 weather from Climate Prediction Center		
<b>c Reserve Capacity (a - b), MW</b>	<b>21,289</b>			
<b>Range of Potential Risks</b>				
	<b>Base Case</b>	<b>Extreme Load/ Typical Gen Outages</b>	<b>Extreme Load/Extreme Gen Outages</b>	
Extreme Load Range		3,398	3,398	Based on load forecast using a September-like peak in early October
Typical Maintenance Outages	4,338	4,338	4,338	Based on five-year average of historic planned outages for hour ending 3P-6P of Oct - Nov weekdays
90th Percentile Maintenance Outages	-	-	-	
Typical Forced Outages	4,263	4,263	4,263	Based on five-year average of historic forced and maintenance-level outages for hour ending 3P-6P of Oct - Nov weekdays
90th Percentile Forced Outages	-	-	5,999	Based on five-year historic forced and maintenance-level outages for hour ending 3P-6P of Oct - Nov weekdays
<b>d Total Uses of Reserve Capacity</b>	<b>8,601</b>	<b>11,999</b>	<b>17,998</b>	
<b>e Capacity Available for Operating Reserves (c-d), MW</b>	<b>12,688</b>	<b>9,290</b>	<b>3,291</b>	Less than 2,300 MW indicates risk of EEA1
<b>f Demand Adjustment during Scarcity *</b>	<b>-</b>	<b>-</b>	<b>-</b>	
<b>g Adjusted Capacity Available for Operating Reserves (e+f)</b>	<b>12,688</b>	<b>9,290</b>	<b>3,291</b>	

\* represents effects of price-responsive demand, conservation appeals, demand programs, etc.; does not include Load Resource or Emergency Response Service activation

Seasonal Assessment of Resource Adequacy for the ERCOT Region  
 Fall 2012  
 Release Date: September 4, 2012

<b>Scenario Inputs</b>	Load Adjustment during EEA	-	Based on 50% of "model error" during peak for 2011; indicates response to appeal, price sensitive demand, etc.
	Extreme Load Adder	3,398	Based on load forecast using a September-like peak in early October
	Typical Maintenance Outages	4,338	Based on five-year average of historic planned outages for hour ending 3P-6P of Oct - Nov weekdays
	90th Percentile Maintenance Outages	5,224	Based on five-year historic planned outages for hour ending 3P-6P of Oct - Nov weekdays
	Typical Forced Outages	4,263	Based on five-year average of historic forced and maintenance-level outages for hour ending 3P-6P of Oct - Nov weekdays
	90th Percentile Forced Outages	5,999	Based on five-year historic forced and maintenance-level outages for hour ending 3P-6P of Oct - Nov weekdays
	<b>Total Uses of Reserves</b>		

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
AZ_AZ_G1	AIRPRO	NG	42 Existing	
AZ_AZ_G2	AIRPRO	NG	42 Existing	
AZ_AZ_G3	AIRPRO	NG	42 Existing	
AZ_AZ_G4	AIRPRO	NG	42 Existing	
AMISTAD_AMISTAG1	AMISTAD	WAT	37.9 Existing	
AMISTAD_AMISTAG2	AMISTAD	WAT	37.9 Existing	
APD_APD_PS1	APPLIED ENERGY	NA	1 Existing	
HB_DG1	ATASCOCITA	LFG	10 Nonmod	
ATKINS_ATKINSG7	ATKINS	NG	20 Existing	
DG_SPRIN_4UNITS	AUSTIN LANDFILL GAS	UNK	6.4 Nonmod	
AUSTPL_AUSTING1	AUSTIN PLANT	WAT	8 Existing	
AUSTPL_AUSTING2	AUSTIN PLANT	WAT	9 Existing	
B_DAVIS_B_DAVIG1	BARNEY DAVIS	NG	335 Existing	
B_DAVIS_B_DAVIG2	BARNEY DAVIS	NG	318 Existing	
B_DAVIS_B_DAVIG3	BARNEY DAVIS	NG	164 Existing	
B_DAVIS_B_DAVIG4	BARNEY DAVIS	NG	164 Existing	
BASTEN_GTG1100	BASTROP ENERGY CENTER	NG	157 Existing	
BASTEN_GTG2100	BASTROP ENERGY CENTER	NG	157 Existing	
BASTEN_ST0100	BASTROP ENERGY CENTER	WH	236 Existing	
TRN_DG1	BAYTOWN	MTH	3.87 Nonmod	
BBSES_UNIT1	BIG BROWN SES	LIG	606 Existing	
BBSES_UNIT2	BIG BROWN SES	LIG	602 Existing	
CARBN_BSP_1	BIG SPRING	WH	17.5 Existing	
DG_BIOE_2UNITS	BIO ENERGY PARTNERS	NG	6.2 Nonmod	
DG_BROOK_1UNIT	BLUE WING SOLAR 1	SUN	7.56 Nonmod	
DG_ELMEN_1UNIT	BLUE WING SOLAR 2	SUN	7.3 Nonmod	
LB_DG1	BLUEBONNET	LFG	3.87 Nonmod	
BOSQUESW_BSQSU_1	BOSQUE SWITCH	NG	175 Existing	
BOSQUESW_BSQSU_2	BOSQUE SWITCH	NG	175 Existing	
BOSQUESW_BSQSU_3	BOSQUE SWITCH	NG	175 Existing	
BOSQUESW_BSQSU_4	BOSQUE SWITCH	WH	83 Existing	
BOSQUESW_BSQSU_5	BOSQUE SWITCH	WH	220 Existing	
BVE_UNIT1	BRAZOS VALLEY ENERGY LP	NG	166 Existing	
BVE_UNIT2	BRAZOS VALLEY ENERGY LP	NG	166 Existing	
BVE_UNIT3	BRAZOS VALLEY ENERGY LP	NG	263 Existing	
BUCHAN_BUCHANG1	BUCHANAN	WAT	18 Existing	
BUCHAN_BUCHANG2	BUCHANAN	WAT	18 Existing	
BUCHAN_BUCHANG3	BUCHANAN	WAT	18 Existing	
FLCNS_UNIT1	CAL ENERGY	NG	75 Existing	
FLCNS_UNIT2	CAL ENERGY	NG	75 Existing	
FLCNS_UNIT3	CAL ENERGY	NG	70 Existing	
CALAVERS_OWS1	CALAVERAS	NG	420 Existing	
CALAVERS_OWS2	CALAVERAS	NG	420 Existing	
CALAVERS_JKS1	CALAVERAS	SUB	562 Existing	

Key to Abbreviations

BIO	Biomass
BIT	Bituminous Coal
LFG	Land-fill Gas
LIG	Lignite Coal
MTH	Methane
NG	Natural Gas
NUC	Nuclear
OG	Other Gas
OTH	Other
PC	Pulverized Coal
SUB	Sub-bituminous Coal
SUN	Sun (Solar Resource)
UNK	Unknown
WAT	Water (Hydro Resource)
WDS	Wood Biomass
WH	Waste Heat
WND	Wind

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
CALAVERS_JKS2	CALAVERAS	SUB	775 Existing	
CALAVERS_JTD1	CALAVERAS	SUB	430 Existing	
CALAVERS_JTD2	CALAVERAS	SUB	420 Existing	
CANYHY_CANYHYG1	CANYON	WAT	6 Nonmod	
CBY4_CT41	CEDAR BAYOU 4	NG	195 Existing	
CBY4_CT42	CEDAR BAYOU 4	NG	195 Existing	
CBY4_ST04	CEDAR BAYOU 4	NG	205 Existing	
CBY_CBY_G1	CEDAR BAYOU PLANT	NG	745 Existing	
CBY_CBY_G2	CEDAR BAYOU PLANT	NG	749 Existing	
CVC_CVC_G1	CHANNELVIEW COGEN	NG	168 Existing	
CVC_CVC_G2	CHANNELVIEW COGEN	NG	167 Existing	
CVC_CVC_G3	CHANNELVIEW COGEN	NG	169 Existing	
CVC_CVC_G5	CHANNELVIEW COGEN	NG	118 Existing	
AV_DG1	COASTAL PLAINS RDF	LFG	6.7 Nonmod	
COLETO_COLETOG1	COLETO CREEK	SUB	650 Existing	
CBEC_GT1	COLORADO BEND ENERGY CENTER	NG	84 Existing	
CBEC_GT2	COLORADO BEND ENERGY CENTER	NG	76 Existing	
CBEC_GT3	COLORADO BEND ENERGY CENTER	NG	75 Existing	
CBEC_GT4	COLORADO BEND ENERGY CENTER	NG	75 Existing	
CBEC_STG1	COLORADO BEND ENERGY CENTER	NG	103 Existing	
CBEC_STG2	COLORADO BEND ENERGY CENTER	NG	108 Existing	
CPSES_UNIT1	COMANCHE PEAK SES	NUC	1222 Existing	
CPSES_UNIT2	COMANCHE PEAK SES	NUC	1209 Existing	
DG_MEDIN_1UNIT	COVEL GARDENS LG POWER STATION	UNK	9.6 Nonmod	
DANSBY_DANSBYG1	DANSBY	NG	110 Existing	
DANSBY_DANSBYG2	DANSBY	NG	48 Existing	
DANSBY_DANSBYG3	DANSBY	NG	48 Existing	
DECKER_DPG1	DECKER POWER PLANT	NG	315 Existing	
DECKER_DPG2	DECKER POWER PLANT	NG	420 Existing	
DECKER_DPGT_1	DECKER POWER PLANT	NG	54 Existing	
DECKER_DPGT_2	DECKER POWER PLANT	NG	54 Existing	
DECKER_DPGT_3	DECKER POWER PLANT	NG	54 Existing	
DECKER_DPGT_4	DECKER POWER PLANT	NG	54 Existing	
DCSES_CT10	DECORDOVA SES CONSTELLATION	NG	74 Existing	
DCSES_CT20	DECORDOVA SES CONSTELLATION	NG	73 Existing	
DCSES_CT30	DECORDOVA SES CONSTELLATION	NG	72 Existing	
DCSES_CT40	DECORDOVA SES CONSTELLATION	NG	71 Existing	
DDPEC_GT1	DEER PARK ENERGY CENTER	NG	167 Existing	
DDPEC_GT2	DEER PARK ENERGY CENTER	NG	197 Existing	
DDPEC_GT3	DEER PARK ENERGY CENTER	NG	182 Existing	
DDPEC_GT4	DEER PARK ENERGY CENTER	NG	197 Existing	
DDPEC_ST1	DEER PARK ENERGY CENTER	WH	290 Existing	
DNDAM_DENISOG1	DENISON DAM	WAT	40 Existing	
DNDAM_DENISOG2	DENISON DAM	WAT	40 Existing	

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
DG_BIO2_4UNITS	DFW GAS RECOVERY	LFG	6.4	Nonmod
DUKE_DUKE_GT1	DUKE (NOW HIDALGO)	NG	145	Existing
DUKE_DUKE_GT2	DUKE (NOW HIDALGO)	NG	145	Existing
DUKE_DUKE_ST1	DUKE (NOW HIDALGO)	WH	171	Existing
DG_SCHUM_2UNITS	DUNLOP (SCHUMANSVILLE)	WAT	3.6	Nonmod
DG_SOME1_1UNIT	SOMERSET NORTH	SUN	5.61	Nonmod
DG_SOME2_1UNIT	SOMERSET SOUTH	SUN	4.95	Nonmod
EAGLE_HY_EAGLE_HY1	EAGLE PASS	WAT	9.6	Nonmod
FALCON_FALCONG1	FALCON PLANT	WAT	12.00	Existing
FALCON_FALCONG2	FALCON PLANT	WAT	12	Existing
FALCON_FALCONG3	FALCON PLANT	WAT	12	Existing
DG_HBR_2UNITS	FARMERS BRANCH LANDFILL	LFG	3.2	Nonmod
FPPYD1_FPP_G1	FAYETTE PLANT 1 & 2	SUB	603	Existing
FPPYD1_FPP_G2	FAYETTE PLANT 1 & 2	SUB	603	Existing
FPPYD2_FPP_G3	FAYETTE PLANT 3	SUB	446	Existing
FERGUS_FERGUSG1	FERGUSON	NG	424	Existing
FRNYPP_GT11	FORNEY	NG	178.19	Existing
FRNYPP_GT12	FORNEY	NG	178.19	Existing
FRNYPP_GT13	FORNEY	NG	178.19	Existing
FRNYPP_GT21	FORNEY	NG	178.19	Existing
FRNYPP_GT22	FORNEY	NG	178.19	Existing
FRNYPP_GT23	FORNEY	NG	178.19	Existing
FRNYPP_ST10	FORNEY	NG	405	Existing
FRNYPP_ST20	FORNEY	NG	405	Existing
FREC_GT1	Freestone Energy Center	NG	156	Existing
FREC_GT2	Freestone Energy Center	NG	156	Existing
FREC_GT4	Freestone Energy Center	NG	153	Existing
FREC_GT5	Freestone Energy Center	NG	153	Existing
FREC_ST3	Freestone Energy Center	WH	178	Existing
FREC_ST6	Freestone Energy Center	WH	174	Existing
FRONTERA_FRONTEG1	FRONTERA	NG	148	Existing
FRONTERA_FRONTEG2	FRONTERA	NG	148	Existing
FRONTERA_FRONTEG3	FRONTERA	WH	184	Existing
DG_RDLML_1UNIT	FW REGIONAL LFG GENERATION FACILITY	UNK	1.6	Nonmod
DG_LKWDT_2UNITS	GBRA	WAT	4.8	Nonmod
STEAM_ENGINE_1	GEUS	NG	8.439	Existing
STEAM_ENGINE_2	GEUS	NG	8.439	Existing
STEAM_ENGINE_3	GEUS	NG	8.439	Existing
STEAM_STEAM_2	GEUS	NG	26	Existing
STEAM_STEAM_3	GEUS	NG	41	Existing
STEAM1A_STEAM_1	GEUS	NG	20	Existing
GIBCRK_GIB_CRG1	GIBBONS CREEK	SUB	470	Existing
GRSES_UNIT1	GRAHAM SES	NG	225	Existing
GRSES_UNIT2	GRAHAM SES	NG	390	Existing

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
GBY_GBY_5	GREENS BAYOU	NG	406	Existing
GBY_GBYGT73	GREENS BAYOU	NG	54	Existing
GBY_GBYGT74	GREENS BAYOU	NG	54	Existing
GBY_GBYGT81	GREENS BAYOU	NG	54	Existing
GBY_GBYGT83	GREENS BAYOU	NG	64	Existing
GBY_GBYGT84	GREENS BAYOU	NG	58	Existing
GUADG_GAS1	GUADALUPE GEN	NG	169	Existing
GUADG_GAS2	GUADALUPE GEN	NG	169	Existing
GUADG_GAS3	GUADALUPE GEN	NG	167	Existing
GUADG_GAS4	GUADALUPE GEN	NG	170	Existing
GUADG_STM5	GUADALUPE GEN	NG	167	Existing
GUADG_STM6	GUADALUPE GEN	NG	171	Existing
HLSES_UNIT3	HANDLEY SES	NG	395	Existing
HLSES_UNIT4	HANDLEY SES	NG	435	Existing
HLSES_UNIT5	HANDLEY SES	NG	435	Existing
HAYSEN_HAYSENG1	HAYS ENERGY	NG	220	Existing
HAYSEN_HAYSENG2	HAYS ENERGY	NG	220	Existing
HAYSEN_HAYSENG3	HAYS ENERGY	NG	225	Existing
HAYSEN_HAYSENG4	HAYS ENERGY	NG	225	Existing
INKSDA_INKS_G1	INKS DAM	WAT	14	Existing
JACKCNTY_CT1	JACK COUNTY PLANT	NG	150	Existing
JACKCNTY_CT2	JACK COUNTY PLANT	NG	150	Existing
JCKCNTY2_CT3	JACK COUNTY PLANT	NG	150	Existing
JCKCNTY2_CT4	JACK COUNTY PLANT	NG	150	Existing
JACKCNTY_STG	JACK COUNTY PLANT	WH	285	Existing
JCKCNTY2_ST2	JACK COUNTY PLANT	WH	285	Existing
DG_KMASB_1UNIT	KMAYBTO	OG	0.125	Nonmod
LH2SES_UNIT2	LAKE HUBBARD 2 SES	NG	524	Existing
LHSES_UNIT1	LAKE HUBBARD SES	NG	392	Existing
LPCCS_CT11	LAMAR POWER PARTNERS	NG	166	Existing
LPCCS_CT12	LAMAR POWER PARTNERS	NG	166	Existing
LPCCS_CT21	LAMAR POWER PARTNERS	NG	166	Existing
LPCCS_CT22	LAMAR POWER PARTNERS	NG	166	Existing
LPCCS_UNIT1	LAMAR POWER PARTNERS	NG	204.3	Existing
LPCCS_UNIT2	LAMAR POWER PARTNERS	NG	204.3	Existing
LARDVFTN_G4	LAREDO ENERGY CENTER	NG	94.2	Existing
LARDVFTN_G5	LAREDO ENERGY CENTER	NG	94.2	Existing
LEON_CRK_LCPCT1	LEON CREEK	NG	48	Existing
LEON_CRK_LCPCT2	LEON CREEK	NG	48	Existing
LEON_CRK_LCPCT3	LEON CREEK	NG	48	Existing
LEON_CRK_LCPCT4	LEON CREEK	NG	48	Existing
DG_LWSVL_1UNIT	LEWISVILLE	WAT	2.8	Nonmod
LEG_LEG_G1	LIMESTONE PLANT	LIG	831	Existing
LEG_LEG_G2	LIMESTONE PLANT	LIG	858	Existing

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
LOSTPI_LOSTPGT1	LOST PINES	NG	178	Existing
LOSTPI_LOSTPGT2	LOST PINES	NG	172	Existing
LOSTPI_LOSTPST1	LOST PINES	NG	188	Existing
LFBIO_UNIT1	LUFKIN BIOMASS	WDS	53	Existing
MARBFA_MARBFAG1	MARBLE FALLS	WAT	21	Existing
MARBFA_MARBFAG2	MARBLE FALLS	WAT	21	Existing
MARSFO_MARSFOG1	MARSHALL FORD	WAT	36	Existing
MARSFO_MARSFOG2	MARSHALL FORD	WAT	36	Existing
MARSFO_MARSFOG3	MARSHALL FORD	WAT	29	Existing
MLSES_UNIT1	MARTIN LAKE SES	LIG	815	Existing
MLSES_UNIT2	MARTIN LAKE SES	LIG	820	Existing
MLSES_UNIT3	MARTIN LAKE SES	LIG	820	Existing
DG_MKNSW_2UNITS	MCKINNEY LANDFILL	LFG	3.2	Nonmod
DG_MCQUE_5UNITS	MCQUEENEY (ABBOTT)	WAT	7.68	Nonmod
DG_FREIH_2UNITS	MESQUITE CREEK LANDFILL	LFG	3.2	Nonmod
MDANP_CT1	MIDLOTHIAN ANP	NG	220	Existing
MDANP_CT2	MIDLOTHIAN ANP	NG	220	Existing
MDANP_CT3	MIDLOTHIAN ANP	NG	220	Existing
MDANP_CT4	MIDLOTHIAN ANP	NG	220	Existing
MDANP_CT5	MIDLOTHIAN ANP	NG	225	Existing
MDANP_CT6	MIDLOTHIAN ANP	NG	225	Existing
MIL_MILLERG1	MILLER	NG	75	Existing
MIL_MILLERG2	MILLER	NG	120	Existing
MIL_MILLERG3	MILLER	NG	208	Existing
MIL_MILLERG4	MILLER	NG	104	Existing
MIL_MILLERG5	MILLER	NG	104	Existing
MNSES_UNIT1	MONTICELLO SES	SUB	572	Existing
MNSES_UNIT2	MONTICELLO SES	SUB	572	Existing
MNSES_UNIT3	MONTICELLO SES	SUB	775	Existing
MGSES_CT1	MORGAN CREEK SES	NG	77	Existing
MGSES_CT2	MORGAN CREEK SES	NG	77	Existing
MGSES_CT3	MORGAN CREEK SES	NG	77	Existing
MGSES_CT4	MORGAN CREEK SES	NG	77	Existing
MGSES_CT5	MORGAN CREEK SES	NG	77	Existing
MGSES_CT6	MORGAN CREEK SES	NG	77	Existing
MCSES_UNIT6	MOUNTAIN CREEK SES	NG	121	Existing
MCSES_UNIT7	MOUNTAIN CREEK SES	NG	117	Existing
MCSES_UNIT8	MOUNTAIN CREEK SES	NG	567	Existing
NEDIN_NEDIN_G1	N EDINBURG	NG	213	Existing
NEDIN_NEDIN_G2	N EDINBURG	NG	213	Existing
NEDIN_NEDIN_G3	N EDINBURG	WH	253	Existing
NACPW_UNIT1	NACOGDOCHES POWER	WDS	105	New
NUECES_B_NUECESG7	NUECES BAY	NG	317	Existing
NUECES_B_NUECESG8	NUECES BAY	NG	180	Existing



Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
NUECES_B_NUECESG9	NUECES BAY	NG	180 Existing	
OGSES_UNIT1A	OAK GROVE SES	LIG	840 Existing	
OGSES_UNIT2	OAK GROVE SES	LIG	825 Existing	
OECCS_CT11	ODESSA ECTOR CCS	NG	158 Existing	
OECCS_CT12	ODESSA ECTOR CCS	NG	152 Existing	
OECCS_CT21	ODESSA ECTOR CCS	NG	149 Existing	
OECCS_CT22	ODESSA ECTOR CCS	NG	165 Existing	
OECCS_UNIT1	ODESSA ECTOR CCS	NG	216 Existing	
OECCS_UNIT2	ODESSA ECTOR CCS	NG	216 Existing	
OKLA_OKLA_G1	OKLAUNION	BIT	650 Existing	
OLINGR_OLING_1	OLINGER	NG	78 Existing	
OLINGR_OLING_2	OLINGER	NG	107 Existing	
OLINGR_OLING_3	OLINGER	NG	146 Existing	
OLINGR_OLING_4	OLINGER	NG	75 Existing	
PSG_PSG_GT2	PASGEN	NG	168 Existing	
PSG_PSG_GT3	PASGEN	NG	168 Existing	
PSG_PSG_ST2	PASGEN	WH	168 Existing	
PEARSALL_PEAR_1	PEARSALL	NG	25 Existing	
PEARSALL_PEAR_2	PEARSALL	NG	25 Existing	
PEARSALL_PEAR_3	PEARSALL	NG	25 Existing	
PEARSAL2_AGR_A	PEARSALL POWER PLANT 2	NG	50.64 Existing	
PEARSAL2_AGR_B	PEARSALL POWER PLANT 2	NG	50.64 Existing	
PEARSAL2_AGR_C	PEARSALL POWER PLANT 2	NG	50.64 Existing	
PEARSAL2_AGR_D	PEARSALL POWER PLANT 2	NG	50.64 Existing	
PB2SES_CT1	PERMIAN BASIN SES RELIANT	NG	71 Existing	
PB2SES_CT2	PERMIAN BASIN SES RELIANT	NG	70 Existing	
PB2SES_CT3	PERMIAN BASIN SES RELIANT	NG	73 Existing	
PB2SES_CT4	PERMIAN BASIN SES RELIANT	NG	74 Existing	
PB2SES_CT5	PERMIAN BASIN SES RELIANT	NG	74 Existing	
QALSW_GT1	QUAIL SWITCH	NG	81 Existing	
QALSW_GT2	QUAIL SWITCH	NG	81 Existing	
QALSW_GT3	QUAIL SWITCH	NG	80 Existing	
QALSW_GT4	QUAIL SWITCH	NG	80 Existing	
QALSW_STG1	QUAIL SWITCH	NG	98 Existing	
QALSW_STG2	QUAIL SWITCH	NG	98 Existing	
RIONOG_CT1	RIO NOGALES POWER PROJECT	NG	162 Existing	
RIONOG_CT2	RIO NOGALES POWER PROJECT	NG	162 Existing	
RIONOG_CT3	RIO NOGALES POWER PROJECT	NG	162 Existing	
RIONOG_ST1	RIO NOGALES POWER PROJECT	WH	323 Existing	
RAYBURN_RAYBURG1	SAM RAYBURN SWITCHYD	NG	13.5 Existing	
RAYBURN_RAYBURG2	SAM RAYBURN SWITCHYD	NG	13.5 Existing	
RAYBURN_RAYBURG7	SAM RAYBURN SWITCHYD	NG	50 Existing	
RAYBURN_RAYBURG8	SAM RAYBURN SWITCHYD	NG	51 Existing	
RAYBURN_RAYBURG9	SAM RAYBURN SWITCHYD	NG	50 Existing	

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
RAYBURN_RAYBURG10	SAM RAYBURN SWITCHYD	WH	40 Existing	
SJS_SJS_G1	SAN JACINTO STEAM	NG	81 Existing	
SJS_SJS_G2	SAN JACINTO STEAM	NG	81 Existing	
SANMIGL_SANMIGG1	SAN MIGUEL GEN	LIG	391 Existing	
SANDHSYD_SH_5A	SANDHILL POWER STATION	NG	170 Existing	
SANDHSYD_SH_5C	SANDHILL POWER STATION	NG	155 Existing	
SANDHSYD_SH1	SANDHILL POWER STATION	NG	47 Existing	
SANDHSYD_SH2	SANDHILL POWER STATION	NG	47 Existing	
SANDHSYD_SH3	SANDHILL POWER STATION	NG	47 Existing	
SANDHSYD_SH4	SANDHILL POWER STATION	NG	47 Existing	
SANDHSYD_SH6	SANDHILL POWER STATION	NG	47 Existing	
SANDHSYD_SH7	SANDHILL POWER STATION	NG	47 Existing	
SD5SES_UNITS	SANDOW 5 SES	LIG	570 Existing	
SILASRAY_SILAS_10	SILAS RAY	NG	48 Existing	
SILASRAY_SILAS_9	SILAS RAY	NG	38 Existing	
SILASRAY_SILAS_6	SILAS RAY	WH	21 Existing	
GIDEON_GIDEONG1	SIM GIDEON	NG	136 Existing	
GIDEON_GIDEONG2	SIM GIDEON	NG	133 Existing	
GIDEON_GIDEONG3	SIM GIDEON	NG	336 Existing	
DG_FERIS_4UNITS	SKYLINE LANDFILL GAS	UNK	6.4 Nonmod	
STP_STP_G1	SOUTH TEXAS PROJECT	NUC	1375 Existing	
STP_STP_G2	SOUTH TEXAS PROJECT	NUC	1375 Existing	
SPNCER_SPNCE_4	SPENCER	NG	61 Existing	
SPNCER_SPNCE_5	SPENCER	NG	61 Existing	
SRB_SRB_G1	SR BERTRON	NG	118 Existing	
SRB_SRB_G2	SR BERTRON	NG	174 Existing	
SRB_SRBGT_2	SR BERTRON	NG	13 Existing	
SCSES_UNIT1A	STRYKER CREEK SES	NG	167 Existing	
SCSES_UNIT2	STRYKER CREEK SES	NG	502 Existing	
DG_VALL1_1UNIT	SUNEDISON RABEL ROAD	SUN	9.9 Existing	
DG_VALL2_1UNIT	SUNEDISON VALLEY ROAD	SUN	9.9 Existing	
TEN_CT1	TENASKA (BRAZOS)	NG	163 Existing	
TEN_STG	TENASKA (BRAZOS)	WH	106 Existing	
TNSKA_GT1	TENASKA (TXU)	NG	86 Existing	
TNSKA_GT2	TENASKA (TXU)	NG	86 Existing	
TNSKA_STG	TENASKA (TXU)	WH	87 Existing	
DG_WALZE_4UNITS	TESSMAN ROAD	MTE	9.78 Nonmod	
TXCTY_CTA	TEXAS CITY GEN	NG	102 Existing	
TXCTY_CTB	TEXAS CITY GEN	NG	97 Existing	
TXCTY_CTC	TEXAS CITY GEN	NG	97 Existing	
TXCTY_ST	TEXAS CITY GEN	WH	125 Existing	
TGF_TGFGT_1	TEXAS GULF SULPHUR	NG	74 Existing	
THW_THWGT_1	TH WHARTON	NG	13 Existing	
THW_THWGT31	TH WHARTON	NG	57 Existing	

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
THW_THWGT32	TH WHARTON	NG	57	Existing
THW_THWGT33	TH WHARTON	NG	57	Existing
THW_THWGT34	TH WHARTON	NG	57	Existing
THW_THWGT41	TH WHARTON	NG	57	Existing
THW_THWGT42	TH WHARTON	NG	57	Existing
THW_THWGT43	TH WHARTON	NG	57	Existing
THW_THWGT44	TH WHARTON	NG	57	Existing
THW_THWGT51	TH WHARTON	NG	57	Existing
THW_THWGT52	TH WHARTON	NG	57	Existing
THW_THWGT53	TH WHARTON	NG	57	Existing
THW_THWGT54	TH WHARTON	NG	57	Existing
THW_THWGT55	TH WHARTON	NG	57	Existing
THW_THWGT56	TH WHARTON	NG	57	Existing
THW_THWST_3	TH WHARTON	NG	104	Existing
THW_THWST_4	TH WHARTON	NG	104	Existing
TNP_ONE_TNP_O_1	TNP ONE PLANT	LIG	158	Existing
TNP_ONE_TNP_O_2	TNP ONE PLANT	LIG	158	Existing
ETCCS_CT1	TRACTEBEL	NG	231	Existing
ETCCS_UNIT1	TRACTEBEL	NG	127	Existing
TRSES_UNIT6	TRINIDAD SES	NG	226	Existing
DG_KLBRG_1UNIT	TRINITY OAKS LFG	LFG	3.2	Nonmod
BRAUNIG_AVR1_CT1	VH BRAUNIG	NG	155	Existing
BRAUNIG_AVR1_CT2	VH BRAUNIG	NG	155	Existing
BRAUNIG_VHB1	VH BRAUNIG	NG	220	Existing
BRAUNIG_VHB2	VH BRAUNIG	NG	230	Existing
BRAUNIG_VHB3	VH BRAUNIG	NG	412	Existing
BRAUNIG_VHB6CT5	VH BRAUNIG	NG	48	Existing
BRAUNIG_VHB6CT6	VH BRAUNIG	NG	48	Existing
BRAUNIG_VHB6CT7	VH BRAUNIG	NG	48	Existing
BRAUNIG_VHB6CT8	VH BRAUNIG	NG	48	Existing
BRAUNIG_AVR1_ST	VH BRAUNIG	WH	180	Existing
VICTORIA_VICTORG6	VICTORIA	NG	160	Existing
VICTORIA_VICTORG5	VICTORIA	WH	125	Existing
WAP_WAP_G5	WA PARISH	BIT	659	Existing
WAP_WAP_G6	WA PARISH	BIT	658	Existing
WAP_WAP_G7	WA PARISH	BIT	577	Existing
WAP_WAP_G8	WA PARISH	BIT	610	Existing
WAP_WAP_G1	WA PARISH	NG	169	Existing
WAP_WAP_G2	WA PARISH	NG	169	Existing
WAP_WAP_G3	WA PARISH	NG	258	Existing
WAP_WAP_G4	WA PARISH	NG	552	Existing
WAP_WAPGT_1	WA PARISH	NG	13	Existing
WEBBER_S_WSP1	WEBBERVILLE	SUN	28.5	Existing
DG_WSTHL_3UNITS	WESTSIDE	LFG	4.8	Nonmod

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
WND_WHITNEY2	WHITNEY DAM	WAT	15	Existing
WFCOGEN_UNIT1	WICHITA FALLS COGEN SWITCH	NG	20	Existing
WFCOGEN_UNIT2	WICHITA FALLS COGEN SWITCH	NG	20	Existing
WFCOGEN_UNIT3	WICHITA FALLS COGEN SWITCH	NG	20	Existing
WFCOGEN_UNIT4	WICHITA FALLS COGEN SWITCH	WH	17	Existing
WIPOPA_WPP_G1	WINCHESTER POWER PARK	NG	44.75	Existing
WIPOPA_WPP_G2	WINCHESTER POWER PARK	NG	44.75	Existing
WIPOPA_WPP_G3	WINCHESTER POWER PARK	NG	44.75	Existing
WIPOPA_WPP_G4	WINCHESTER POWER PARK	NG	44.75	Existing
WIRTZ_WIRTZ_G1	WIRTZ	WAT	30	Existing
WIRTZ_WIRTZ_G2	WIRTZ	WAT	30	Existing
WCPP_CT1	WISE COUNTY POWER PLANT	NG	260	Existing
WCPP_CT2	WISE COUNTY POWER PLANT	NG	260	Existing
WCPP_ST1	WISE COUNTY POWER PLANT	NG	290	Existing
WHCCS_CT1	WOLF HOLLOW GEN	NG	227	Existing
WHCCS_CT2	WOLF HOLLOW GEN	NG	227	Existing
WHCCS_STG	WOLF HOLLOW GEN	WH	286	Existing
	<b>Total Existing Resources</b>		<b>65,879</b>	
PUN AGGREGATE	PUN OUTPUT TO GRID	OTH	4390	PUN
	<b>Total Private Use Networks</b>		<b>4,390</b>	
FTR_FTR_G1	FRONTIER	NG	170	Switchable
FTR_FTR_G2	FRONTIER	NG	170	Switchable
FTR_FTR_G3	FRONTIER	NG	170	Switchable
KMCHI_1CT101	KIAMICHI ENERGY FACILITY	NG	178	Switchable
KMCHI_1CT201	KIAMICHI ENERGY FACILITY	NG	180	Switchable
KMCHI_2CT101	KIAMICHI ENERGY FACILITY	NG	178	Switchable
KMCHI_2CT201	KIAMICHI ENERGY FACILITY	NG	180	Switchable
TGCCS_CT1	TENASKA GATEWAY	NG	162	Switchable
TGCCS_CT2	TENASKA GATEWAY	NG	179	Switchable
TGCCS_CT3	TENASKA GATEWAY	NG	178	Switchable
FTR_FTR_G4	FRONTIER	WH	390	Switchable
KMCHI_1ST	KIAMICHI ENERGY FACILITY	WH	307	Switchable
KMCHI_2ST	KIAMICHI ENERGY FACILITY	WH	307	Switchable
TGCCS_UNIT4	TENASKA GATEWAY	WH	389	Switchable
	<b>Total Switchable Resources</b>		<b>3,138</b>	
BRAZ_WND_WND1	GREEN MOUNTAIN ENERGY WIND FARM AT BRAZOS	WND	99	Wind
BRAZ_WND_WND2	GREEN MOUNTAIN ENERGY WIND FARM AT BRAZOS	WND	61	Wind
BRTSW_BCW1	BARTON CHAPEL WIND FARM	WND	120	Wind
BUFF_GAP_UNIT1	BUFFALO GAP WIND FARM	WND	121	Wind
BUFF_GAP_UNIT2_1	BUFFALO GAP WIND FARM	WND	116	Wind
BUFF_GAP_UNIT2_2	BUFFALO GAP WIND FARM	WND	117	Wind
BUFF_GAP_UNIT3	BUFFALO GAP WIND FARM	WND	170	Wind
BULLCRK_WND1	BULL CREEK WIND	WND	88	Wind
BULLCRK_WND2	BULL CREEK WIND	WND	90	Wind

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
CAPRIDG4_CR4	CAPRICORN RIDGE 4	WND	113 Wind	
CAPRIDGE_CR1	CAPRICORN RIDGE	WND	215 Wind	
CAPRIDGE_CR2	CAPRICORN RIDGE	WND	150 Wind	
CAPRIDGE_CR3	CAPRICORN RIDGE	WND	186 Wind	
CEDROHIL_CHW1	CEDRO HILL	WND	150 Wind	
CHAMPION_UNIT1	CHAMPION WINDFARM	WND	127 Wind	
COTTON_PAP2	PAPALOTE CREEK 2	WND	200 Wind	
CSEC_CSECG1	CAMP SPRINGS ENERGY CENTER	WND	134 Wind	
CSEC_CSECG2	CAMP SPRINGS ENERGY CENTER	WND	124 Wind	
DG_NUECE_6UNITS	HARBOR WIND	WND	9 Wind	
DG_ROSC2_1UNIT	TSTC WEST TEXAS WIND	WND	2 Wind	
DG_TURL_UNIT1	WOLFE FLATS	WND	1 Wind	
ELB_ELBCREEK	ELBOW CREEK	WND	119 Wind	
ENAS_ENA1	ENA SNYDER WIND	WND	63 Wind	
FLTCK_SSI	SILVER STAR WIND	WND	60 Wind	
GOAT_GOATWIN2	GOAT WIND	WND	70 Wind	
GOAT_GOATWIND	GOAT WIND	WND	80 Wind	
HHGT_CALLAHAN	HORSE HOLLOW	WND	114 Wind	
HHGT_HHOLLOW1	HORSE HOLLOW	WND	213 Wind	
HHGT_HHOLLOW2	HORSE HOLLOW	WND	184 Wind	
HHGT_HHOLLOW3	HORSE HOLLOW	WND	224 Wind	
HHGT_HHOLLOW4	HORSE HOLLOW	WND	115 Wind	
HWF_HWFG1	HACKBERRY WIND FARM	WND	162 Wind	
INDL_INADALE1	INADALE	WND	197 Wind	
INDNENR_INDNENR	INDIAN MESA ENRON	WND	84 Wind	
INDNENR_INDNENR_2	INDIAN MESA ENRON	WND	77 Wind	
INDNNWP_INDNNWP	INDIAN MESA NWP	WND	83 Wind	
KEO_KEO_SM1	SHERBINO 1 WIND FARM	WND	150 Wind	
KEO_SHRBINO2	SHERBINO 2 WIND FARM	WND	150 Wind	
KING_NE_KINGNE	KING MOUNTAIN NE	WND	79 Wind	
KING_NW_KINGNW	KING MOUNTAIN NW	WND	79 Wind	
KING_SE_KINGSE	KING MOUNTAIN SE	WND	40 Wind	
KING_SW_KINGSW	KING MOUNTAIN SW	WND	79 Wind	
KUNITZ_WIND_LGE	KUNITZ	WND	40 Wind	
KUNITZ_WIND_NWP	KUNITZ	WND	30 Wind	
LGD_LANGFORD	LANGFORD	WND	155 Wind	
LNCRK_G83	MESQUITE WIND	WND	200 Wind	
LNCRK2_G871	POST OAK WIND	WND	100 Wind	
LNCRK2_G872	POST OAK WIND	WND	100 Wind	
LONEWOLF_G1	LORAIN WINDPARK PROJECT LLC	WND	50 Wind	
LONEWOLF_G2	LORAIN WINDPARK PROJECT LLC	WND	51 Wind	
LONEWOLF_G3	LORAIN WINDPARK PROJECT LLC	WND	26 Wind	
LONEWOLF_G4	LORAIN WINDPARK PROJECT LLC	WND	24 Wind	
MCDLD_FCW1	AIRTRICITY	WND	124 Wind	

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
MCDLD_SBW1	AIRTRICITY	WND	90	Wind
MWEC_G1	MCADOO WIND ENERGY	WND	150	Wind
NWF_NWF1	NOTREES WINDFARM	WND	153	Wind
OWF_OWF	OCOTILLO WINDFARM	WND	60	Wind
PAP1_PAP1	PAPALOTE CREEK I	WND	180	Wind
PC_NORTH_PANTHER1	PANTHER CREEK	WND	143	Wind
PC_SOUTH_PANTHER2	PANTHER CREEK 2	WND	116	Wind
PC_SOUTH_PANTHER3	PANTHER CREEK 2	WND	200	Wind
PENA_UNIT1	PENASCAL WIND POWER	WND	161	Wind
PENA_UNIT2	PENASCAL WIND POWER	WND	142	Wind
PENA3_UNIT3	PENASCAL WIND POWER	WND	101	Wind
PYR_PYRON1	PYRON	WND	249	Wind
RDCANYON_RDCNY1	RED CANYON	WND	84	Wind
SGMTN_SIGNALMT	SIGNAL MOUNTAIN	WND	34	Wind
STWF_T1	SOUTH TRENT WIND FARM	WND	101	Wind
SW_MESA_SW_MESA	SOUTHWEST MESA	WND	74	Wind
SWEC_G1	STANTON WIND ENERGY CENTER	WND	124	Wind
SWEETWN2_WND2	SWEETWATER WIND 2	WND	98	Wind
SWEETWN2_WND24	SWEETWATER WIND 2	WND	16	Wind
SWEETWN3_WND3A	SWEETWATER WIND 3	WND	29	Wind
SWEETWN3_WND3B	SWEETWATER WIND 3	WND	101	Wind
SWEETWN4_WND4A	SWEETWATER WIND 4	WND	118	Wind
SWEETWN4_WND4B	SWEETWATER WIND 4	WND	104	Wind
SWEETWN4_WND5	SWEETWATER WIND 4	WND	79	Wind
SWEETWND_WND1	SWEETWATER WIND 1	WND	37	Wind
TGW_T1	TEXAS GULF WIND	WND	142	Wind
TGW_T2	TEXAS GULF WIND	WND	142	Wind
TKWSW1_ROSCOE	ROSCOE WIND FARM	WND	209	Wind
TRENT_TRENT	TRENT MESA WIND FARM	WND	151	Wind
TRINITY_TH1_BUS1	TRINITY HILLS	WND	118	Wind
TRINITY_TH1_BUS2	TRINITY HILLS	WND	108	Wind
TTWEC_G1	TURKEY TRACK WIND ENERGY CENTER	WND	170	Wind
WEC_WECG1	WHIRLWIND ENERGY CENTER	WND	57	Wind
WHTTAIL_WR1	WOLF RIDGE	WND	113	Wind
WOODWRD1_WOODWRD1	WOODWARD 1	WND	83	Wind
WOODWRD2_WOODWRD2	WOODWARD 2	WND	77	Wind
REDFISH_MV1A	MAGIC VALLEY WIND	WND	103	New
REDFISH_MV1B	MAGIC VALLEY WIND	WND	103	New
	<b>Total Wind Resources</b>		<b>10,035</b>	
APD_APD_G1	APPLIED ENERGY	PC	138	Currently Unavailable (Mothballed)
ATKINS_ATKINSG3	ATKINS	NG	12	Currently Unavailable (Mothballed)
ATKINS_ATKINSG4	ATKINS	NG	22	Currently Unavailable (Mothballed)
ATKINS_ATKINSG5	ATKINS	NG	25	Currently Unavailable (Mothballed)
ATKINS_ATKINSG6	ATKINS	NG	50	Currently Unavailable (Mothballed)

Unit Code	Plant Name	Primary Energy Source	Fall Capacity (MW)	Status
GBY_GBYGT82	GREENS BAYOU	NG	58	Currently Unavailable (Mothballed)
LEON_CRK_LCP3G3	LEON CREEK	NG	60	Currently Unavailable (Mothballed)
LEON_CRK_LCP4G4	LEON CREEK	NG	95	Currently Unavailable (Mothballed)
NTX_NTX_1	NORTH TEXAS	NG	18	Currently Unavailable (Mothballed)
NTX_NTX_2	NORTH TEXAS	NG	18	Currently Unavailable (Mothballed)
NTX_NTX_3	NORTH TEXAS	NG	39	Currently Unavailable (Mothballed)
PBSES_UNIT6	PERMIAN BASIN SES	NG	520	Currently Unavailable (Mothballed)
SILASRAY_SILAS_5	SILAS RAY	NG	10	Currently Unavailable (Mothballed)
SRB_SRB_G3	SR BERTRON	NG	230	Currently Unavailable (Mothballed)
SRB_SRB_G4	SR BERTRON	NG	230	Currently Unavailable (Mothballed)
VLSES_UNIT1	VALLEY SES	NG	174	Currently Unavailable (Mothballed)
VLSES_UNIT2	VALLEY SES	NG	520	Currently Unavailable (Mothballed)
VLSES_UNIT3	VALLEY SES	NG	375	Currently Unavailable (Mothballed)
WND_WHITNEY1	WHITNEY DAM	WAT	15	Existing
	<b>Total Mothballed Resources</b>		<b>2,609</b>	

## Seasonal Assessment of Resource Adequacy for the ERCOT Region

### **Background**

The Seasonal Assessment of Resource Adequacy (SARA) report is a deterministic approach to considering the impact of potential variables that may impact the sufficiency of installed resources to meet the peak electrical demand on the ERCOT System during a particular season.

The standard approach to assessing resource adequacy for one or more years into the future is to account for projected load and resources on a normalized basis and to require sufficient reserves (resources in excess of peak demand, on this normalized basis) to cover the uncertainty in peak demand and resource availability to meet a one-in-ten-years loss-of-load event criteria on a probabilistic basis.

For seasonal assessments that look ahead less than a year, specific information may be available (such as seasonal climate forecasts or anticipated common-mode events such as drought) which can be used to consider the range of resource adequacy in a more deterministic manner.

The SARA report is intended to illustrate the range of resource adequacy outcomes that might occur. Several sensitivity analyses are developed by varying the values of certain parameters that affect resource adequacy. The variation in these parameters are based on historic values , adjusted by any known or expected change.