

The Withdrawal of Outage AEP00058811 AJO to Rio Hondo





Shane Thomas





Initial Acceptance


- Outage submitted September 6th into ERCOT Outage Coordination midterm process
 - The purpose was for the reconductoring of the line
 - Studied at a load of 54000MW
 - Adequate resources shown in study
 - Study shows N-1 stability
- If the outage isn't taken at this time, conditions will only get worse
- Approved October 6th
- The outage began November 17 at 07:01




Forced/Maintenance Outages

- 11/17 after the outage was implemented loss of significant resources in area impacted by the outage occur
 - Units return the next day
 - No issues arise
- 11/23 loss of significant resources in area impacted by the outage occur
 - Units return 11/27
 - No issues arise
- 12/3 loss of significant resources in area impacted by the outage occur
 - No initial threat to reliability but load forecast steadily increasing
 - Issues ensue the following day as temperatures rise to unseasonably hi levels ~90°F











Reliability Issues

- 12/4 at 12:03 ERCOT Real-Time takes measures to maintain reliability without the withdrawal of the Ajo – Rio Hondo line
- 12/4 at 12:27 ERCOT Real-Time takes further measures for reliability
- Load continues to rise it appears that a withdrawal is only solution
- 12/4 at 14:42 Transmission watch issued for the Valley area
- 12/4 at 14:50 ERCOT Real-Time instructs AEP to restore outage AEP00058811
 - AEP gives 12-18hr estimated restoration time
 - Would allow line to be in service before the next peak load
 - At this time the outage is still visible in the MIS
 - "Approved and Accepted Transmission Outages"
- 12/4 at 14:50 ERCOT Real-Time takes further measures for reliability
- 12/4 at 22:16 Transmission watch issued for the Valley area lifted

^{**}Real-Time Reliability measure details are available through ercot.com



Withdrawal

- 12/5 at 12:24 Outage AEP00058811 AJO to Rio Hondo status changed to withdrawn.
 - At this time the outage is no longer visible in the "Approved and Accepted Transmission Outages" report but it still visible in the MIS
 - Now in the "Withdrawal of Approved/Accepted Transmission Outages" report
- 12/5 at 18:49 the AJO to Rio Hondo line is reenergized
 - Line energized still in dollies
 - Actual restoration time 26hrs




New Outage

- 12/5 at 18:57 Outage AEP00071738 submitted for the continuation of the reconductoring of the AJO-Rio Hondo line
 - In addition to reconductoring, AEP is doing prep work to do the remaining line work hot
- Majority of critical generation restored
- 12/6 at 08:28 ERCOT approves outage
 - At this time the new outage is visible in the MIS
 - "Approved and Accepted Transmission Outages"
 - The original withdrawn outage is still visible in the "Withdrawal of Approved/Accepted Transmission Outages" report
- 12/7 at 05:34 Outage begins effectively continuing outage AEP00058811




Reports on MIS





Info on ERCOT.com





Questions?

