

DOCKET NO. 41462

2013 MAY -6 PM 3:00

PETITION OF ELECTRIC RELIABILITY	§	BEFORE THE
COUNCIL OF TEXAS, INC., FOR	§	
APPROVAL OF PROTOCOL REVISIONS	§	PUBLIC UTILITY COMMISSION
AFFECTING NONCOMPETITIVE	§	
CONSTRAINT DESIGNATIONS	§	OF TEXAS


PUBLIC UTILITY COMMISSION
FILING CLERK

**ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC.'S
ERRATUM TO PETITION FOR APPROVAL OF PROTOCOL REVISIONS
AFFECTING NONCOMPETITIVE CONSTRAINT DESIGNATIONS**

Electric Reliability Council of Texas, Inc. (ERCOT) files this Erratum to its Petition for Approval of Protocol Revisions Affecting Noncompetitive Constraint Designations, filed with the Public Utility Commission on May 3, 2013. The document included as Exhibit C to the Petition—entitled “Technical Values for Competitive Constraint Test”—was not the version approved by the ERCOT Technical Advisory Committee (TAC) on May 2, 2013, as the Petition represented. The correct, TAC-approved version of the Threshold Values document is attached to this pleading and should be substituted as Exhibit C to the Petition. The attached version differs from the filed version in one material respect: the value indicated for the variable “ECIT2” is 2300, not 2000.

Notice of this Erratum is being provided to all parties who received notice of the Petition.

Respectfully submitted,

By: 
 Chad V. Seely
 Assistant General Counsel
 (512) 225-7035 (Phone)
 (512) 225-7079 (Fax)
cseely@ercot.com


Nathan Bigbee
 Senior Corporate Counsel
 (512) 225-7093 (Phone)
 (512) 225-7079 (Fax)
nbigbee@ercot.com

ERCOT
7620 Metro Center Drive
Austin, Texas 78744

ATTORNEYS FOR ELECTRIC
RELIABILITY COUNCIL OF TEXAS, INC.

CERTIFICATE OF SERVICE

I certify that a copy of this document was served on all parties of record in this proceeding on May 6, 2013 in the following manner: by facsimile, email, or first-class U.S. mail.



Nathan Bigbee

EXHIBIT C

Threshold Values for Competitive Constraint Test
Effective Upon Implementation of NPRR520, Real-Time
Mitigation Rules and Creation of a Real-Time Constraint
Competitiveness

EXHIBIT C

Document Revisions

Date Approved	Version	Description	Author(s)	Approved By	Effective Date
5/2/2013	1.0	Other Binding Document created as requested by TAC in association with NPRR520, Real-Time Mitigation Rules and Creation of a Real-Time Constraint Competitiveness.	ERCOT	TAC	Upon Implementation of NPRR520

EXHIBIT C

1. Revision Process

Revisions to this document shall be made according to the approval process prescribed in paragraph (6) of Protocol Section 3.19.1, Constraint Competitiveness Test Definitions.

2. Threshold Values for Competitive Constraint Test

Protocol Section 3.19.1 requires ERCOT to develop thresholds to be used in determining the competitive designation of a constraint and the Resources for which mitigation will be applied in SCED Step 2. The definitions and thresholds are as follows:

Threshold	Definition	Value
SFP1	Minimum shift factor threshold for determining which Managed Capacity to include in the ECI calculation	2%
ECIT1	Maximum competitive threshold for ECI on the import side of a constraint for the Long-Term CCT process	2000
SFP2	Minimum shift factor threshold for a constraint to be eligible to be a Competitive Constraint as part of the Long-term CCT Process	2%
ECIT2	Maximum competitive threshold for ECI on the import side of a constraint for the SCED CCT process	2300
SFP3	Minimum shift factor threshold for a constraint to be eligible to be a Competitive Constraint as part of the SCED CCT Process	2%
DMEECP	Threshold for the ECI Effective Capacity for an Entity or its Affiliates to determine if their Managed Capacity is eligible to be mitigated as part of SCED Step 2	10%
SFP4	Minimum shift factor threshold below which a Resource will not have mitigation applied in SCED Step 2	2%