



---

# **Panhandle Renewable Energy Zone (PREZ) Study Preliminary Results**

*Shun-Hsien (Fred) Huang  
ERCOT System Planning*

ERCOT Regional Planning Group (RPG) Meeting  
12-17-2013


# Outlines

---

- CREZ Implementation in Panhandle
- PREZ Needs and Study Objective
- Preliminary Results and Key Findings
- Summary and Conclusion
- Future Work

# CREZ Implementation in Panhandle

- Original CREZ plan called for ~5.5 GW of capacity in Panhandle, but reactive support equipment initially installed for ~2.4 GW
- Panhandle transmission remote from ERCOT load and synchronous generation
- Stability constrained
  - Most of the activity is at the edge of the Panhandle system which exacerbates the stability constraints



# Standard Generation Interconnection Agreements in Panhandle (12/12/2013)

GINR	ProjectName	County	IA Capacity (MW)	FC Capacity (MW)	IA Signed Date	Projected COD
13INR0048	Spinning Spur Wind Two	Oldham	161	161	2/27/2013	6/1/2014
14INR0012a	Miami Wind 1 Project	Gray	289	289	3/1/2013	7/31/2014
14INR0030a2	Panhandle Wind	Carson	218	218	12/19/2012	8/1/2014
11INR0050	Moore Wind 1	Crosby	149	0	7/12/2012	8/8/2014
14INR0030b	Panhandle Wind (Ph2)	Carson	198	0	10/2/2013	9/1/2014
13INR0059a	Hereford Wind	Castro	200	200	6/10/2013	9/4/2014
13INR0010a	Mariah Wind	Parmer	200	0	1/31/2013	10/30/2014
13INR0005	Conway Windfarm	Carson	600	600	10/24/2012	12/1/2014
14INR0023	Longhorn Energy Center	Briscoe	361	0	12/10/2012	12/1/2014
14INR0032a	Route66 Wind	Randall	150	0	10/31/2013	12/1/2014
13INR0059b	Hereford Wind	Castro	300	0	6/10/2013	4/15/2015
14INR0012b	Miami Wind 1 Project	Gray	112	0	3/1/2013	8/15/2015
13INR0010b	Mariah Wind	Parmer	200	0	1/31/2013	12/31/2015
13INR0010c	Mariah Wind	Parmer	200	0	1/31/2013	12/31/2016
12INR0029	Comanche Run Wind	Swisher	500	0	7/24/2013	12/31/2016
12INR0018	Pampa Wind Project	Gray	500	0	11/12/2013	3/31/2017
			4,338	1,468		

IA: Interconnection Agreement

FC: Financial Commitment

COD: Commercial Operating Day



# Needs of PREZ Study

---

- 2012 Long Term System Assessment
  - Significant expansion of wind resources in the Panhandle under a range of future outcomes.
  - If the northwestern-most portion of the Panhandle CREZ system becomes over-subscribed, voltage stability limits will constrain wind power delivery to the rest of the ERCOT system.
- Generation projects will exceed the CREZ design capacity for the Panhandle area (based on the CREZ Reactive Study “Initial Build” recommendations).
- No near-term Panhandle transmission projects being developed post CREZ 2013.



# Purpose of PREZ Study

---

- To identify system constraints and upgrades to accommodate future wind generation projects.
- To provide a project roadmap for both ERCOT and TSPs to accommodate additional generation resources in the study area.
  - List of potential system upgrade projects.
  - Triggers for when those projects will be recommended.



# Disclaimer

---

- PREZ study focuses on the upgrade needs to increase Panhandle export capability. Other ERCOT regions may require further studies for potential thermal and stability challenges.
- The identified upgrades may be revised based on the actual implementation of wind projects in Panhandle.
- The upgrades identified in this study are “NOT” approved projects. The identified projects may still require RPG review.



# Study Process

- Study Base Case
  - Reliability Analysis: 2016 HWLL DWG (8,946 MW wind output / 36.5 GW load, 24.5% wind penetration)
  - Economic Cost Analysis: 2017 UPLAN case from 2012 Five-Year Transmission Plan
- Study Tasks
  - Scenario 1:
    - Add 5,043 MW of Panhandle wind at 95% output
    - Wind penetration: ~35% (13.7GW wind output)
  - Scenario 2:
    - Add 7,845 MW of Panhandle wind at 95% output
    - Wind penetration: ~45% (16.4GW wind output)
  - Roadmap and triggering point for upgrades






# Study Progress


Mar-13	Present PREZ study scope in RPG
May-13	Complete Steady State Voltage Stability Analysis
	Complete Dynamic Flat Start Cases
Jun-13	Complete Scenario 1 (5GW Wind Gen in Panhandle)
	Identify High Voltage Ride Through (HVRT) Needs
Aug-13	Propose HVRT requirement (NOGRR 124)
	Complete Scenario 2 (7.5GW Wind Gen in Panhandle) and observe system constraint in other ERCOT region
Oct-13	Complete Roadmap Upgrade 1 (Panhandle export limit: 3.5 GW)
	Propose SCR criteria and identification for system strength enhancement
Nov-13	RPG synchronous condenser presentation (3 vendors and 1 utility)
	Complete Roadmap Upgrade 2 (Panhandle export limit: 5.2 GW)
Dec-13	Complete PREZ study
Jan-14	Complete PREZ report




# Scenario 1: System Upgrade Option



# Scenario 2: System Upgrade Option A





# Scenario 2: System Upgrade Option B




# Key Findings – Upgrade Needs

- Panhandle Upgrade Needs
  - Voltage Stability
  - System Strength (Short Circuit Ratio)
- Constraints in other region may limit the Panhandle export capability when Panhandle generation exceeds 6.5 GW. Other ERCOT regions may require further studies for potential thermal and stability challenges.




# Key Findings – Overvoltage Cascading

- High Voltage Ride Through Capability in the proposed NOGRR 124 is needed to accommodate more wind generation in Panhandle



Potential overvoltage cascading




Proposed HVRT: NOGRR 124



# System Strength Needs.



## Synchronous Condenser as an example



- Panhandle SCR target = 1.5
  - Actual synchronous condenser needs will vary based on transmission line upgrades and wind generation projects.
- 
- Is the need based on wind generation capacity or output?

# Key Findings – System Strength Enhancement


- The need of system strength enhancement in Panhandle is based on **wind generation output**.
- ERCOT and TSPs observed unstable responses from an existing WGR under a weak connection. A mitigation was developed to constraint the wind generation output to provide a stable operation of the WGR.





# Key Findings – System Strength Enhancement

- PREZ Sensitivity Test:
  - Base case: 3,500MW output from 3,700MW capacity, SCR ~1.5
  - Test case: 3,500MW output from 7,400MW capacity, same system condition in the base case
- PREZ study results confirm the system strength enhancement is based on wind generation output.




# Roadmap

- Upgrades identified in scenario 1 and 2 are the reference for roadmap.
- The upgrade stage in the roadmap is identified to provide most reliability Panhandle export increase at a least upgrade cost.
- Perform economic cost analysis to find the triggers of upgrades
  - in terms of wind project capacity in Panhandle
  - Protocol 3.11.2 (5)
    - ....., the levelized ERCOT-wide annual production cost savings over the period for which the simulation is feasible is calculated and compared to the first year annual revenue requirement of the transmission project.....




# Roadmap – Panhandle Export Limit



- Each upgrade also requires synchronous condensers and reactors
- Upgrade 1: add second circuit on the existing single circuit in Panhandle
- Upgrade 2: add new 345kV double circuits from Ogallala to Long Draw
- Upgrade 3: include one option from upgrade list below
- Upgrade 4: include one additional option from upgrade list below
- The final upgrade should include Gray-Riley option
- Upgrade list
  - Gray-Riley 345kV double circuits
  - Windmill—Edith Clarke 345kV double circuits
  - Windmill—Cottonwood—W.Shackelford 345kV double circuits

- Upgrades, project trigger points, and export limits may vary based on the assumed location of wind generation projects

# Roadmap – Consider Operation Practice



Upgrades

Element	Description	Circuit #	Upgrade	Length/Size	Note	Estimated Cost (\$M)	Total Cost (\$M)
345kV Line	Alibates-Windmill	1	1	93 miles	On the existing tower	63	115
345kV Line	Windmill-Ogallala	1	1	27 miles	On the existing tower		
345kV Line	Ogallala-Tule Canyon	1	1	47 miles	On the existing tower		
Synchronous Condenser	Windmill	--	1	200 MVA		43	
Reactor	Alibates	--	1	50 MVar		2.75	
Reactor	Ogallala	--	1	100 MVar		5.5	
345kV Line	Ogallala-Long Draw	2	2	190 miles	New line	380	560
Synchronous Condenser	Windmill	--	2	400 MVA		86	
Synchronous Condenser	Alibates	--	2	200 MVA		43	
Synchronous Condenser	Gray	--	2	150 MVA		32.25	
Reactor	Windmill	--	2	50 MVar		2.75	
Reactor	Ogallala	--	2	150 MVar		8.25	
Reactor	Long Draw	--	2	150 MVar		8.25	

- Upgrades, project trigger points, and export limits may vary based on the assumed location of wind generation projects



# Summary -- Roadmap

Panhandle Grid	Panhandle Export Limit	Trigger for Upgrade (Panhandle Wind Capacity)	Upgrade Element	Estimated Upgrade Cost (\$M)
Existing Grid	2,400 MW	-	-	-
Upgrade 1	3,500 MW	3,000 MW	<ul style="list-style-type: none"> <li>• Add second circuits on the existing Panhandle grid</li> <li>• 200MVA synchronous condenser</li> <li>• 150MVAR reactors</li> </ul>	115
Upgrade 2	5,200 MW	6,500MW	<ul style="list-style-type: none"> <li>• Add one new 345kV double circuits -- (Ogallala-Long Draw)</li> <li>• 750MVA synchronous condenser</li> <li>• 350MVAR reactors</li> </ul>	560
Upgrade 3	6,175 MW	-	<ul style="list-style-type: none"> <li>• Add one new 345kV double circuits -- (Gray-Riley or Windmill-Edith Clarke or Windmill-Cottonwood-W.Shackelford)</li> <li>• 350MVA synchronous condenser</li> <li>• 300MVAR reactors</li> </ul>	442
Upgrade 4	7,500 MW	-	<ul style="list-style-type: none"> <li>• Add one additional new 345kV double circuits -- (Gray-Riley or Windmill-Edith Clarke or Windmill-Cottonwood-W.Shackelford)</li> <li>• 350MVA synchronous condenser</li> <li>• 450MVAR reactors</li> </ul>	500



# Conclusion

- ERCOT initiated study in early 2013 to determine roadmap for transmission improvements necessary to accommodate Panhandle wind development beyond initial 2.4 GW capacity
  - Preliminary results show some near-term improvements may be able to be put in place to increase capacity relatively quickly but improvements for higher capacity may include longer lead time transmission lines
- Upgrades, project trigger points, and export limits may vary based on the assumed location of wind generation projects

# Future Work

---

- Continue to work with TSPs for other alternative upgrade options proposed by TSPs and/or stakeholders
- Monitor the generation interconnection status for actual implementation of wind projects in Panhandle
  - The identified upgrades may be revised based on the actual implementation of wind projects in Panhandle
  - The impact of the proposed DC-tie connect to Panhandle may require further investigation