



ERCOT STF MEETING

Bill Blevins

Manager, Operations Support

Synchrophasor Taskforce Meeting

Jan 08, 2014



Uses for PMUs within ERCOT

Examples of experience using PMU data

1. System Oscillation events

- SCADA cant detect or alarm for system oscillation events
- Addresses RC visibility for
 - Wide Area Oscillations
 - Inter-area Oscillations




2. Generator Model Validation

- NERC MOD-26 Excitation Model verification
- NERC MOD-27 Turbine/Governor Model verification
- Addresses requirements for:
 - Transmission Planner
 - Generator Owner


3. Post Event analysis/reporting

- PRC-002 Disturbance Monitoring and Reporting Requirements
- Applies to:
 - TO's
 - GO's
 - ERCOT


EXAMPLES OF ISSUES PMUs OSCILLATION EVENTS





EXAMPLES OF HOW PMUs CAN BE USED WITHIN ERCOT FOR MODEL VALIDATION




Challenge: Build a good dynamic model for a Generator/Excitation System that matches the actual equipment in the field and validate it through offline/online testing



WSCC August 10, 1996 disturbance



POST EVENT ANALYSIS SYSTEM FAULT



A fault should in general cause an impulse drop in voltage and a corresponding rise in current.


In the report, the Odessa (345 kV), Permian Basin (138 kV) and Morgan Creek (345 kV) all indicated a drop in voltage similar to expected response and also a sharp, temporary increase in current magnitude. Even the PMUs at CPSSW and GAVSW showed minor indications of the fault but the deviation at these locations was small.

The interesting responses were recorded at LNGSW and Gonzales.

At Gonzales, the current magnitude also saw a sharp drop along with the voltage. But looking at the power (MW) plot showed the reason. In general power was flowing into Gonzales from the rest of the system. So a major portion of the current flow would be redirected into the fault, thereby *reducing* the current flowing into Gonzales by a proportionate amount.

Even more interesting is the fact that *there was little to no fault current recorded at LNGSW*, even though it is located in between Morgan Creek and Odessa both of which showed fault current. The reason is that *the PMU at LNGSW directly measures the output of 3 wind farms*. Since wind farms produce little to no fault current, the PMU only recorded the sharp change in voltage (magnitude and angle) and no change in current or power flow (MW).

POST EVENT ANALYSIS FREQUENCY



- **Given that so many approaches exist and are based on sound research and testing, the question is how to decide which approach adds the most value to monitoring the electric grid while giving the other benefits the PMU can provide.**

- **Analyzed publications related to identifying locations for PMUs.**
 - “Generator Black Start Validation Using Synchronized Phasor Measurement” by **Kris Koellner**, Chris Anderson and Roy Moxley [1]
 - PMU Placement Considerations – A Roadmap for Optimal PMU Placement” by V. Madani
 - “Applications of Synchrophasor Measurement Units (PMUs) in ERCOT” by **Surya Santoso** and **W. Mack Grady**
 - “Optimal PMU Placement to Ensure System Observability under Contingencies” by Ranjana Sodhi, S. C. Srivastava, and S. N. Singh
 - “Optimal PMU Placement for Improving Hybrid State Estimator Accuracy” by Markos Asprou, and Elias Kyriakides
 - “Use of Synchronized Phasor Measurements for Dynamic Stability Monitoring and Model Validation in ERCOT” by **Jian Chen**, **Prakash Shrestha**, **Shun-Hsien Huang**, **N.D.R. Sarma**, **John Adams**, **Diran Obadina**, and John Balance

PMU LOCATION ALGORITHM TOOL

Weights based on a scale of importance from 1 to 4

Black Start Restoration.....	4
Contingencies (ranked by order: VSAT IROLs, TSAs, Generation (SPS), STPs)....	4
Observability.....	1
VSAT (voltage stability).....	3
Inter-area Oscillations.....	3
Major Generation (with lower short circuit capacity).....	3
Renewable Sources and CREZ lines.....	3
Major 345kV lines.....	2
Local Oscillations.....	4

				Applications												SCORE (Priority)
Bus	KV level	Station	Name	State Estimation	Key Tie Lines	Critical Paths	Regional Angular Separation	Local Angular Separation	Major Generation	Inter-area Oscillations	Local Oscillations	Islanding	System Restoration	Adaptive Protection	Local FACTS Controls	
ENTER Business Priority Weight for Column Category				2	2	2	1	1	2	2	2	2	1	1	2	
1	500.0	STATION 1	STN NAME 1													8.0
2	500.0	STATION 2	STN NAME 2													7.0
3	500.0	STATION 3	STN NAME 3													6.0
4	500.0	STATION 4	STN NAME 4													5.0
5	500.0	STATION 5	STN NAME 5													4.0
6	500.0	STATION 6	STN NAME 6													3.0
7	500.0	STATION 7	STN NAME 7													2.0
8	500.0	STATION 8	STN NAME 8													1.0
9	500.0	STATION 9	STN NAME 9													0.0
10	500.0	STATION 10	STN NAME 10													0.0

Priority (weighted score)

Applications


Weights

				Infrastructure												SCORE (Priority)
Bus	KV level	Station	Name	PMU Ready Device	COPT (Networked)	On Critical Cyber Asset (CCA) list	Automated PSC	Site ready for PSC	Site ready for PSC	CON LAN	CON WAN	Redundancy	Proposed	Aggregate Site		
ENTER Business Priority Weight for Column Category				1	2	1	1	1	2	2	1	1	1	1	1	
1	500.0	STATION 1	STN NAME 1													10.0
2	500.0	STATION 2	STN NAME 2													10.0
3	500.0	STATION 3	STN NAME 3													10.0
4	500.0	STATION 4	STN NAME 4													10.0
5	500.0	STATION 5	STN NAME 5													10.0
6	500.0	STATION 6	STN NAME 6													10.0
7	500.0	STATION 7	STN NAME 7													10.0
8	500.0	STATION 8	STN NAME 8													10.0
9	500.0	STATION 9	STN NAME 9													10.0
10	500.0	STATION 10	STN NAME 10													10.0

Infrastructure

Weights

Comprehensive PMU Placement List																	
Rank	Bus Number	Planning Bus Name	EMMS Station Name	1.5 PMUs Voltage (KV)	AreaName	Black Start	Generation	Load	N-1.1	N-1 Secure	Voltage Stability	CREZ	Renewables	Connectivity	Sensitive Buses	Score Subtotal	Score Adj
1	59951	BORLYNN_345K	NO MATCH	345	WETT								0.25	0.3764589	0.62566	34.08	34.70521
2	59950	STEPHENS-BOR	NO MATCH	345	WETT								0.1875	0.3793088	0.66881	26.16	26.730891
3	41450	SHELL_138A	SL	138	CNP TSP			0.916					0.3125	0.4639619	1.69197	20.2	21.887732
4	44010	W.A.P. 138A	WAP	138	CNP TSP								0.1875	0.6514477	0.88995	18.45	19.247483
5	45555	T.H.W. 138E	THW	138	CNP TSP								0.1875	0.5012248	0.68872	17.13	17.814263
6	1032	MIRGONCK 8	MGS85	138	ONCOR ED								0.6875	0.3813305	1.06883	12.95	14.018567
7	41300	PSARCO_138A	PSA	138	CNP TSP			0.743					0.25	0.5007584	1.49379	11.62	13.110456
8	110279	AMOCODIL 6.8	AMOCODIL	138	TNMP TSP			2.934					0.1875	0.3851548	0.50425	0.548	13.05241
9	1891	DECRDOVA 8	DCSES	138	ONCOR ED						1.5		0.25	0.2090509	1.95906	9.726	11.684927
10	8395	FALCON 4	FALCON	138	STEC TSP								0.1875	1.5441506	1.73165	9.149	10.880459
11	110797	CREC 1.8	CREC	138	CNP TSP								0.125	0.212129	0.33715	10.48	10.816544
12	40715	GRNBYSY 138F	GBY	138	CNP TSP								0.25	0.5426538	0.79263	9.934	10.726167
13	9218	SANDHSDY	SANDHSDY	138	AEN TSP								0.3125	0.1099479	0.41843	10.03	10.470403
14	160747	FG LOSV1 1.8	NO MATCH	138	APC TCC								0.125	1.5699081	1.69491	8.742	10.436961
15	160750	FG LOSV1 2.8	LV1	138	APC TCC								0.125	1.5713074	1.69631	8.739	10.435502
16	3030	BRAUNING 8	BRAUNING	138	CPS TSP			0					0.3125	0.2589797	0.37148	8.391	9.963278
17	3100	MARTINK 5	MLSE5	345	ONCOR ED								0.25	0.7388159	0.58882	8.498	9.480457
18	86111	FAM-138	NOT LISTED	138	CPE		1.0909091						0.4375	1.5920378	1.12045	5.364	9.484164
19	59800	PWRPLANT	SILASRAY	138	BPUB TSP								0.125	2.0666603	2.19166	7.06	9.2517041
20	131247	QALSW 1.5	QALSW	345	ONCOR ED								0.125	0.3790899	0.45409	8.792	9.2456188
21	86112	MTM-138	NOT LISTED	138	CPE		1.0909091						0.25	1.590794	2.9337	6.301	9.2329202
22	1800	COMCHPKW 5	CPSE5	345	ONCOR ED			0.021			1.5		0.25	0.1361314	1.90781	7.282	9.1993646
23	40480	DS BAT 138A	DIB	138	CNP TSP			2.043					0.375	0.4840466	2.88329	6.283	9.1656099
24	18100	PSGENUS 8	PS2ES5	138	TEMPORARY								0.125	0.5936617	0.71866	8.386	9.1046684
25	5260	LEON_CRK	LEON_CRK	138	CPS TSP								0.1875	0.2422033	0.44897	16.8	9.079597



Thank U !!