



Houston Import Project – ERCOT Independent Review

Technical Advisory Committee (TAC)
February 27, 2014


Jeff Billo, ERCOT Transmission Planning

Background

- In July and August 2013 CenterPoint Energy, City of Garland and Cross Texas Transmission, and Lone Star Transmission separately identified a reliability need to increase the import capability into the Houston area by 2018
 - Each Transmission Service Provider submitted a project proposal to the Regional Planning Group (RPG) for review and comment
- ERCOT conducted a single, combined Independent Review of the proposals

ERCOT Study Assumptions


- ERCOT Independent Review study assumptions are consistent with the 2013 and previous Regional Transmission Plans
 - Used the 2018 SE summer peak case
 - Generation assumptions per Planning Guide Section 6.9
 - Load in Coast, East, Southern, and South Central Weather Zones at peak, all other weather zones scaled down to balance load/ generation
 - ERCOT validated this assumption



NEED ASSESSMENT

Study Results

- Several planning criteria violations found
- Singleton-Zenith 345 kV lines are overloaded under N-1
- Multiple 345 kV lines (total length ~200 miles) and low voltages under G-1+N-1 conditions



Load Variations

- Since planning cases model non-coincident peaks for all areas throughout the system and it is not reasonable to expect that all areas will hit their coincident peaks at the same time, it is a reasonable variation of load to scale load down in areas outside of the study area
- During RPG discussions stakeholders commented that ERCOT's load scaling methodology may exacerbate the North-Houston line loading in the 2018 SE study case

Load Variations cont.

- To address stakeholder comments ERCOT analyzed three additional load variations to test the reliability need for a project using the ERCOT Steady-State Working Group (SSWG) cases
 - **Case 1:** 2018 SSWG case (2018 SUM1 Final 10/15/2013) with no changes to load or generation
 - **Case 2:** 2018 SSWG case with outside weather zone load scaled to the highest percentage load level between 2011 and 2013 when the Coast weather zone was at its peak
 - **Case 3:** 2018 SSWG case with outside weather zone load scaled to the percentage of load level when the Coast weather zone was at its peak in 2013

Load Variation Results

- The result of the G-1+N-1 analysis showed either overload or heavy flow on the existing 345 kV lines from the north into Houston
- The results confirm that the reliability need exists under several different reasonable variations of load

| Overload Element (under G-1+N-1) | Case 1 | Case 2 | Case 3* |
|----------------------------------|-----------|-----------|-----------|
| Singleton-Zenith double circuit | 122% | 128% | 137% |
| Roans Prairie-Bobville #75 | 99% | 104% | 110% |
| Bobville-Kuykendahl #75 | 99% | 103% | 110% |
| Jewett North-Singleton #1 | 93% | 99% | 106% |
| Jewett South-Singleton #1 | 91% | 97% | 103% |
| Gibbons Creek-Singleton #75 | 92% | 94% | 101% |
| Gibbons Creek-Singleton #99 | 92% | 94% | 101% |
| Jack Creek-Twin Oak #1 | 92% | 100% | 102% |
| Singleton-Tomball #74 | Below 90% | 93% | 99% |
| Gibbons Creek-Twin Oak #1 | Below 90% | 92% | 95% |
| Gibbons Creek-Jack Creek #2 | Below 90% | Below 90% | Below 90% |

* Also showed low voltage issue (below 90%) at Tomball 345 kV bus

Load/ Generation Sensitivity

- ERCOT performed an additional sensitivity to determine how much generation additions/ load reduction would be required to defer the identified reliability issues by one year
 - Sensitivity performed by scaling down load in Coast weather zone until the thermal violations resolved (to below 100%)
 - Result indicated that ~1800 MW reduction would be needed
 - Actual generation additions or load reduction may need to be greater depending on shift factors
 - Older generation retirement in the Houston area may offset new generation additions

Need Assessment Summary


- ERCOT found several planning criteria violations along the North to Houston 345 kV import pathway
- ERCOT confirmed the need using several reasonable variations to load
- ERCOT found that a net of approximately 1800 MW of generation addition/ load reduction would defer the need to 2019
 - 1800 MW represents ~ 6.8% of the total projected load (2018) in the Coastal weather zone

PROJECT ALTERNATIVES

Project Alternative Evaluation

- ERCOT evaluated 21 project alternatives to address the identified reliability need (including project proposals from the TSPs)
- 8 of the projects would resolve the reliability criteria violations:
 - Option 1: Twin Oak-Zenith 345 kV with 25% series compensation
 - Option 2: Twin Oak-Zenith 345 kV with 50% series compensation
 - Option 3: Limestone-Ragan Creek-Zenith 345 kV
 - Option 4: Limestone-Gibbons Creek-Zenith 345 kV
 - Option 5: Jewett-Jack Creek-Zenith 345 kV
 - Option 6: Jewett-Jack Creek-Zenith 345 kV with 25% series compensation
 - Option 7: Jewett-Jack Creek-Zenith 345 kV with 50% series compensation
 - Option 8: Navarro-Gibbons Creek-Zenith 345 kV

Map of 21 Alternatives



Project Alternative Evaluation

- ERCOT performed the following analysis to determine which option would best meet the long-term needs of the system:
 - Assessment of potential future system upgrades and time value of money analysis of those upgrades
 - Voltage stability margin analysis
 - System needs analysis if older generation in the Houston area were to retire
 - NERC Category C and D contingency analysis
 - Production cost savings analysis
 - System loss analysis

Overall Comparison of Options

| Description | Option 1 (TWZ-25comp-TA) | Option 2 (TWZ-50comp-TA) | Option 3 (LRZ-TA) | Option 4 (LGZ-TA) | Option 5 (JJZ-TA) | Option 6 (JJZ-25comp-TATJ) | Option 7 (JJZ-50comp-TATJ) | Option 8 (NGZ-TATJ) |
|--|-----------------------------|-----------------------------|---------------------------|---------------------------|----------------------|-------------------------------|-------------------------------|---------------------------|
| System Performance (2018) (All options addressed the reliability need) | Met criteria | Met criteria | Met criteria | Met criteria | Met criteria | Met criteria | Met criteria | Met criteria |
| Capital cost in 2018 dollar (\$ Million), (Based on \$3.78 million per mile for T-cost) | 554.8 | 572.0 | 610.2 | 590.1 | 596.3 | 617.1 | 629.1 | 805.9 |
| NPV of the set of future upgrades under each option in 2018 dollar (\$ Million) | 387.0 | 390.6 | 399.5 | 383.1 | 652.9 | 419.5 | 435.2 | 537.5 |
| Overall cost impact: Sum of the cost of each option and NPV of future upgrades in 2018 dollar (\$ Million) | 941.8 | 962.6 | 1009.7 | 973.3 | 1249.3 | 1036.6 | 1064.4 | 1343.4 |
| Voltage stability Analysis (Estimated 2028 load level in Coast zone = 27931 MW) | 28105 MW (beyond 2028) | 28095 MW (beyond 2028) | 28105 MW (beyond 2028) | 28025 MW (beyond 2028) | 27905 MW (2028) | 28075 MW (beyond 2028) | 28205 MW (beyond 2028) | 28125 MW (beyond 2028) |
| Performance with the old units offline (AC power flow under N-1) | 4 overloads | 2 overloads | 0 overload | 0 overload | 6 overloads | 2 overload | 0 overload | 3 overloads |
| Amount of generation reduction from the old units without causing overload under G-1+N-1 (MW) | 900.6 | 911.1 | 1061.3 | 1020.0 | 400.0 | 773.8 | 662.6 | 652.6 |
| NERC Category C and D | Good | Good | Good | Good | Good | Good | Good | Good |
| Economic Benefit (Relative annual production cost savings in \$ million, referenced to Option 8) | 4.3 | 3.4 | 3.2 | 1.7 | 2.1 | 2.2 | 1.7 | 0.0 |
| System Loss Reduction at Peak (MW) | 44.7 | 38.8 | 47.6 | 31.2 | 38.2 | 44.8 | 35 | 32.7 |
| New right of way | 117 mi | 117 mi | 130 mi | 129.9 mi | 128.9 mi | 128.9 mi | 128.9 mi | 177.9 mi |
| Sub-Synchronous Resonance (SSR) concern | Yes | Yes | No | No | No | Yes | Yes | No |

ERCOT Recommendation

- **ERCOT will seek Board of Director endorsement of the following project (Option # 4) as the best option to address both the near-term and long-term reliability needs and to serve the future load in the Houston area:**
 - Construction of a new Limestone-Gibbons Creek-Zenith 345 kV double circuit to achieve 2988 MVA of emergency rating for each circuit
 - Upgrade of the substations at Limestone, Gibbons Creek and Zenith to accommodate the terminations of new transmission lines
 - Upgrade of the existing T.H. Wharton-Addicks 345 kV line to achieve 1450 MVA of emergency rating (~10.7 miles)

QUESTIONS?

APPENDIX

Study Base Case

- Total Load in Coast Weather Zone in the 2018 SE case
 - ~ 26,355 MW (CNP load = ~ 22800 MW)
 - The load is identical to the SSWG case load in the Coastal weather zone
- Status of future generators in the study case
 - Online:
 - Deer Park Energy G6, Channel Energy GT3,
 - Deepwater Energy,
 - Offline:
 - New W.A. Parish unit, Pondera King, Cobisa

Case Load Scaling Validation

| Average % of peak load of each weather zone during the top ten hourly peak load conditions at the Coast Weather Zone | | | | | | | |
|--|------------|------------|---------------|------------|------------|------------|---------------|
| Year | East | South | South Central | Far West | West | North | North Central |
| 2011 | 97% | 98% | 96% | 94% | 84% | 68% | 93% |
| 2012 | 96% | 96% | 96% | 93% | 93% | 79% | 86% |
| 2013 | 77% | 99% | 97% | 96% | 78% | 91% | 89% |
| Average | 90% | 97% | 97% | 94% | 85% | 79% | 89% |
| Max | 97% | 99% | 97% | 96% | 93% | 91% | 93% |
| Min | 77% | 96% | 96% | 93% | 78% | 68% | 86% |

Options Evaluated for N-1

| ID | CenterPoint Options | Approximate Length (mi) |
|------|---|-------------------------|
| C1 | Twin Oak-Zenith 345 kV double circuit | 117.0 |
| C2 | Ragan Creek-Zenith double-circuit 345 kV double circuit | 69.0 |
| C3 | Limestone-Ragan Creek-Zenith 345 kV double circuit | 130.2 |
| ID | Lone Star Options | Approximate Length (mi) |
| L1 | Navarro-Gibbons Creek-Zenith 345 kV double circuit | 165.0 |
| L2 | Navarro-King 345 kV double circuit | 186.0 |
| L3 | Navarro-King 500 kV double circuit | 186.0 |
| L4 | Navarro-King 345 kV double circuit with 50% Series Compensation | 186.0 |
| ID | Cross Texas & Garland Power and Light Options | Approximate Length (mi) |
| T1 | Gibbons Creek-Tomball 345 kV double circuit | 50.0 |
| T2 | Gibbons Creek-Zenith 345 kV double circuit | 60.0 |
| T3 | Limestone-Gibbons Creek-Zenith 345 kV double circuit | 122.0 |
| ID | ERCOT and Other Options | Approximate Length (mi) |
| E1 | Jewett-King 345 kV double circuit | 142.5 |
| E2 | Lufkin-Jordan 345 kV double circuit | 126.0 |
| E3 | Fayette-Zenith 345 kV double circuit | 65.6 |
| E4 | Fayette-O'Brien 345 kV double circuit | 73.9 |
| E5 | Jewett-Jack Creek-O'Brien 345 kV double circuit plus loop Twin Oak-Gibbons Creek into Jack Creek | 154.6 |
| E6 | Jewett-Jack Creek-Zenith 345 kV double circuit plus loop Twin Oak-Gibbons Creek into Jack Creek | 134.1 |
| E7 | Sandow-Salem-Zenith 345 kV double circuit | 113.4 |
| E6-a | Jewett-Jack Creek-Zenith 345 kV double circuit with 50% or 25% Series Compensation plus Loop Twin Oak-Gibbons Creek into Jack Creek | 134.1 |
| C1-a | Twin Oak-Zenith 345 kV double circuit with 50% or 25% Series Compensation | 117.0 |

Result – N-1 Analysis

- Options that did not pass N-1 criteria:
 - **C2: Ragan Creek-Zenith 345 kV**
 - Overload of Twin Oak-Ragan Creek 345 kV, Jack Creek-Twin Oak 345 kV
 - Heavy flow* on Jewett-Singleton 345 kV
 - **T1: Gibbons Creek-Tomball 345 kV**
 - Overload of Jack Creek-Twin Oaks 345 kV
 - Heavy flow* on Jewett-Singleton 345 kV
 - **T2: Gibbons Creek-Zenith 345 kV**
 - Overload of Jack Creek-Twin Oaks 345 kV
 - Heavy flow* on Jewett-Singleton 345 kV
 - **E2: Lufkin-Jordan 345 kV**
 - Overload of ~50 miles of 138 kV lines in the Lufkin area
 - **E3: Fayette-Zenith 345 kV**
 - Overload of Singleton-Zenith 345 kV
 - **E4: Fayette-O'Brien 345 kV**
 - Overload of Singleton-Zenith 345 kV

Result – G-1+N-1 Analysis

- Options that did not meet the G-1+N-1 Analysis:
 - **C1: Twin Oak-Zenith 345 kV**
 - ✓ Heavy flow* on Singleton-Zenith 345 kV
 - **E1: Jewett-King 345 kV**
 - ✓ Overload of Singleton-Zenith 345 kV
 - **E5: Jewett-Jack Creek-O'Brien 345 kV**
 - ✓ Overload of Singleton-Zenith 345 kV
 - **E7: Sadow-Salem Zenith 345 kV**
 - ✓ Overload of Singleton-Zenith 345 kV
 - ✓ Heavy flow* on Jewett-Singleton 345 kV
 - **L3: Navarro-King 500 kV**
 - ✓ Overload of Singleton-Zenith 345 kV
 - **L4: Navarro-King 345 kV with 50% series compensation**
 - ✓ Overload of Singleton-Zenith 345 kV
 - **L2: Navarro-King 345 kV**
 - ✓ Overload of Singleton-Zenith 345 kV
 - ✓ Heavy flow* on Jewett-Singleton 345 kV

Selected Option for Further Analysis

- **Eight options selected for further study**
 - Option 1: Twin Oak-Zenith 345 kV with 25% series compensation (~117 miles)
 - Option 2: Twin Oak-Zenith 345 kV with 50% series compensation (~117 miles)
 - Option 3: Limestone-Ragan Creek-Zenith 345 kV (~130.2 miles)
 - Option 4: Limestone-Gibbons Creek-Zenith 345 kV (~122 miles)
 - Option 5: Jewett-Jack Creek-Zenith 345 kV (~134.1 miles)
 - Option 6: Jewett-Jack Creek-Zenith 345 kV with 25% series compensation (~134.1 miles)
 - Option 7: Jewett-Jack Creek-Zenith 345 kV with 50% series compensation (~134.1 miles)
 - Option 8: Navarro-Gibbons Creek-Zenith 345 kV (~165 miles)
- **Few upgrades of existing lines are also included as part of the options**
 - For all options above, upgrade
 - T.H. Wharton-Addicks 345 kV line (~10.7 miles)
 - For Option 6 and 7, upgrade
 - Jack Creek-Twin Oak double-circuit 345 kV line (terminal upgrade)
 - For Option 8, upgrade
 - Jack Creek-Twin Oak 345 kV #1 (terminal upgrade)
- **These select options moved to the next stage for further evaluation.**


Result of Transfer Capability Analysis (Thermal Overload)

- Performed power transfer analysis and identified future thermal upgrades needed for each option over the next 15 years (2028)

| Option | | by 2025 | by 2026 | by 2027 | by 2028 |
|----------|--|-----------------------------------|---|--|--|
| Option 1 | Twin Oak-Zenith w/ 25% compensation plus TH Wharton-Addicks upgrade | | Singleton-Zenith 345 kV (53.2 mi) | Big Brown-Jewett 345 kV (32.8 mi) | Zenith-TH Wharton 345 kV (15.1 mi) |
| Option 2 | Twin Oak-Zenith w/ 50% compensation plus TH Wharton-Addicks upgrade | | Big Brown-Jewett 345 kV (32.8 mi) | | Singleton-Zenith 345 kV (53.2 mi), Zenith-TH Wharton 345 kV (15.1 mi) |
| Option 3 | Limestone-Ragan Creek-Zenith plus TH Wharton-Addicks upgrade | | | Singleton-Zenith 345 kV (53.2 mi), Jack Creek-Twin Oak #1 (26.7 mi), Big Brown-Jewett 345 kV (32.8 mi) | Gibbons Creek-Ragan Creek 345 kV (9.6 mi) |
| Option 4 | Limestone-Gibbons Creek-Zenith plus TH Wharton-Addicks upgrade | | | Singleton-Zenith 345 kV (53.2 mi), Big Brown-Jewett 345 kV (32.8 mi) | Jack Creek-Twin Oak #1 (26.7 mi) |
| Option 5 | Jewett-Jack Creek-Zenith plus TH Wharton-Addicks upgrade | Singleton-Zenith 345 kV (53.2 mi) | Big Brown-Jewett 345 kV (32.8 mi), Twin Oak-Jack Creek 345 kV (26.7 mi) | | Jewett-Singleton 345 kV (49.9 mi), Zenith-TH Wharton 345 kV (15.1 mi), Gibbons Creek-Singleton 345 kV (9.4 mi), Gibbons Creek-Jack Creek 345 kV (21.3 mi) |
| Option 6 | Jewett-Jack Creek-Zenith w/ 25% compensation plus TH Wharton-Addicks & Twin Oak-Jack Creek upgrade | | Big Brown-Jewett 345 kV (32.8 mi) | Singleton-Zenith 345 kV (53.2 mi) | Zenith-TH Wharton 345 kV (15.1 mi), Twin Oak-Jack Creek 345 kV (26.7 mi) |
| Option 7 | Jewett-Jack Creek-Zenith w/ 50% compensation plus TH Wharton-Addicks & Twin Oak-Jack Creek upgrade | | Big Brown-Jewett 345 kV (32.8 mi) | | Singleton-Zenith 345 kV (53.2 mi), Zenith-TH Wharton 345 kV (15.1 mi), Twin Oak-Jack Creek 345 kV (26.7 mi) |
| Option 8 | Navarro-Gibbons Creek-Zenith plus TH Wharton-Addicks & Twin Oak-Jack Creek upgrade | | Jewett-Singleton 345 kV (49.9 mi), Gibbons Creek-Twin Oak & Gibbons Creek-Jack Creek-Twin Oak 345 kV (48 mi) | Singleton-Zenith 345 kV (53.2 mi) | |

Result of Transfer Capability Analysis (Voltage Stability)

- MW load level at the point of voltage collapse under each select option without any upgrades
- Voltage collapse occurs beyond 2028 under every option except Option 5



Impact of Old Generator Retirement

- 11 units (total 1939 MW) are more than 50 year old by 2018
 - Sam Bertron G1, G2, G3, G4 and GT2
 - T.H. Warton GT1
 - W.A. Parish G1, G2, G3, G4, and GT1
- Result of AC power flow analysis with all these 50-year old units offline
 - System problems in the 2018 base case either under system intact or N-1 conditions:
 - Under system intact condition with the units offline,
 - Overload of Singleton-Zenith 345 kV line
 - Overload of Jewett-Singleton 345 kV line
 - Low voltage around Tomball, Kuykendahl, Bobville, Rothwood
 - Under N-1 contingency conditions,
 - Overload of Jewett-Singleton 345 kV line
 - Overload of the bus ties at Twin Oak/Oak Grove
 - Overload of Singleton-Zenith 345 kV line
 - Overload of Gibbons Creek-Twin Oak 345 kV line
 - Overload of Jack Creek-Twin Oak 345 kV line
 - Overload of Gibbons Creek-Singleton 345 kV line
 - Overload of Roans Prairie-Bobville-Kuykendahl 345 kV line
 - Heavy flow on Singleton-Tomball and Gibbons Creek-Jack Creek 345 kV line
 - Low voltages at 15 345-KV buses and 38 138-kV buses in Houston area

Impact of Old Generator Retirement

- Result of AC power flow analysis with each option:
 - ✓ No system problem under system intact condition
 - ✓ No low voltage issues under N-1 condition
 - ✓ Table below shows overload and heavy flow issues under N-1 conditions when the old units are offline

| Elements | Jewett S-Singleton 345 kV line #1 | Jewett N-Singleton 345 kV line #1 | Twin Oak-Oak Grove 345 kV bus tie | Twin Oak 345 kV bus tie | Singleton-Zenith 345 kV line #98 | Singleton-Zenith 345 kV line #99 | Gibbons Creek-Twin Oak 345 kV #1 | Gibbons Creek-Jack Creek 345 kV #2 | Jack Creek-Twin Oak 345 kV #1 | Jack Creek-Twin Oak 345 kV #2 |
|----------|-----------------------------------|-----------------------------------|-----------------------------------|-------------------------|----------------------------------|----------------------------------|----------------------------------|------------------------------------|-------------------------------|-------------------------------|
| Option 1 | | | Overload | Overload | Overload | Overload | | | | |
| Option 2 | | | Overload | Overload | | | | | | |
| Option 3 | | | Heavy flow | Heavy flow | Heavy flow | Heavy flow | | | Heavy flow | |
| Option 4 | | | Heavy flow | Heavy flow | Heavy flow | Heavy flow | | | | |
| Option 5 | | | Overload | Overload | Overload | Overload | | | Overload | Overload |
| Option 6 | | | Overload | Overload | Heavy flow | Heavy flow | | | | |
| Option 7 | | | Heavy flow | Heavy flow | | | | | Heavy flow | Heavy flow |
| Option 8 | Overload | Overload | Heavy flow | Heavy flow | Heavy flow | Heavy flow | Overload | Heavy flow | Heavy flow | |

Impact of Old Generator Retirement

- Result of generation reduction analysis:

- ✓ Tested G-1+N-1 while reducing the output from the old units
- ✓ Estimated total MW output that can be reduced from the old unit under each select option without causing any thermal issues

| Option | Description | Approximate MW generation reduction that starts causing overload under G-1+N-1 |
|----------|---|--|
| Option 1 | Twin Oak-Zenith with 25% series compensation plus TH Wharton-Addicks upgrade | 900.6 |
| Option 2 | Twin Oak-Zenith with 50% series compensation plus TH Wharton-Addicks upgrade | 911.1 |
| Option 3 | Limestone-Ragan Creek-Zenith plus TH Wharton-Addicks upgrade | 1061.3 |
| Option 4 | Limestone-Gibbons Creek-Zenith plus TH Wharton-Addicks upgrade | 1020.0 |
| Option 5 | Jewett-Jack Creek-Zenith plus TH Wharton-Addicks upgrade | 400.0 |
| Option 6 | Jewett-Jack Creek-Zenith with 25% series compensation plus TH Wharton-Addicks upgrade and Twin Oak-Jack Creek upgrade | 773.8 |
| Option 7 | Jewett-Jack Creek-Zenith with 50% series compensation plus TH Wharton-Addicks upgrade and Twin Oak-Jack Creek upgrade | 662.6 |
| Option 8 | Navarro-Gibbons Creek-Zenith plus TH Wharton-Addicks upgrade and Twin Oak-Jack Creek upgrade | 652.6 |

Impact of NERC Category C and D

- Tested 23 severe events (NERC Cat. C and D contingencies) based on the past study and knowledge of the system

| Options | Description | # of Unsolved Contingencies (NERC Cat. D) | Thermal Overload 345 kV 115% above | Low Voltage At 345 kV Buses (below 0.9 pu) |
|----------|--|---|---------------------------------------|--|
| | Base Case | 6 | 6 | 5 |
| Option 1 | Tw in Oak-Zenith with 25% series compensation plus TH Wharton-Addicks upgrade | 1 | 1 | 4 |
| Option 2 | Tw in Oak-Zenith with 50% series compensation plus TH Wharton-Addicks upgrade | 1 | 0 | 3 |
| Option 3 | Limestone-Ragan Creek-Zenith plus TH Wharton-Addicks upgrade | 1 | 0 | 5 |
| Option 4 | Limestone-Gibbons Creek-Zenith plus TH Wharton-Addicks upgrade | 1 | 0 | 5 |
| Option 5 | Jewett-Jack Creek-Zenith plus TH Wharton-Addicks upgrade | 1 | 1 | 6 |
| Option 6 | Jewett-Jack Creek-Zenith with 25% series compensation plus TH Wharton-Addicks upgrade and Tw in Oak-Jack Creek upgrade | 1 | 0 | 5 |
| Option 7 | Jewett-Jack Creek-Zenith with 50% series compensation plus TH Wharton-Addicks upgrade and Tw in Oak-Jack Creek upgrade | 1 | 0 | 3 |
| Option 8 | Navarro-Gibbons Creek-Zenith plus TH Wharton-Addicks upgrade and Tw in Oak-Jack Creek upgrade | 1 | 0 | 5 |

System Loss Reduction

- System losses with each option modeled in the 2018 summer peak study case were compared to the base case
- In every option, significant loss reduction is expected

| Option | Option 1 (TWZ- 25%COMP-TA) | Option 2 (TWZ- 50%COMP-TA) | Option 3 (LRZ-TA) | Option 4 (LGZ-TA) | Option 5 (JJZ-TA) | Option 6 (JJZ-25%COMP- TATJ) | Option 7 (JJZ-50%COMP- TATJ) | Option 8 (NGZ-TATJ) |
|----------------------------------|----------------------------------|----------------------------------|----------------------|----------------------|----------------------|------------------------------------|------------------------------------|------------------------|
| System Loss Reduction (MW) | 44.7 | 38.8 | 47.6 | 31.2 | 38.2 | 44.8 | 35 | 32.7 |

Sensitivity Analyses for Transfer Study

- A sensitivity analysis was performed using the latest SSWG case
 - Case used: As-built 2014 SSWG Data Set B 2018 base case
 - Results confirmed overload on Singleton-Zenith 345 kV double circuit line under the G-1+N-1 condition

- Power transfer analysis using different load scaling approach
 - Power transfer analysis was performed for certain options under N-1 conditions using the following two load scaling approaches:
 - 1) Scaling load down in North, North Central, West and Far West
 - 2) Scaling all load down except the load in Coast Weather Zone
 - The result indicates that:
 - There are reliability criteria violations in 2018 regardless of which approach is used
 - The need identification for the next set of upgrades may be deferred by a year or two if the all-load-scaling (#2) approach is used
 - For example, roughly 220~300 MW difference in the transfer capability, when the future overload issue on the Singleton-Zenith double-circuit 345 kV line occurs with each option

Cost Analysis

■ Methodology and Assumptions:

- ✓ In addition to the cost of each select option, the cost of each future upgrade (up to 2028) was also considered to capture the long-term reliability benefit of each select option.
- ✓ Overall cost associated with each select option was calculated.

Overall cost = Construction cost* of each select option +
NPV[†] of construction cost** of future upgrades

* the construction cost of each select option in 2018 dollar.

** the future value of each future upgrade, estimated by using 3% inflation rate.

† 8% discount rate was used to calculate the NPV (in 2018 dollar) of the set of future upgrades under each select option.

(Reference of discount rate: www.puc.texas.gov/industry/electric/reports/31600/PUCT_CBA_Report_Final.pdf)

Result of Cost Analysis


Unit: \$ Million

| Option | Construction Cost * of Each Select Option (in 2018 dollar) | Net Present Value (NPV) of Construction Cost of the Set of Future Upgrades (in 2018 dollar) | Overall Cost (in 2018 dollar) |
|-----------------------|---|---|----------------------------------|
| Option 1 (TWZ-25%) | 554.8 | 387.0 | 941.8 |
| Option 2 (TWZ-50%) | 572.0 | 390.6 | 962.6 |
| Option 3 (LRZ) | 610.2 | 399.5 | 1,009.7 |
| Option 4 (LGZ) | 590.1 | 383.1 | 973.3 |
| Option 5 (JJZ) | 596.3 | 652.9 | 1,249.3 |
| Option 6 (JJZ-25%) | 617.1 | 419.5 | 1,036.6 |
| Option 7 (JJZ-50%) | 629.1 | 435.2 | 1,064.4 |
| Option 8 (NGZ) | 805.9 | 537.5 | 1,343.4 |

* \$ 3.78 million-per-mile was assumed for T-line portion of the cost. ERCOT performed sensitivity analysis using different cost-per-mile assumption. No significant impact was found in selecting a best solution.



Result of Cost Analysis



Economic Analysis

- Although the Houston Import RPG review is purely driven by reliability need, ERCOT also performed an economic analysis for the year 2018 using the 2018 economic case.
- Relative annual production cost of each option was obtained by comparing the annual production cost of each option against the option with the highest annual production cost.

Unit: \$ Million

| Option | Option 1 | Option 2 | Option 3 | Option 4 | Option 5 | Option 6 | Option 7 | Option 8 |
|---|----------|----------|----------|----------|----------|----------|----------|----------|
| Relative Production cost savings (Referenced to Option 8) | 4.3 | 3.4 | 3.2 | 1.7 | 2.1 | 2.2 | 1.7 | 0.0 |