


\*A superficial, unnecessary, or overly bad sequel. Usually the second in the series though not always (see CIP). Adding the phrase to a title is similar to adding the "electric boogaloo. Examples include: "BAL-006-2," "MOD-025-2," "NERC Functional Model Version 2," "SPP PC UFLS Plan Rev 2," etc.\*\*


\*\* This is not the case.






- From a “Maintenance and Testing Program”
- To a maintenance program which includes at least one of the following activities:
  - Verify
  - Monitor
  - Test
  - Inspect
  - Calibrate


138KV TRANSFER BUS






12/4/2015


5



Version 1	Version 2
Batteries & Chargers	Batteries & Chargers
Current Transformers	Current Transformers
Potential Transformers	Potential Transformers
Carrier systems	Carrier systems
Wavetraps	Wavetraps
UF relays	UF relays
Protection Relays	Protection Relays
Special Protection Schemes	Remedial Action Systems
Protection Functional test (trip checks)	Protection Functional test (trip checks)
	UF Functional test
	Alarms or monitoring



- Our Program is strictly “Time-Based”



**CLECO**





MANSFIELD

# Unmonitored vs Monitored

Component Attribute	Maximum Interval for Unmonitored	Maximum Interval for Monitored
Protective Relay	6 years	12 years
Communications system	4 months & 6 years	12 years
Voltage & current sensing devices	12 years	None
Protection System DC supply	4 months & 18 months	None
Control Circuitry	6 or 12 years	None
Alarm Path	12 years	None
UFLS/UVLS	6 years	12 years







# Cleco's Testing Intervals

	COMPONENT ATTRIBUTES	PROTECTION SYSTEM ELEMENT or COMPONENT TYPE Standard Table	MAXIMUM INTERVAL**	CASCADE TRIGGER "work code"
1	Electromechanical or Electronic Protection relays (generation & transmission)	Protective Relays Table 1-1, Row 1	6 years	5 years "40"
2	Microprocessor Protection relays (generation & transmission)	Protective Relays Table 1-1, Row 2	12 years	10 years "40"
3	Electromechanical, Electronic, Microprocessor, & UF relays commissioning tests	Protective relays NA	Prior to in service	NA "62"
4	Special Protection or Remedial Action System relays ***	Protective Relays Table 1-1, Row 1	6 years	5 years "40"
5	Carrier systems & Wavetraps	Communication Systems Table 1-2, Row 2	12 years	10 years "40"
6	Wavetrap initial testing	Communication Systems NA	Prior to in service	NA "40"
7	CTs, PTs, CCVTs (generation & transmission) associated with BES Breaker	Voltage & Current sensing device Table 1-3, Row 1	12 years	5 years "91" Trigger tied to breaker
8	CTs, PTs, & CCVTs (generation & transmission) associated with BES Breaker initial testing	Voltage & Current sensing device NA	Prior to in service	NA
9	Battery maintenance vented lead acid (generation & transmission)	Station DC supply Table 1-4(a), Row 1b	Annual but not longer than 18 calendar months	1 year "50"
10	Battery maintenance valve regulated (transmission)	Station DC supply Table 1-4(b), Row 1b, 1c & 1d	6 calendar months	5 months "50"



# Testing Intervals cont.

	COMPONENT ATTRIBUTES	PROTECTION SYSTEM ELEMENT or COMPONENT TYPE Standard Table	MAXIMUM INTERVAL**	CASCADE TRIGGER "work code"
11	Battery maintenance vented lead acid (generation & transmission) and valve regulated (transmission)	Station DC supply Table 1-4(a), Row 1a Table 1-4(b), Row 1a	4 calendar months	3 months "51"
12	Battery maintenance vented lead acid (generation & transmission) and valve regulated (transmission) acceptance test	Station DC supply NA	6 calendar months	4 months "62"
13	Battery load test vented lead acid (generation & transmission)	Station DC supply Table 1-4(a), Row 2	6 years	5 years "82"
14	Battery replacement valve regulated (transmission)	Station DC supply NA	6 years	5 years "90"
15	Battery Charger (generation & transmission)	Station DC supply Table 1-4(a), Row 1b Table 1-4(b), Row 1c	Annual but not longer than 18 calendar months	1 year "50"
16	Protection functional test with trip coil & lockout (generation & transmission) associated with BES Breaker	Control Circuitry Table 1-5, Row 1 & 2 Table 2, Row 1	6 years	5 years "91" Trigger tied to breaker
17	Protection functional test with trip coil & lockout (generation & transmission) associated with BES Breaker initial testing	Control Circuitry NA	Prior to in service	NA "91" Trigger tied to breaker
18	UFLS functional test (distribution) associated with distribution breaker or recloser	Control Circuitry Table 3, Row 5, 6, & 7	12 years	5 years "91" Trigger tied to breaker
19	UFLS relays (distribution)	Protective Relays Table 3, Row 1 & 4	6 years	5 years "40"
20	UVLS relays (distribution) ***	Protective Relays Table 3, Row 1	6 years	5 years "40"

\*\* Annual (not to exceed 18 calendar months) or year(s) is a calendar year(s).

\*\*\* Not installed on Cleco's system

Within the equipment database (CASCADE), triggers are set by Component Type and are less than the maximum interval.



(3) PTS  
80.5KV

MANSFIELD

## What didn't change for relays.

- Protective Relays

- Verify that settings are as specified.

- include statement in test

- Test and calibrate

- Verify operation of inputs & outputs

- Verify alarm path

TRIP  
OCB 8240

21P

RI  
8240

94

94

94

TX  
RX

LFZP111

(3)MRBCT  
2000:5A  
1100

TRIP  
OCB 8238  
OCB 8240  
GCB 8242  
S&C 8236  
S&C 8244

(3)MRBCT  
2000:5A  
1100


8240 MCGRAW EDISON OCB  
AHJ-60-138-10000


(3)MRBCT  
2000:5A  
1200

XMIT  
TUNER  
RECV

CCVT  
TRENCH  
TEV 138

138KV TRANSFER BUS






(3) PTS  
80.5KV

# Cleco changes for communication systems

- Carrier & Wavetraps:
  - Verify automated testing for the presence of the channel function and alarming for the loss of function
  - Verify operation of the communications system inputs and outputs that are essential to proper functioning of the Protection System.

138KV TRANSFER BUS

MANSFIELD



Who moved my cheese?



© cartoongems.com 2008

CLECO

(3) PTS  
80.5KV


What didn't change for voltage & current sensing devices.

- PT & CT
  - Verify that current and voltage signal values are provided to the protective relays:

(3) PTS  
80.5KV


# What changed for voltage & current sensing devices.


- PT & CT
  - Nothing





# What didn't change for batteries

- Batteries
    - Verify station dc supply voltage
    - Inspect Electrolyte level
    - Inspect for unintentional grounds
    - Replace valve regulated type batteries












- Control Circuitry
  - Verify that each trip coil is able to operate...
  - Verify electrical operation of electromechanical lockout devices


138KV TRANSFER BUS



# What didn't change for UFLS

- UFLS
    - Verify that settings are as specified
    - Test and calibrate
    - Verify operation of relay inputs and outputs






(3) PTS  
80.5KV

# What could we miss!


MANSFIELD

- **Unresolved Maintenance Issues:**

- A deficiency identified during a maintenance activity that causes the component to not meet the intended performance, cannot be corrected during the maintenance interval, and requires follow up corrective action.
- Cleco will document within the maintenance database the corrective action plan. Included will be a description of the problem, who was notified of the problem (System Operations, Generation Operations, or operating personnel at the plant), and a description of the corrective action to resolve the issue.



138KV TRANSFER BUS



12/4/2015

### 138KV TRANSFER BUS

**CLECO**  
27

(3) PTS  
80.5KV

138KV MAIN BUS


MANSFIELD

# Carrier Evidence

GEC	106947				
Manufacturer	Serial Number				
393594	40				
Document Number	Work Codes				
TYPE	CT61	APPLICATION	85	1	
TEST			CAL.	A.F.	A.L.
1	Transmit	Guard FWD	40 dB	40 dB	39.5 dB
2	Transmit	Guard REV	---	27.2 dB	23.5 dB
3	Return	Loss	> 14 dB	12.8 dB	16.0 dB
4	Transmit	Trip FWD	40 dB	40.5 dB	39.1 dB
5	Transmit	Trip REV	---	30.1 dB	22.6 dB
6	Return	Loss	> 14 dB	10.4 dB	16.5 dB
7	Guard	Frequency	145.188	kHz	
8	Trip	Frequency	144.677	kHz	
9	Tripped	86TT at	Remote end		

138KV TRANSFER BUS

0609  
**CLECO** 28



(3) PTS  
80.5KV

138KV MAIN BUS

MANSFIELD

# Alarm Evidence


Results

Date_Time	Station	Point Name	Description	Point Type	Point Number
03/24/2015 12:18:45	RODMR	R0H13 SEL311L FIBERFAIL-R	ALARM	I	14156
03/24/2015 12:18:47	RODMR	R0H13 SEL311L RELAYCASE-R	ALARM	I	14157
03/24/2015 12:18:41	RODMR	R0H13 SEL311L 87P CUTOFF	ALARM	I	14154
03/24/2015 12:18:41	RODMR	R0H13 SEL311L TRIP	ALARM	I	14155
03/20/2015 13:17:49	RODMR	9045 868F TRIP-R	ALARM	I	14089
03/24/2015 12:12:04	RODMR	9045 SEL-451 TRIP	ALARM	I	14090
03/24/2015 12:12:07	RODMR	9045 BCB MAINTENANCE-A	ALARM	I	14091
03/24/2015 12:12:10	RODMR	9045 SEL-451 FAILURE-R	ALARM	I	14092
03/24/2015 12:12:32	RODMR	9045 BCB OP BLOCKED-A	ALARM	I	14093
03/24/2015 12:12:15	RODMR	9045 NO SPRING CHG-A	ALARM	I	14094
03/24/2015 12:12:38	RODMR	9045 LOW SF6 PRES-A	ALARM	I	14095
03/24/2015 12:12:19	RODMR	9045 LOF AC POWER-R	ALARM	I	14096
03/24/2015 12:12:22	RODMR	9045 MOTOR EXCS RUN-A	ALARM	I	14097
03/24/2015 12:12:25	RODMR	9045 LOF CLOSE DC-R	ALARM	I	14098
03/24/2015 12:12:27	RODMR	9045 LOF TRIP1 DC-R	ALARM	I	14099
03/24/2015 12:12:31	RODMR	9045 LOF TRIP2 DC-R	ALARM	I	14100
03/24/2015 12:12:31	RODMR	9045 BCB CLOSE BLOCKED-A	ALARM	I	14101
04/23/2015 14:26:59	RODMR	9045 TRIP COOL MONITOR-R	ALARM	I	26715
03/24/2015 12:11:53	RODMR	9045 LOF MOTOR DC-R	ALARM	I	26712
04/23/2015 13:42:24	RPS3	R0H1 SEL-387 RLY FAIL-R	ALARM	I	7491
04/23/2015 13:42:29	RPS3	R0H1 868 TRIP	ALARM	I	7492
04/23/2015 13:36:29	RPS3	R0H1 SEL-311L FRR FAIL-R	ALARM	I	7486
04/23/2015 13:36:33	RPS3	R0H1 SEL-311L RLY FAIL-R	ALARM	I	7487

138KV TRANSFER BUS

8239





RODEMACHER SUB - HINESTON LINE PANEL	
3 10/14 MODIFIED CURRENTS FOR GCB 9045	OFF
2 8/12 CHANGED CORDERS TO HINESTON LINE & REPLACED LINE PANEL	ON
1 1/08 REVISED CABLE LAYS REFERENCE	ON
REV DATE	06/15
DISCRIPTION	06/15
APPROVE BY	PS
DATE	07/15
INITIALS	PS
DRAWING NO.	54-05A
DESIGNER	3e
REVISION	1
SHEET NO. 1	



12/4/2015

138KV TRANSFER BUS

06/15

CLECO

31




REPLACED CCB 9045 WITH 936A LAMP		CHF	CHF	LSI
REV DATE	CONSTRUCTION	WHR	WHR	WHR
REV DATE	DESCRIPTION	REV DATE	REV DATE	REV DATE


0209

12/4/2015

138KV TRANSFER BUS


CLECO 32





(3) PTS  
80.5KV

138KV MAIN BUS



MANSFIELD

# Reliability Assurance Initiative


OC




138KV TRANSFER BUS

8239


CLECO








# Control Types cont.

- **Preventive** - designed to discourage non-compliance with the Reliability Standards. They are proactive internal controls that help ensure the management objective of compliance with Reliability Standards (e.g., a training tracking tool that notifies management that required training has not taken place prior to the training deadline so management can take appropriate action).













- **Preventive:** Annually, the GMs approve the Protection System Maintenance and Testing Program.


- **Expected Documentation:** Approval emails or signoff sheet
- **Test to be performed:** Prior to year end document the approval.











(3) PTS  
80.5KV



138KV TRANSFER BUS

