

Release Date: March 1, 2016

**PRELIMINARY  
Seasonal Assessment of Resource Adequacy for the ERCOT Region (SARA)  
Summer 2016**

## **SUMMARY**

The ERCOT Region is expected to have sufficient installed generating capacity to serve forecasted peak demands in the upcoming summer season (June - September 2016).

This preliminary SARA report includes a 70,588 MW summer peak load forecast based on current expectations for average weather. The summer peak load forecast for the final report, to be released in May, will reflect the weather conditions expected at that time. Regarding generation resources, expected new installed capacity additions include 1,068 MW of gas-fired generation (based on summer ratings) and 723 MW of wind with a summer peak capacity contribution of 174 MW. The unit outage forecast is 3,245 MW, developed from historical summer season outage data gathered since the start of the Texas Nodal Market in December 2010.

This SARA report reflects a change in the methodology for calculating the summer peak solar unit capacity. This methodology change was triggered by operational solar capacity registered with ERCOT reaching the 200 MW threshold as specified in ERCOT Nodal Protocol Section 3.2.6.2.2. The summer peak solar capacity contribution percentage is now 80% based on three years of historical summer solar production data, whereas the previous capacity contribution percentage was 100%. The impact of this change is a reduction in total available installed and planned solar capacity from 295 MW to 236 MW.

This SARA report also includes a new scenario that combines an extreme peak load event with low wind output. The expected summer peak capacity for wind is 2,879 MW, equivalent to a 17.3% capacity contribution based on contributions of 12% for non-coastal wind resources and 55% for coastal wind resources. In contrast, the extreme peak load/low wind scenario includes wind peak capacity of 679 MW, equivalent to a 4.1% summer peak capacity contribution. This low wind level is based on a 10th percentile value of wind output over the prior three summer seasons, and is meant to be consistent with the 90th percentile outage value used for the "extreme load/extreme generation outage" scenario.

At this time, ERCOT does not anticipate changes to available generation capacity for the summer season due to compliance with environmental regulations. The final compliance date for the Mercury and Air Toxics Standards (MATS) for coal units with compliance extensions is April 15, 2016. Confidential survey information gathered in December 2015 indicated that coal generators are expected to be compliant with MATS by the compliance date. ERCOT continues to monitor implementation and consults with generation resource owners on their compliance plans for MATS and other environmental regulations.

## Seasonal Assessment of Resource Adequacy for the ERCOT Region

Summer 2016 - Preliminary

Release Date: March 1, 2016

### Forecasted Capacity and Demand

Operational Resources (thermal and hydro), MW	66,314	Based on current Seasonal Maximum Sustainable Limits reported through the unit registration process
Switchable Capacity Total, MW	3,496	Installed capacity of units that can interconnect with other Regions and are available to ERCOT
Less Switchable Capacity Unavailable to ERCOT, MW	(300)	Based on survey responses of Switchable Resource owners
Mothball Resources, MW	805	Based on seasonal Mothball units plus Probability of Return responses of Mothball Resource owners
Private Use Network Capacity Contribution, MW	4,284	Average capability of the top 20 hours in the summer peak seasons for the past three years (2012-2014)
Non-Coastal Wind Resources Capacity Contribution, MW	1,690	Based on 12% of installed capacity for non-coastal wind resources per ERCOT Nodal Protocols Section 3.2.6.2.2
Coastal Wind Resources Capacity Contribution, MW	1,015	Based on 55% of installed capacity for coastal wind resources per ERCOT Nodal Protocols Section 3.2.6.2.2
Solar Utility-Scale, Peak Average Capacity Contribution, MW	230	Based on 80% of rated capacity for solar resources per Nodal Protocols Section 3.2.6.2.2
RMR Resources to be Under Contract, MW	0	No RMR Resources currently under contract
Non-Synchronous Ties Capacity Contribution, MW	577	Average capability of the top 20 hours in the summer peak seasons for the past three years (2012-2014)
Planned Resources (not wind) with signed IA and Air Permit, MW	1,068	Based on in-service dates provided by developers of generation resources
Planned Non-Coastal Wind with signed IA, MW	63	Based on in-service dates provided by developers of generation resources and 12% of installed capacity for non-coastal wind resources
Planned Coastal Wind with signed IA, MW	111	Based on in-service dates provided by developers of generation resources and 55% of installed capacity for coastal wind resources
Planned Solar Utility-Scale with signed IA, MW	6	Based on 80% of rated capacity for solar resources per Nodal Protocols Section 3.2.6.2.2
<b>[a] Total Resources, MW</b>	<b>79,354</b>	
<b>[b] Peak Demand, MW</b>	<b>70,588</b>	Based on normal weather from 2002-2014
<b>[c] Reserve Capacity [a - b], MW</b>	<b>8,766</b>	

### Range of Potential Risks

	Forecasted Summer Season Peak Load	Extreme Load / Typical Generation Outages	Extreme Load / Wind Output	Extreme Load / Extreme Generation Outages	
Seasonal Load Adjustment		2,754	2,754	2,754	Based on extreme weather forecast using 2011 weather data.
Typical Maintenance Outages	347	347	347	347	Based on historical average of planned outages for June through September weekdays (starting in August 2010).
Typical Forced Outages, Thermal	2,898	2,898	2,898	2,898	Based on historical average of forced outages for June through September weekdays (starting in August 2010).
90th Percentile Forced Outages, Thermal	-	-	-	1,831	Based on historical forced outages assuming a 90% confidence interval
Low Wind Output Adjustment	-	-	2,200	-	Based on the 10th percentile of wind output associated with the 100 highest Net Load hours (Load minus wind output) for the 2013-2015 summer Peak Load seasons; this wind output level is 679 MW.
<b>[d] Total Uses of Reserve Capacity</b>	<b>3,245</b>	<b>5,999</b>	<b>8,199</b>	<b>7,830</b>	
<b>[e] Capacity Available for Operating Reserves (c-d), MW</b>	<b>5,521</b>	<b>2,767</b>	<b>567</b>	<b>936</b>	
Less than 2,300 MW indicates risk of EEA1					

## Unit Capacities - Summer

UNIT NAME	GENERATION INTERCONNECTION	PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
<b>Operational Resources (Thermal)</b>								
4 COMANCHE PEAK U1		CPSES_UNIT1	SOMERVELL	NUCLEAR	NORTH	1990	1205.0	
5 COMANCHE PEAK U2		CPSES_UNIT2	SOMERVELL	NUCLEAR	NORTH	1993	1195.0	
6 SOUTH TEXAS U1		STP_STP_G1	MATAGORDA	NUCLEAR	COASTAL	1988	1286.0	
7 SOUTH TEXAS U2		STP_STP_G2	MATAGORDA	NUCLEAR	COASTAL	1989	1295.0	
8 BIG BROWN U1		BBSES_UNIT1	FREESTONE	COAL	NORTH	1971	606.0	
9 BIG BROWN U2		BBSES_UNIT2	FREESTONE	COAL	NORTH	1972	602.0	
10 COLETO CREEK		COLETO_COLETOG1	GOLIAD	COAL	SOUTH	1980	660.0	
11 FAYETTE POWER U1		FPPYD1_FPP_G1	FAYETTE	COAL	SOUTH	1979	604.0	
12 FAYETTE POWER U2		FPPYD1_FPP_G2	FAYETTE	COAL	SOUTH	1980	599.0	
13 FAYETTE POWER U3		FPPYD2_FPP_G3	FAYETTE	COAL	SOUTH	1988	437.0	
14 GIBBONS CREEK U1		GIBCRK_GIB_CRG1	GRIMES	COAL	NORTH	1983	470.0	
15 J K SPRUCE U1		CALAVERS_JKS1	BEXAR	COAL	SOUTH	1992	560.0	
16 J K SPRUCE U2		CALAVERS_JKS2	BEXAR	COAL	SOUTH	2010	775.0	
17 J T DEELY U1		CALAVERS_JTD1	BEXAR	COAL	SOUTH	1977	420.0	
18 J T DEELY U2		CALAVERS_JTD2	BEXAR	COAL	SOUTH	1978	420.0	
19 LIMESTONE U1		LEG_LEG_G1	LIMESTONE	COAL	NORTH	1985	831.0	
20 LIMESTONE U2		LEG_LEG_G2	LIMESTONE	COAL	NORTH	1986	858.0	
21 MARTIN LAKE U1		MLSES_UNIT1	RUSK	COAL	NORTH	1977	800.0	
22 MARTIN LAKE U3		MLSES_UNIT3	RUSK	COAL	NORTH	1979	805.0	
23 MONTICELLO U1		MNSES_UNIT1	TITUS	COAL	NORTH	1974	535.0	
24 MONTICELLO U2		MNSES_UNIT2	TITUS	COAL	NORTH	1975	535.0	
25 MONTICELLO U3		MNSES_UNIT3	TITUS	COAL	NORTH	1978	795.0	
26 OAK GROVE SES U1		OGSES_UNIT1A	ROBERTSON	COAL	NORTH	2010	840.0	
27 OAK GROVE SES U2		OGSES_UNIT2	ROBERTSON	COAL	NORTH	2011	825.0	
28 OKLAUNION U1		OKLA_OKLA_G1	WILBARGER	COAL	WEST	1986	650.0	
29 SAN MIGUEL U1		SANMIGL_G1	ATASCOSA	COAL	SOUTH	1982	391.0	
30 SANDOW U5		SD5SES_UNITS5	MILAM	COAL	SOUTH	2010	600.0	
31 SANDY CREEK U1		SCES_UNIT1	MCLENNAN	COAL	NORTH	2013	970.0	
32 TWIN OAKS U1		TNP_ONE_TNP_O_1	ROBERTSON	COAL	NORTH	1990	156.0	
33 TWIN OAKS U2		TNP_ONE_TNP_O_2	ROBERTSON	COAL	NORTH	1991	156.0	
34 W A PARISH U5		WAP_WAP_G5	FT. BEND	COAL	HOUSTON	1977	659.0	
35 W A PARISH U6		WAP_WAP_G6	FT. BEND	COAL	HOUSTON	1978	658.0	
36 W A PARISH U7		WAP_WAP_G7	FT. BEND	COAL	HOUSTON	1980	577.0	
37 W A PARISH U8		WAP_WAP_G8	FT. BEND	COAL	HOUSTON	1982	610.0	
38 ARTHUR VON ROSENBERG 1 CTG 1		BRAUNIG_AVR1_CT1	BEXAR	GAS	SOUTH	2000	149.0	
39 ARTHUR VON ROSENBERG 1 CTG 2		BRAUNIG_AVR1_CT2	BEXAR	GAS	SOUTH	2000	149.0	
40 ARTHUR VON ROSENBERG 1 STG		BRAUNIG_AVR1_ST	BEXAR	GAS	SOUTH	2000	160.0	
41 BARNEY M DAVIS REPOWER CTG 3		B_DAVID_B_DAVIG3	NUECES	GAS	COASTAL	2010	157.0	
42 BARNEY M DAVIS REPOWER CTG 4		B_DAVID_B_DAVIG4	NUECES	GAS	COASTAL	2010	157.0	
43 BARNEY M DAVIS REPOWER STG 2		B_DAVID_B_DAVIG2	NUECES	GAS	COASTAL	1976	319.0	
44 BASTROP ENERGY CENTER CTG 1		BASTEN_GTG1100	BASTROP	GAS	SOUTH	2002	150.0	
45 BASTROP ENERGY CENTER CTG 2		BASTEN_GTG2100	BASTROP	GAS	SOUTH	2002	150.0	
46 BASTROP ENERGY CENTER STG		BASTEN_ST0100	BASTROP	GAS	SOUTH	2002	233.0	
47 BOSQUE ENERGY CENTER CTG 1		BOSQUESW_BSQSU_1	BOSQUE	GAS	NORTH	2000	148.9	
48 BOSQUE ENERGY CENTER STG 4		BOSQUESW_BSQSU_4	BOSQUE	GAS	NORTH	2001	81.4	
49 BOSQUE ENERGY CENTER CTG 2		BOSQUESW_BSQSU_2	BOSQUE	GAS	NORTH	2000	148.9	
50 BOSQUE ENERGY CENTER CTG 3		BOSQUESW_BSQSU_3	BOSQUE	GAS	NORTH	2001	150.2	
51 BOSQUE ENERGY CENTER STG 5		BOSQUESW_BSQSU_5	BOSQUE	GAS	NORTH	2009	214.9	
52 BRAZOS VALLEY CTG 1		BVE_UNIT1	FORT BEND	GAS	HOUSTON	2003	166.0	
53 BRAZOS VALLEY CTG 2		BVE_UNIT2	FORT BEND	GAS	HOUSTON	2003	166.0	
54 BRAZOS VALLEY STG 3		BVE_UNIT3	FORT BEND	GAS	HOUSTON	2003	270.0	
55 CALENERGY-FALCON SEABOARD CTG 1		FLCNS_UNIT1	HOWARD	GAS	WEST	1987	75.0	
56 CALENERGY-FALCON SEABOARD CTG 2		FLCNS_UNIT2	HOWARD	GAS	WEST	1987	75.0	
57 CALENERGY-FALCON SEABOARD STG 3		FLCNS_UNIT3	HOWARD	GAS	WEST	1988	70.0	
58 CEDAR BAYOU 4 CTG 1		CBY4_CT41	CHAMBERS	GAS	HOUSTON	2009	163.0	
59 CEDAR BAYOU 4 CTG 2		CBY4_CT42	CHAMBERS	GAS	HOUSTON	2009	163.0	
60 CEDAR BAYOU 4 STG		CBY4_ST04	CHAMBERS	GAS	HOUSTON	2009	178.0	
61 COLORADO BEND ENERGY CENTER CTG 1		CBEC_GT1	WHARTON	GAS	SOUTH	2007	70.0	
62 COLORADO BEND ENERGY CENTER CTG 2		CBEC_GT2	WHARTON	GAS	SOUTH	2007	62.0	
63 COLORADO BEND ENERGY CENTER STG 1		CBEC_STG1	WHARTON	GAS	SOUTH	2007	101.0	
64 COLORADO BEND ENERGY CENTER CTG 3		CBEC_GT3	WHARTON	GAS	SOUTH	2008	69.0	
65 COLORADO BEND ENERGY CENTER CTG 4		CBEC_GT4	WHARTON	GAS	SOUTH	2008	63.0	
66 COLORADO BEND ENERGY CENTER STG 2		CBEC_STG2	WHARTON	GAS	SOUTH	2008	103.0	
67 CVC CHANNELVIEW CTG 1		CVC_CVC_G1	HARRIS	GAS	HOUSTON	2008	172.0	
68 CVC CHANNELVIEW CTG 2		CVC_CVC_G2	HARRIS	GAS	HOUSTON	2008	164.0	
69 CVC CHANNELVIEW CTG 3		CVC_CVC_G3	HARRIS	GAS	HOUSTON	2008	164.0	
70 CVC CHANNELVIEW STG 5		CVC_CVC_G5	HARRIS	GAS	HOUSTON	2008	146.0	
71 DEER PARK ENERGY CENTER CTG 1		DDPEC_GT1	HARRIS	GAS	HOUSTON	2002	181.0	
72 DEER PARK ENERGY CENTER CTG 2		DDPEC_GT2	HARRIS	GAS	HOUSTON	2002	193.0	
73 DEER PARK ENERGY CENTER CTG 3		DDPEC_GT3	HARRIS	GAS	HOUSTON	2002	181.0	
74 DEER PARK ENERGY CENTER CTG 4		DDPEC_GT4	HARRIS	GAS	HOUSTON	2002	193.0	
75 DEER PARK ENERGY CENTER STG		DDPEC_ST1	HARRIS	GAS	HOUSTON	2002	290.0	
76 DEER PARK ENERGY CENTER CTG 6		DDPEC_GT6	HARRIS	GAS	HOUSTON	2014	165.0	
77 ENNIS POWER STATION CTG 2		ETCCS_CT1	ELLIS	GAS	NORTH	2002	196.0	
78 ENNIS POWER STATION STG 1		ETCCS_UNIT1	ELLIS	GAS	NORTH	2002	116.0	
79 FERGUSON REPLACEMENT CTG1		FERGCC_FERGGT1	LLANO	GAS	SOUTH	2014	161.9	
80 FERGUSON REPLACEMENT CTG2		FERGCC_FERGGT2	LLANO	GAS	SOUTH	2014	161.9	
81 FERGUSON REPLACEMENT STG		FERGCC_FERGST1	LLANO	GAS	SOUTH	2014	186.0	
82 FORNEY ENERGY CENTER CTG 11		FRNYPP_GT11	KAUFMAN	GAS	NORTH	2003	169.0	
83 FORNEY ENERGY CENTER CTG 12		FRNYPP_GT12	KAUFMAN	GAS	NORTH	2003	161.0	
84 FORNEY ENERGY CENTER CTG 13		FRNYPP_GT13	KAUFMAN	GAS	NORTH	2003	161.0	
85 FORNEY ENERGY CENTER CTG 21		FRNYPP_GT21	KAUFMAN	GAS	NORTH	2003	169.0	
86 FORNEY ENERGY CENTER CTG 22		FRNYPP_GT22	KAUFMAN	GAS	NORTH	2003	161.0	
87 FORNEY ENERGY CENTER CTG 23		FRNYPP_GT23	KAUFMAN	GAS	NORTH	2003	161.0	
88 FORNEY ENERGY CENTER STG 10		FRNYPP_ST10	KAUFMAN	GAS	NORTH	2003	420.0	
89 FORNEY ENERGY CENTER STG 20		FRNYPP_ST20	KAUFMAN	GAS	NORTH	2003	420.0	
90 FREESTONE ENERGY CENTER CTG 1		FREC_GT1	FREESTONE	GAS	NORTH	2002	151.6	
91 FREESTONE ENERGY CENTER CTG 2		FREC_GT2	FREESTONE	GAS	NORTH	2002	151.6	
92 FREESTONE ENERGY CENTER STG 3		FREC_ST3	FREESTONE	GAS	NORTH	2002	176.2	
93 FREESTONE ENERGY CENTER CTG 4		FREC_GT4	FREESTONE	GAS	NORTH	2002	151.7	
94 FREESTONE ENERGY CENTER CTG 5		FREC_GT5	FREESTONE	GAS	NORTH	2002	151.7	

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
95 FREESTONE ENERGY CENTER STG 6		FREC_ST6	FREESTONE	GAS	NORTH	2002	174.5
96 GUADALUPE ENERGY CENTER CTG 1		GUADG_GAS1	GUADALUPE	GAS	SOUTH	2000	148.0
97 GUADALUPE ENERGY CENTER CTG 2		GUADG_GAS2	GUADALUPE	GAS	SOUTH	2000	148.0
98 GUADALUPE ENERGY CENTER CTG 3		GUADG_GAS3	GUADALUPE	GAS	SOUTH	2000	148.0
99 GUADALUPE ENERGY CENTER CTG 4		GUADG_GAS4	GUADALUPE	GAS	SOUTH	2000	148.0
100 GUADALUPE ENERGY CENTER STG 5		GUADG_STM5	GUADALUPE	GAS	SOUTH	2000	197.0
101 GUADALUPE ENERGY CENTER STG 6		GUADG_STM6	GUADALUPE	GAS	SOUTH	2000	197.0
102 HAYS ENERGY FACILITY CSG 1		HAYSEN_HAYSENG1	HAYS	GAS	SOUTH	2002	216.0
103 HAYS ENERGY FACILITY CSG 2		HAYSEN_HAYSENG2	HAYS	GAS	SOUTH	2002	216.0
104 HAYS ENERGY FACILITY CSG 3		HAYSEN_HAYSENG3	HAYS	GAS	SOUTH	2002	225.0
105 HAYS ENERGY FACILITY CSG 4		HAYSEN_HAYSENG4	HAYS	GAS	SOUTH	2002	225.0
106 HIDALGO ENERGY CENTER CTG 1		DUKE_DUKE_GT1	HIDALGO	GAS	SOUTH	2000	143.0
107 HIDALGO ENERGY CENTER CTG 2		DUKE_DUKE_GT2	HIDALGO	GAS	SOUTH	2000	143.0
108 HIDALGO ENERGY CENTER STG		DUKE_DUKE_ST1	HIDALGO	GAS	SOUTH	2000	172.0
109 JACK COUNTY GEN FACILITY CTG 1		JACKCNTY_CT1	JACK	GAS	NORTH	2005	150.0
110 JACK COUNTY GEN FACILITY CTG 2		JACKCNTY_CT2	JACK	GAS	NORTH	2005	150.0
111 JACK COUNTY GEN FACILITY STG 1		JACKCNTY_STG	JACK	GAS	NORTH	2005	295.0
112 JACK COUNTY GEN FACILITY CTG 3		JCKCNTY2_CT3	JACK	GAS	NORTH	2011	150.0
113 JACK COUNTY GEN FACILITY CTG 4		JCKCNTY2_CT4	JACK	GAS	NORTH	2011	150.0
114 JACK COUNTY GEN FACILITY STG 2		JCKCNTY2_ST2	JACK	GAS	NORTH	2011	295.0
115 JOHNSON COUNTY GEN FACILITY CTG		TEN_CT1	JOHNSON	GAS	NORTH	1997	163.0
116 JOHNSON COUNTY GEN FACILITY STG		TEN_STG	JOHNSON	GAS	NORTH	1997	106.0
117 LAMAR ENERGY CENTER CTG 11		LPCCS_CT11	LAMAR	GAS	NORTH	2000	163.0
118 LAMAR ENERGY CENTER CTG 12		LPCCS_CT12	LAMAR	GAS	NORTH	2000	153.0
119 LAMAR ENERGY CENTER CTG 21		LPCCS_CT21	LAMAR	GAS	NORTH	2000	153.0
120 LAMAR ENERGY CENTER CTG 22		LPCCS_CT22	LAMAR	GAS	NORTH	2000	163.0
121 LAMAR ENERGY CENTER STG 1		LPCCS_UNIT1	LAMAR	GAS	NORTH	2000	204.0
122 LAMAR ENERGY CENTER STG 2		LPCCS_UNIT2	LAMAR	GAS	NORTH	2000	204.0
123 LOST PINES POWER CTG 1		LOSTPI_LOSTPGT1	BASTROP	GAS	SOUTH	2001	170.0
124 LOST PINES POWER CTG 2		LOSTPI_LOSTPGT2	BASTROP	GAS	SOUTH	2001	170.0
125 LOST PINES POWER STG		LOSTPL_LOSTPST1	BASTROP	GAS	SOUTH	2001	188.0
126 MAGIC VALLEY STATION CTG 1		NEDIN_NEDIN_G1	HIDALGO	GAS	SOUTH	2001	208.6
127 MAGIC VALLEY STATION CTG 2		NEDIN_NEDIN_G2	HIDALGO	GAS	SOUTH	2001	208.6
128 MAGIC VALLEY STATION STG		NEDIN_NEDIN_G3	HIDALGO	GAS	SOUTH	2001	253.0
129 MIDLOTHIAN ENERGY FACILITY CS 1		MDANP_CT1	ELLIS	GAS	NORTH	2001	235.0
130 MIDLOTHIAN ENERGY FACILITY CS 2		MDANP_CT2	ELLIS	GAS	NORTH	2001	235.0
131 MIDLOTHIAN ENERGY FACILITY CS 3		MDANP_CT3	ELLIS	GAS	NORTH	2001	235.0
132 MIDLOTHIAN ENERGY FACILITY CS 4		MDANP_CT4	ELLIS	GAS	NORTH	2001	235.0
133 MIDLOTHIAN ENERGY FACILITY CS 5		MDANP_CT5	ELLIS	GAS	NORTH	2002	252.0
134 MIDLOTHIAN ENERGY FACILITY CS 6		MDANP_CT6	ELLIS	GAS	NORTH	2002	252.0
135 NUECES BAY REPOWER CTG 8		NUECES_B_NUECESG8	NUECES	GAS	COASTAL	2010	157.0
136 NUECES BAY REPOWER CTG 9		NUECES_B_NUECESG9	NUECES	GAS	COASTAL	2010	157.0
137 NUECES BAY REPOWER STG 7		NUECES_B_NUECESG7	NUECES	GAS	COASTAL	1972	319.0
138 ODESSA-ECTOR POWER CTG 11		OECCS_CT11	ECTOR	GAS	WEST	2001	146.4
139 ODESSA-ECTOR POWER CTG 12		OECCS_CT12	ECTOR	GAS	WEST	2001	143.6
140 ODESSA-ECTOR POWER CTG 21		OECCS_CT21	ECTOR	GAS	WEST	2001	141.9
141 ODESSA-ECTOR POWER CTG 22		OECCS_CT22	ECTOR	GAS	WEST	2001	137.7
142 ODESSA-ECTOR POWER STG 1		OECCS_UNIT1	ECTOR	GAS	WEST	2001	210.0
143 ODESSA-ECTOR POWER STG 2		OECCS_UNIT2	ECTOR	GAS	WEST	2001	210.0
144 PANDA SHERMAN POWER CTG1		PANDA_S_SHER1CT1	GRAYSON	GAS	NORTH	2014	196.0
145 PANDA SHERMAN POWER CTG2		PANDA_S_SHER1CT2	GRAYSON	GAS	NORTH	2014	195.0
146 PANDA SHERMAN POWER STG		PANDA_S_SHER1ST1	GRAYSON	GAS	NORTH	2014	326.0
147 PANDA TEMPLE I POWER CTG1		PANDA_T1_TMP1CT1	BELL	GAS	NORTH	2014	195.0
148 PANDA TEMPLE I POWER CTG2		PANDA_T1_TMP1CT2	BELL	GAS	NORTH	2014	195.0
149 PANDA TEMPLE I POWER STG		PANDA_T1_TMP1ST1	BELL	GAS	NORTH	2014	312.0
150 PANDA TEMPLE II POWER CTG1		PANDA_T2_TMP1CT2	BELL	GAS	NORTH	2015	191.2
151 PANDA TEMPLE II POWER CTG2		PANDA_T2_TMP1CT2	BELL	GAS	NORTH	2015	191.2
152 PANDA TEMPLE II POWER STG		PANDA_T2_TMP2ST1	BELL	GAS	NORTH	2015	334.7
153 PARIS ENERGY CENTER CTG 1		TNSKA_GT1	LAMAR	GAS	NORTH	1989	76.0
154 PARIS ENERGY CENTER CTG 2		TNSKA_GT2	LAMAR	GAS	NORTH	1989	76.0
155 PARIS ENERGY CENTER STG		TNSKA_STG	LAMAR	GAS	NORTH	1990	87.0
156 PASADENA COGEN FACILITY CTG 2		PSG_PSG_GT2	HARRIS	GAS	HOUSTON	2000	164.0
157 PASADENA COGEN FACILITY CTG 3		PSG_PSG_GT3	HARRIS	GAS	HOUSTON	2000	164.0
158 PASADENA COGEN FACILITY STG 2		PSG_PSG_ST2	HARRIS	GAS	HOUSTON	2000	167.0
159 QUAIL RUN ENERGY CTG 1		QALSW_G1	ECTOR	GAS	WEST	2007	74.0
160 QUAIL RUN ENERGY CTG 2		QALSW_G2	ECTOR	GAS	WEST	2007	74.0
161 QUAIL RUN ENERGY STG 1		QALSW_STG1	ECTOR	GAS	WEST	2007	98.0
162 QUAIL RUN ENERGY CTG 3		QALSW_G3	ECTOR	GAS	WEST	2008	72.0
163 QUAIL RUN ENERGY CTG 4		QALSW_G4	ECTOR	GAS	WEST	2008	72.0
164 QUAIL RUN ENERGY STG 2		QALSW_STG2	ECTOR	GAS	WEST	2008	98.0
165 RIO NOGALES POWER CTG 1		RIONOG_C1	GUADALUPE	GAS	SOUTH	2002	154.0
166 RIO NOGALES POWER CTG 2		RIONOG_C2	GUADALUPE	GAS	SOUTH	2002	154.0
167 RIO NOGALES POWER CTG 3		RIONOG_C3	GUADALUPE	GAS	SOUTH	2002	154.0
168 RIO NOGALES POWER STG 4		RIONOG_ST1	GUADALUPE	GAS	SOUTH	2002	323.0
169 SAM RAYBURN POWER CTG 7		RAYBURN_RAYBURG7	VICTORIA	GAS	SOUTH	2003	50.0
170 SAM RAYBURN POWER CTG 8		RAYBURN_RAYBURG8	VICTORIA	GAS	SOUTH	2003	50.0
171 SAM RAYBURN POWER CTG 9		RAYBURN_RAYBURG9	VICTORIA	GAS	SOUTH	2003	50.0
172 SAM RAYBURN POWER STG 10		RAYBURN_RAYBURG10	VICTORIA	GAS	SOUTH	2003	40.0
173 SANDHILL ENERGY CENTER CTG 5A		SANDHSYD_SH_5A	TRAVIS	GAS	SOUTH	2004	150.0
174 SANDHILL ENERGY CENTER STG 5C		SANDHSYD_SH_5C	TRAVIS	GAS	SOUTH	2004	145.0
175 SILAS RAY POWER CTG 6		SILASRAY_SILAS_6	CAMERON	GAS	COASTAL	1962	20.0
176 SILAS RAY POWER CTG 9		SILASRAY_SILAS_9	CAMERON	GAS	COASTAL	1996	38.0
177 T H WHARTON POWER CTG 31		THW_THWGT31	HARRIS	GAS	HOUSTON	1972	57.0
178 T H WHARTON POWER CTG 32		THW_THWGT32	HARRIS	GAS	HOUSTON	1972	57.0
179 T H WHARTON POWER CTG 33		THW_THWGT33	HARRIS	GAS	HOUSTON	1972	57.0
180 T H WHARTON POWER CTG 34		THW_THWGT34	HARRIS	GAS	HOUSTON	1972	57.0
181 T H WHARTON POWER STG 3		THW_THWST_3	HARRIS	GAS	HOUSTON	1974	104.0
182 T H WHARTON POWER CTG 41		THW_THWGT41	HARRIS	GAS	HOUSTON	1972	57.0
183 T H WHARTON POWER CTG 42		THW_THWGT42	HARRIS	GAS	HOUSTON	1972	57.0
184 T H WHARTON POWER CTG 43		THW_THWGT43	HARRIS	GAS	HOUSTON	1974	57.0
185 T H WHARTON POWER CTG 44		THW_THWGT44	HARRIS	GAS	HOUSTON	1974	57.0
186 T H WHARTON POWER STG 4		THW_THWST_4	HARRIS	GAS	HOUSTON	1974	104.0
187 TEXAS CITY POWER CTG A		TXCTY_CTA	GALVESTON	GAS	HOUSTON	2000	96.6
188 TEXAS CITY POWER CTG B		TXCTY_CTB	GALVESTON	GAS	HOUSTON	2000	96.6
189 TEXAS CITY POWER CTG C		TXCTY_CTC	GALVESTON	GAS	HOUSTON	2000	96.6

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
190 TEXAS CITY POWER STG		TXCTY_ST	GALVESTON	GAS	HOUSTON	2000	131.6
191 VICTORIA POWER CTG 6		VICTORIA_VICTORG6	VICTORIA	GAS	SOUTH	2009	160.0
192 VICTORIA POWER STG 5		VICTORIA_VICTORG5	VICTORIA	GAS	SOUTH	1963	125.0
193 WICHITA FALLS CTG 1		WFCOGEN_UNIT1	WICHITA	GAS	WEST	1987	20.0
194 WICHITA FALLS CTG 2		WFCOGEN_UNIT2	WICHITA	GAS	WEST	1987	20.0
195 WICHITA FALLS CTG 3		WFCOGEN_UNIT3	WICHITA	GAS	WEST	1987	20.0
196 WICHITA FALLS STG 4		WFCOGEN_UNIT4	WICHITA	GAS	WEST	1987	17.0
197 WISE-TRACTEBEL POWER CTG 1		WCPP_CT1	WISE	GAS	NORTH	2004	212.0
198 WISE-TRACTEBEL POWER CTG 2		WCPP_CT2	WISE	GAS	NORTH	2004	212.0
199 WISE-TRACTEBEL POWER STG 1		WCPP_ST1	WISE	GAS	NORTH	2004	241.0
200 WOLF HOLLOW POWER CTG 1		WHCCS_CT1	HOOD	GAS	NORTH	2002	212.5
201 WOLF HOLLOW POWER CTG 2		WHCCS_CT2	HOOD	GAS	NORTH	2002	212.5
202 WOLF HOLLOW POWER STG		WHCCS_STG	HOOD	GAS	NORTH	2002	280.0
203 ATKINS CTG 7		ATKINS_ATKINSG7	BRAZOS	GAS	NORTH	1973	18.0
204 DANSBY CTG 2		DANSBY_DANSBYG2	BRAZOS	GAS	NORTH	2004	45.0
205 DANSBY CTG 3		DANSBY_DANSBYG3	BRAZOS	GAS	NORTH	2010	47.0
206 DECKER CREEK CTG 1		DECKER_DPGT_1	TRAVIS	GAS	SOUTH	1989	48.0
207 DECKER CREEK CTG 2		DECKER_DPGT_2	TRAVIS	GAS	SOUTH	1989	48.0
208 DECKER CREEK CTG 3		DECKER_DPGT_3	TRAVIS	GAS	SOUTH	1989	48.0
209 DECKER CREEK CTG 4		DECKER_DPGT_4	TRAVIS	GAS	SOUTH	1989	48.0
210 DECORDOVA CTG 1		DCSES_CT10	HOOD	GAS	NORTH	1990	71.0
211 DECORDOVA CTG 2		DCSES_CT20	HOOD	GAS	NORTH	1990	70.0
212 DECORDOVA CTG 3		DCSES_CT30	HOOD	GAS	NORTH	1990	69.0
213 DECORDOVA CTG 4		DCSES_CT40	HOOD	GAS	NORTH	1990	68.0
214 ECTOR COUNTY ENERGY CTG 1		ECEC_G1	ECTOR	GAS	WEST	2015	147.0
215 ECTOR COUNTY ENERGY CTG 2		ECEC_G2	ECTOR	GAS	WEST	2015	147.0
216 EXTEX LAPORTE GEN STN CTG 1		AZ_AZ_G1	HARRIS	GAS	HOUSTON	2009	38.0
217 EXTEX LAPORTE GEN STN CTG 2		AZ_AZ_G2	HARRIS	GAS	HOUSTON	2009	38.0
218 EXTEX LAPORTE GEN STN CTG 3		AZ_AZ_G3	HARRIS	GAS	HOUSTON	2009	38.0
219 EXTEX LAPORTE GEN STN CTG 4		AZ_AZ_G4	HARRIS	GAS	HOUSTON	2009	38.0
220 GREENS BAYOU CTG 73		GBY_GBYGT73	HARRIS	GAS	HOUSTON	1976	46.0
221 GREENS BAYOU CTG 74		GBY_GBYGT74	HARRIS	GAS	HOUSTON	1976	46.0
222 GREENS BAYOU CTG 81		GBY_GBYGT81	HARRIS	GAS	HOUSTON	1976	46.0
223 GREENS BAYOU CTG 82		GBY_GBYGT82	HARRIS	GAS	HOUSTON	1976	58.0
224 GREENS BAYOU CTG 83		GBY_GBYGT83	HARRIS	GAS	HOUSTON	1976	56.0
225 GREENS BAYOU CTG 84		GBY_GBYGT84	HARRIS	GAS	HOUSTON	1976	46.0
226 GREENVILLE IC ENGINE PLANT		STEAM_ENGINE_1	HUNT	GAS	NORTH	2010	8.4
227 GREENVILLE IC ENGINE PLANT		STEAM_ENGINE_2	HUNT	GAS	NORTH	2010	8.4
228 GREENVILLE IC ENGINE PLANT		STEAM_ENGINE_3	HUNT	GAS	NORTH	2010	8.4
229 LAREDO CTG 4		LARDVFTN_G4	WEBB	GAS	SOUTH	2008	90.1
230 LAREDO CTG 5		LARDVFTN_G5	WEBB	GAS	SOUTH	2008	87.3
231 LEON CREEK PEAKER CTG 1		LEON_CRK_LCPCT1	BEXAR	GAS	SOUTH	2004	45.0
232 LEON CREEK PEAKER CTG 2		LEON_CRK_LCPCT2	BEXAR	GAS	SOUTH	2004	46.0
233 LEON CREEK PEAKER CTG 3		LEON_CRK_LCPCT3	BEXAR	GAS	SOUTH	2004	44.0
234 LEON CREEK PEAKER CTG 4		LEON_CRK_LCPCT4	BEXAR	GAS	SOUTH	2004	46.0
235 MORGAN CREEK CTG 1		MGSES_CT1	MITCHELL	GAS	WEST	1988	68.0
236 MORGAN CREEK CTG 2		MGSES_CT2	MITCHELL	GAS	WEST	1988	68.0
237 MORGAN CREEK CTG 3		MGSES_CT3	MITCHELL	GAS	WEST	1988	68.0
238 MORGAN CREEK CTG 4		MGSES_CT4	MITCHELL	GAS	WEST	1988	68.0
239 MORGAN CREEK CTG 5		MGSES_CT5	MITCHELL	GAS	WEST	1988	68.0
240 MORGAN CREEK CTG 6		MGSES_CT6	MITCHELL	GAS	WEST	1988	67.0
241 PEARSALL IC ENGINE PLANT A		PEARSAL2_AGR_A	FRIOS	GAS	SOUTH	2012	50.6
242 PEARSALL IC ENGINE PLANT B		PEARSAL2_AGR_B	FRIOS	GAS	SOUTH	2012	50.6
243 PEARSALL IC ENGINE PLANT C		PEARSAL2_AGR_C	FRIOS	GAS	SOUTH	2012	50.6
244 PEARSALL IC ENGINE PLANT D		PEARSAL2_AGR_D	FRIOS	GAS	SOUTH	2012	50.6
245 PERMIAN BASIN CTG 1		PB2SES_CT1	WARD	GAS	WEST	1988	68.0
246 PERMIAN BASIN CTG 2		PB2SES_CT2	WARD	GAS	WEST	1988	65.0
247 PERMIAN BASIN CTG 3		PB2SES_CT3	WARD	GAS	WEST	1988	68.0
248 PERMIAN BASIN CTG 4		PB2SES_CT4	WARD	GAS	WEST	1990	69.0
249 PERMIAN BASIN CTG 5		PB2SES_CT5	WARD	GAS	WEST	1990	70.0
250 R W MILLER CTG 4		MIL_MILLERG4	PALO PINTO	GAS	NORTH	1994	104.0
251 R W MILLER CTG 5		MIL_MILLERG5	PALO PINTO	GAS	NORTH	1994	104.0
252 RAY OLINGER CTG 4		OLINGER_OLING_4	COLLIN	GAS	NORTH	2001	75.0
253 SAM RAYBURN CTG 1		RAYBURN_RAYBURG1	VICTORIA	GAS	SOUTH	1963	11.0
254 SAM RAYBURN CTG 2		RAYBURN_RAYBURG2	VICTORIA	GAS	SOUTH	1963	11.0
255 SAN JACINTO SES CTG 1		SJS_SJS_G1	HARRIS	GAS	HOUSTON	1995	81.0
256 SAN JACINTO SES CTG 2		SJS_SJS_G2	HARRIS	GAS	HOUSTON	1995	81.0
257 SANDHILL ENERGY CENTER CTG 1		SANDHSYD_SH1	TRAVIS	GAS	SOUTH	2001	47.0
258 SANDHILL ENERGY CENTER CTG 2		SANDHSYD_SH2	TRAVIS	GAS	SOUTH	2001	47.0
259 SANDHILL ENERGY CENTER CTG 3		SANDHSYD_SH3	TRAVIS	GAS	SOUTH	2001	47.0
260 SANDHILL ENERGY CENTER CTG 4		SANDHSYD_SH4	TRAVIS	GAS	SOUTH	2001	47.0
261 SANDHILL ENERGY CENTER CTG 6		SANDHSYD_SH6	TRAVIS	GAS	SOUTH	2010	47.0
262 SANDHILL ENERGY CENTER CTG 7		SANDHSYD_SH7	TRAVIS	GAS	SOUTH	2010	47.0
263 SILAS RAY CTG 10		SILASRAY_SILAS_10	CAMERON	GAS	COASTAL	2004	46.0
264 T H WHARTON CTG 51		THW_THWGT51	HARRIS	GAS	HOUSTON	1975	57.0
265 T H WHARTON CTG 52		THW_THWGT52	HARRIS	GAS	HOUSTON	1975	57.0
266 T H WHARTON CTG 53		THW_THWGT53	HARRIS	GAS	HOUSTON	1975	57.0
267 T H WHARTON CTG 54		THW_THWGT54	HARRIS	GAS	HOUSTON	1975	57.0
268 T H WHARTON CTG 55		THW_THWGT55	HARRIS	GAS	HOUSTON	1975	57.0
269 T H WHARTON CTG 56		THW_THWGT56	HARRIS	GAS	HOUSTON	1975	57.0
270 T H WHARTON CTG G1		THW_THWGT_1	HARRIS	GAS	HOUSTON	1967	13.0
271 TEXAS GULF SULPHUR		TGF_TGFGT_1	WHARTON	GAS	SOUTH	1985	79.0
272 V H BRAUNIG CTG 5		BRAUNIG_VHB6CT5	BEXAR	GAS	SOUTH	2009	48.0
273 V H BRAUNIG CTG 6		BRAUNIG_VHB6CT6	BEXAR	GAS	SOUTH	2009	48.0
274 V H BRAUNIG CTG 7		BRAUNIG_VHB6CT7	BEXAR	GAS	SOUTH	2009	48.0
275 V H BRAUNIG CTG 8		BRAUNIG_VHB6CT8	BEXAR	GAS	SOUTH	2009	47.0
276 W A PARISH CTG 1		WAP_WAPGT_1	FT. BEND	GAS	HOUSTON	1967	13.0
277 WINCHESTER POWER PARK CTG 1		WIPOPA_WPP_G1	FAYETTE	GAS	SOUTH	2009	44.0
278 WINCHESTER POWER PARK CTG 2		WIPOPA_WPP_G2	FAYETTE	GAS	SOUTH	2009	44.0
279 WINCHESTER POWER PARK CTG 3		WIPOPA_WPP_G3	FAYETTE	GAS	SOUTH	2009	44.0
280 WINCHESTER POWER PARK CTG 4		WIPOPA_WPP_G4	FAYETTE	GAS	SOUTH	2009	44.0
281 B M DAVIS STG U1		B_DAVIS_B_DAVIG1	NUECES	GAS	COASTAL	1974	330.0
282 CEDAR BAYOU STG U1		CBY_CBY_G1	CHAMBERS	GAS	HOUSTON	1970	745.0
283 CEDAR BAYOU STG U2		CBY_CBY_G2	CHAMBERS	GAS	HOUSTON	1972	749.0
284 DANSBY STG U1		DANSBY_DANSBYG1	BRAZOS	GAS	NORTH	1978	107.0

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
285 DECKER CREEK STG U1		DECKER_DPG1	TRAVIS	GAS	SOUTH	1971	315.0
286 DECKER CREEK STG U2		DECKER_DPG2	TRAVIS	GAS	SOUTH	1978	420.0
287 GRAHAM STG U1		GRSES_UNIT1	YOUNG	GAS	WEST	1960	234.0
288 GRAHAM STG U2		GRSES_UNIT2	YOUNG	GAS	WEST	1969	390.0
289 GREENS BAYOU STG U5		GBY_GBY_5	HARRIS	GAS	HOUSTON	1973	371.0
290 HANDLEY STG U3		HLSES_UNIT3	TARRANT	GAS	NORTH	1963	395.0
291 HANDLEY STG U4		HLSES_UNIT4	TARRANT	GAS	NORTH	1976	435.0
292 HANDLEY STG U5		HLSES_UNIT5	TARRANT	GAS	NORTH	1977	435.0
293 LAKE HUBBARD STG U1		LHSES_UNIT1	DALLAS	GAS	NORTH	1970	392.0
294 LAKE HUBBARD STG U2		LHSES_UNIT2A	DALLAS	GAS	NORTH	1973	523.0
295 MOUNTAIN CREEK STG U6		MCSSES_UNIT6	DALLAS	GAS	NORTH	1956	122.0
296 MOUNTAIN CREEK STG U7		MCSSES_UNIT7	DALLAS	GAS	NORTH	1958	118.0
297 MOUNTAIN CREEK STG U8		MCSSES_UNIT8	DALLAS	GAS	NORTH	1967	568.0
298 O W SOMMERS STG U1		CALAVERS_OWS1	BEXAR	GAS	SOUTH	1972	420.0
299 O W SOMMERS STG U2		CALAVERS_OWS2	BEXAR	GAS	SOUTH	1974	410.0
300 PEARSALL STG U1		PEARSALL_PEARLS_1	FRIO	GAS	SOUTH	1961	19.0
301 PEARSALL STG U2		PEARSALL_PEARLS_2	FRIO	GAS	SOUTH	1961	22.0
302 PEARSALL STG U3		PEARSALL_PEARLS_3	FRIO	GAS	SOUTH	1961	20.0
303 POWERLANE PLANT STG U1		STEAM1A_STEAM_1	HUNT	GAS	NORTH	1966	20.0
304 POWERLANE PLANT STG U2		STEAM_STEAM_2	HUNT	GAS	NORTH	1967	26.0
305 POWERLANE PLANT STG U3		STEAM_STEAM_3	HUNT	GAS	NORTH	1978	41.0
306 R W MILLER STG U1		MIL_MILLERG1	PALO PINTO	GAS	NORTH	1968	75.0
307 R W MILLER STG U2		MIL_MILLERG2	PALO PINTO	GAS	NORTH	1972	120.0
308 R W MILLER STG U3		MIL_MILLERG3	PALO PINTO	GAS	NORTH	1975	208.0
309 RAY OLINGER STG U1		OLINGER_OLING_1	COLLIN	GAS	NORTH	1967	78.0
310 RAY OLINGER STG U2		OLINGER_OLING_2	COLLIN	GAS	NORTH	1971	107.0
311 RAY OLINGER STG U3		OLINGER_OLING_3	COLLIN	GAS	NORTH	1975	146.0
312 SIM GIDEON STG U1		GIDEON_GIDEONG1	BASTROP	GAS	SOUTH	1965	130.0
313 SIM GIDEON STG U2		GIDEON_GIDEONG2	BASTROP	GAS	SOUTH	1968	135.0
314 SIM GIDEON STG U3		GIDEON_GIDEONG3	BASTROP	GAS	SOUTH	1972	336.0
315 SPENCER STG U4		SPNCER_SPNCE_4	DENTON	GAS	NORTH	1966	61.0
316 SPENCER STG U5		SPNCER_SPNCE_5	DENTON	GAS	NORTH	1973	61.0
317 STRYKER CREEK STG U1		SCSES_UNIT1A	CHEROKEE	GAS	NORTH	1958	167.0
318 STRYKER CREEK STG U2		SCSES_UNIT2	CHEROKEE	GAS	NORTH	1965	502.0
319 TRINIDAD STG U6		TRSES_UNIT6	HENDERSON	GAS	NORTH	1965	235.0
320 V H BRAUNIG STG U1		BRAUNIG_VHB1	BEXAR	GAS	SOUTH	1966	220.0
321 V H BRAUNIG STG U2		BRAUNIG_VHB2	BEXAR	GAS	SOUTH	1968	230.0
322 V H BRAUNIG STG U3		BRAUNIG_VHB3	BEXAR	GAS	SOUTH	1970	412.0
323 W A PARISH STG U1		WAP_WAP_G1	FT. BEND	GAS	HOUSTON	1958	169.0
324 W A PARISH STG U2		WAP_WAP_G2	FT. BEND	GAS	HOUSTON	1958	169.0
325 W A PARISH STG U3		WAP_WAP_G3	FT. BEND	GAS	HOUSTON	1961	246.0
326 W A PARISH STG U4		WAP_WAP_G4	FT. BEND	GAS	HOUSTON	1968	536.0
327 NACOGDOCHES POWER		NACPW_UNIT1	NACOGDOCHES	BIO MASS	NORTH	2012	105.0
328 LUFKIN BIOMASS		LFBIO_UNIT1	ANGELINA	BIO MASS	NORTH	2012	45.0
329 BIOENERGY AUSTIN WALZEM RD LGF		DG_WALZE_4UNITS	BEXAR	BIO MASS	SOUTH	2002	9.8
330 BIOENERGY TEXAS COVEL GARDENS LGF		DG_MEDIN_1UNIT	BEXAR	BIO MASS	SOUTH	2005	9.6
331 FORT WORTH METHANE LGF		DG_RDLML_1UNIT	TARRANT	BIO MASS	NORTH	2011	1.6
332 GRAND PRAIRIE LGF		DG_TRIRA_1UNIT	DALLAS	BIO MASS	NORTH	2015	4.0
333 MCKINNEY LGF		DG_MKNSW_2UNITS	COLLIN	BIO MASS	NORTH	2011	3.2
334 NELSON GARDENS LGF		DG_78252_4UNITS	BEXAR	BIO MASS	SOUTH	2013	4.2
335 SKYLINE LGF		DG_FERIS_4 UNITS	DALLAS	BIO MASS	NORTH	2007	6.4
336 TRINITY OAKS LGF		DG_KLBRG_1UNIT	DALLAS	BIO MASS	NORTH	2011	3.2
337 VIRIDIS ENERGY-ALVIN LGF		DG_AV_DG1	GALVESTON	BIO MASS	HOUSTON	2002	6.7
338 VIRIDIS ENERGY-HUMBLE LGF		DG_HB_DG1	HARRIS	BIO MASS	HOUSTON	2002	10.0
339 VIRIDIS ENERGY-LIBERTY LGF		DG_LB_DG1	HARRIS	BIO MASS	HOUSTON	2002	3.9
340 VIRIDIS ENERGY-TRINITY BAY LGF		DG_TRN_DG1	CHAMBERS	BIO MASS	HOUSTON	2002	3.9
341 WM RENEWABLE-AUSTIN LGF		DG_SPRIN_4UNITS	TRAVIS	BIO MASS	SOUTH	2007	6.4
342 WM RENEWABLE-DFW GAS RECOVERY LGF		DG_BIO2_4UNITS	DENTON	BIO MASS	NORTH	2009	6.4
343 WM RENEWABLE-BIOENERGY PARTNERS LGF		DG_BIOE_2UNITS	DENTON	BIO MASS	NORTH	1988	6.2
344 WM RENEWABLE-MESQUITE CREEK LGF		DG_FREIH_2UNITS	COMAL	BIO MASS	SOUTH	2011	3.2
345 WM RENEWABLE-WESTSIDE LGF		DG_WSTHL_3UNITS	PARKER	BIO MASS	NORTH	2010	4.8
346 NOTREES BATTERY FACILITY		NWF_NBS	WINKLER	STORAGE	WEST	2012	0.0
347 Operational Capacity Total (Nuclear, Coal, Gas, Biomass)							66070.2
348							
349 Operational Resources (Hydro)							
350 AMISTAD HYDRO 1		AMISTAD_AMISTAG1	VAL VERDE	HYDRO	WEST	1983	37.9
351 AMISTAD HYDRO 2		AMISTAD_AMISTAG2	VAL VERDE	HYDRO	WEST	1983	37.9
352 AUSTIN HYDRO 1		AUSTPL_AUSTING1	TRAVIS	HYDRO	SOUTH	1940	8.0
353 AUSTIN HYDRO 2		AUSTPL_AUSTING2	TRAVIS	HYDRO	SOUTH	1940	9.0
354 BUCHANAN HYDRO 1		BUCHAN_BUCHANG1	LLANO	HYDRO	SOUTH	1938	16.0
355 BUCHANAN HYDRO 2		BUCHAN_BUCHANG2	LLANO	HYDRO	SOUTH	1938	16.0
356 BUCHANAN HYDRO 3		BUCHAN_BUCHANG3	LLANO	HYDRO	SOUTH	1950	17.0
357 DENISON DAM 1		DNDAM_DENISOG1	GRAYSON	HYDRO	NORTH	1944	40.0
358 DENISON DAM 2		DNDAM_DENISOG2	GRAYSON	HYDRO	NORTH	1948	40.0
359 FALCON HYDRO 1		FALCON_FALCONG1	STARR	HYDRO	SOUTH	1954	12.0
360 FALCON HYDRO 2		FALCON_FALCONG2	STARR	HYDRO	SOUTH	1954	12.0
361 FALCON HYDRO 3		FALCON_FALCONG3	STARR	HYDRO	SOUTH	1954	12.0
362 GRANITE SHOALS HYDRO 1		WIRTZ_WIRTZ_G1	BURNET	HYDRO	SOUTH	1951	29.0
363 GRANITE SHOALS HYDRO 2		WIRTZ_WIRTZ_G2	BURNET	HYDRO	SOUTH	1951	29.0
364 INKS HYDRO 1		INKSDA_INKS_G1	LLANO	HYDRO	SOUTH	1938	14.0
365 MARBLE FALLS HYDRO 1		MARBFQA_MARBFGA1	BURNET	HYDRO	SOUTH	1951	21.0
366 MARBLE FALLS HYDRO 2		MARBFQA_MARBFGA2	BURNET	HYDRO	SOUTH	1951	20.0
367 MARSHALL FORD HYDRO 1		MARSFO_MARSFOG1	TRAVIS	HYDRO	SOUTH	1941	36.0
368 MARSHALL FORD HYDRO 2		MARSFO_MARSFOG2	TRAVIS	HYDRO	SOUTH	1941	36.0
369 MARSHALL FORD HYDRO 3		MARSFO_MARSFOG3	TRAVIS	HYDRO	SOUTH	1941	29.0
370 WHITNEY DAM HYDRO		WND_WHITNEY1	BOSQUE	HYDRO	NORTH	1953	24.0
371 WHITNEY DAM HYDRO 2		WND_WHITNEY2	BOSQUE	HYDRO	NORTH	1953	24.0
372 ARLINGTON OUTLET HYDROELECTRIC FACILITY		DG_OAKHL_1UNIT	TARRANT	HYDRO	NORTH	2014	1.4
373 EAGLE PASS HYDRO		DG_EAGLE_HY_EAGLE_HY1	MAVERICK	HYDRO	SOUTH	2005	9.6
374 GUADALUPE BLANCO RIVER AUTH-CANYON		DG_CANYHY_CANYHY1	COMAL	HYDRO	SOUTH	1989	6.0
375 GUADALUPE BLANCO RIVER AUTH-LAKEWOOD TAP		DG_LKWDT_2UNITS	GONZALES	HYDRO	SOUTH	2031	4.8
376 GUADALUPE BLANCO RIVER AUTH-MCQUEENEY		DG_MCQUE_5UNITS	GUADALUPE	HYDRO	SOUTH	2028	7.7
377 GUADALUPE BLANCO RIVER AUTH-SCHUMANSVILLE		DG_SCHUM_2UNITS	GUADALUPE	HYDRO	SOUTH	2028	3.6
378 LEWISVILLE HYDRO-CITY OF GARLAND		DG_LWSVL_1UNIT	DENTON	HYDRO	NORTH	1991	2.2
379 Operational Capacity Total (Hydro)							555.1

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE HYDRO_CAP_CONT	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
380 Hydro Capacity Contribution (Top 20 Hours)							437.2
381							
382 Operational Capacity Unavailable due to Extended Outage or Derate		OPERATION_UNAVAIL					-193.0
383 Operational Capacity Total (Including Hydro)		OPERATION_TOTAL					66314.4
384							
385 <b>Operational Resources (Switchable)</b>							
386 TENASKA KIAMICHI STATION 1CT101		KMCHL_1CT101	FANNIN	GAS	NORTH	2003	153.0
387 TENASKA KIAMICHI STATION 1CT201		KMCHL_1CT201	FANNIN	GAS	NORTH	2003	155.0
388 TENASKA KIAMICHI STATION 1ST		KMCHL_1ST	FANNIN	GAS	NORTH	2003	315.0
389 TENASKA KIAMICHI STATION 2CT101		KMCHL_2CT101	FANNIN	GAS	NORTH	2003	153.0
390 TENASKA KIAMICHI STATION 2CT201		KMCHL_2CT201	FANNIN	GAS	NORTH	2003	155.0
391 TENASKA KIAMICHI STATION 2ST		KMCHL_2ST	FANNIN	GAS	NORTH	2003	315.0
392 TENASKA FRONTIER STATION CTG 1		FTR_FTR_G1	GRIMES	GAS	NORTH	2000	160.0
393 TENASKA FRONTIER STATION CTG 2		FTR_FTR_G2	GRIMES	GAS	NORTH	2000	160.0
394 TENASKA FRONTIER STATION CTG 3		FTR_FTR_G3	GRIMES	GAS	NORTH	2000	160.0
395 TENASKA FRONTIER STATION STG 4		FTR_FTR_G4	GRIMES	GAS	NORTH	2000	400.0
396 TENASKA GATEWAY STATION CTG 1		TGCCS_CT1	RUSK	GAS	NORTH	2001	156.0
397 TENASKA GATEWAY STATION CTG 2		TGCCS_CT2	RUSK	GAS	NORTH	2001	135.0
398 TENASKA GATEWAY STATION CTG 3		TGCCS_CT3	RUSK	GAS	NORTH	2001	153.0
399 TENASKA GATEWAY STATION STG 4		TGCCS_UNIT4	RUSK	GAS	NORTH	2001	402.0
400 FRONTERA GENERATION CTG 1		FRONTERA_FRONTEG1	HIDALGO	GAS	SOUTH	1999	170.0
401 FRONTERA GENERATION CTG 2		FRONTERA_FRONTEG2	HIDALGO	GAS	SOUTH	1999	170.0
402 FRONTERA GENERATION STG		FRONTERA_FRONTEG3	HIDALGO	GAS	SOUTH	2000	184.0
403 <b>Switchable Capacity Total</b>							3496.0
404							
405 Switchable Capacity Unavailable to ERCOT		SWITCH_UNAVAIL		GAS			(300.0)
406							
407 Available Mothball Capacity based on Seasonal Schedule or Return Probability		MOTH_AVAIL		COAL			805.0
408							
409 Private-Use Network Capacity Contribution (Top 20 Hours)		PUN_CAP_CONT		GAS			4258.0
410 Private-Use Network Forecast Adjustment (per Protocol 10.3.2.4)							26.0
411							
412 <b>Operational Resources (Wind)</b>							
413 ANACACHO WIND		ANACACHO_ANA	KINNEY	WIND	SOUTH	2012	99.8
414 BARTON CHAPEL WIND		BRTSW_BCW1	JACK	WIND	NORTH	2007	120.0
415 BLUE SUMMIT WIND 5		BLSUMMIT_BLSMT1_5	WILBARGER	WIND	WEST	2013	9.0
416 BLUE SUMMIT WIND 6		BLSUMMIT_BLSMT1_6	WILBARGER	WIND	WEST	2013	126.4
417 BOBCAT BLUFF WIND		BCATWIND_WIND_1	ARCHER	WIND	WEST	2012	150.0
418 BRISCOE WIND		BRISCOE_WIND	BRISCOE	WIND	PANHANDLE	2015	149.8
419 BUFFALO GAP WIND 1		BUFF_GAP_UNIT1	TAYLOR	WIND	WEST	2006	120.6
420 BUFFALO GAP WIND 2_1		BUFF_GAP_UNIT2_1	TAYLOR	WIND	WEST	2007	115.5
421 BUFFALO GAP WIND 2_2		BUFF_GAP_UNIT2_2	TAYLOR	WIND	WEST	2007	117.0
422 BUFFALO GAP WIND 3		BUFF_GAP_UNIT3	TAYLOR	WIND	WEST	2008	170.2
423 BULL CREEK WIND U1		BULLCRK_WND1	BORDEN	WIND	WEST	2009	88.0
424 BULL CREEK WIND U2		BULLCRK_WND2	BORDEN	WIND	WEST	2009	90.0
425 CALLAHAN WIND		CALLAHAN_WND1	CALLAHAN	WIND	WEST	2004	114.0
426 CAMP SPRINGS WIND 1		CSEC_CSECG1	SCURRY	WIND	WEST	2007	130.5
427 CAMP SPRINGS WIND 2		CSEC_CSECG2	SCURRY	WIND	WEST	2007	120.0
428 CAPRICORN RIDGE WIND 1		CAPRIDGE_CR1	STERLING	WIND	WEST	2007	214.5
429 CAPRICORN RIDGE WIND 2		CAPRIDGE_CR3	STERLING	WIND	WEST	2008	186.0
430 CAPRICORN RIDGE WIND 3		CAPRIDGE_CR2	STERLING	WIND	WEST	2007	149.5
431 CAPRICORN RIDGE WIND 4		CAPRIDGE_CR4	COKE	WIND	WEST	2008	112.5
432 CEDRO HILL WIND 1		CEDROHIL_CHW1	WEBB	WIND	SOUTH	2010	75.0
433 CEDRO HILL WIND 2		CEDROHIL_CHW2	WEBB	WIND	SOUTH	2010	75.0
434 CHAMPION WIND		CHAMPION_UNIT1	NOLAN	WIND	WEST	2008	126.5
435 DESERT SKY WIND 1		INDNENR_INDNENR	PECOS	WIND	WEST	2002	84.0
436 DESERT SKY WIND 2		INDNENR_INDNENR_2	PECOS	WIND	WEST	2002	76.5
437 ELBOW CREEK WIND		ELB_ELCREEK	HOWARD	WIND	WEST	2008	118.7
438 FOREST CREEK WIND		MCDDL_FCW1	GLASSCOCK	WIND	WEST	2007	124.2
439 GOAT WIND		GOAT_GOATWIND	STERLING	WIND	WEST	2008	80.0
440 GOAT WIND 2		GOAT_GOATWIN2	STERLING	WIND	WEST	2010	69.6
441 GOLDTHWAITE WIND 1		GWEC_GWECA1	MILLS	WIND	NORTH	2014	148.6
442 GRANDVIEW WIND 1 (CONWAY) GV1A		GRANDVW1_GV1A	CARSON	WIND	PANHANDLE	2014	107.4
443 GRANDVIEW WIND 1 (CONWAY) GV1B		GRANDVW1_GV1B	CARSON	WIND	PANHANDLE	2014	103.8
444 GREEN MOUNTAIN WIND (BRAZOS) U1		BRAZ_WND_WND1	SCURRY	WIND	WEST	2003	99.0
445 GREEN MOUNTAIN WIND (BRAZOS) U2		BRAZ_WND_WND2	SCURRY	WIND	WEST	2003	61.0
446 GREEN PASTURES WIND I		GPASTURE_WIND_I	BAYLOR	WIND	WEST	2015	150.0
447 GREEN PASTURES WIND 2		GPASTURE_WIND_II	BAYLOR	WIND	WEST	2015	150.0
448 HACKBERRY WIND		HWF_HWF1	SHACKELFORD	WIND	WEST	2008	163.5
449 HEREFORD WIND G		HRFDWIND_WIND_G	DEAF SMITH	WIND	PANHANDLE	2015	99.9
450 HEREFORD WIND V		HRFDWIND_WIND_V	DEAF SMITH	WIND	PANHANDLE	2015	100.0
451 HORSE HOLLOW WIND 1		H_HOLLOW_WND1	TAYLOR	WIND	WEST	2005	206.6
452 HORSE HOLLOW WIND 2		HHOLLOW2_WIND1	TAYLOR	WIND	WEST	2006	158.0
453 HORSE HOLLOW WIND 3		HHOLLOW3_WND_1	TAYLOR	WIND	WEST	2006	208.0
454 HORSE HOLLOW WIND 4		HHOLLOW4_WND1	TAYLOR	WIND	WEST	2006	108.0
455 INADALE WIND		INDL_INADALE1	NOLAN	WIND	WEST	2008	196.6
456 INDIAN MESA WIND		INDNNWP_INDNNWP	PECOS	WIND	WEST	2001	82.5
457 JAVELINA WIND 18		BORDAS_JAVEL18	WEBB	WIND	SOUTH	2015	19.7
458 JAVELINA WIND 20		BORDAS_JAVEL20	WEBB	WIND	SOUTH	2015	230.0
459 JUMBO ROAD WIND 1		HRFDWIND_JRDWIND1	DEAF SMITH	WIND	PANHANDLE	2015	146.2
460 JUMBO ROAD WIND 2		HRFDWIND_JRDWIND2	DEAF SMITH	WIND	PANHANDLE	2015	153.6
461 KEECHI WIND 138 KV JOPLIN		KEECHI_U1	JACK	WIND	NORTH	2015	110.0
462 KING MOUNTAIN WIND (NE)		KING_NE_KINGNE	UPTON	WIND	WEST	2001	79.3
463 KING MOUNTAIN WIND (NW)		KING_NW_KINGNW	UPTON	WIND	WEST	2001	79.3
464 KING MOUNTAIN WIND (SE)		KING_SE_KINGSE	UPTON	WIND	WEST	2001	40.3
465 KING MOUNTAIN WIND (SW)		KING_SW_KINGSW	UPTON	WIND	WEST	2001	79.3
466 LANGFORD WIND POWER		LGD_LANGFORD	TOM GREEN	WIND	WEST	2009	155.0
467 LOGANS GAP WIND I U1		LGW_UNIT1	COMANCHE	WIND	NORTH	2015	103.8
468 LOGANS GAP WIND I U2		LGW_UNIT2	COMANCHE	WIND	NORTH	2015	106.3
469 LONE STAR WIND 1 (MESQUITE)		LNCRK_G83	SHACKELFORD	WIND	WEST	2006	200.0
470 LONE STAR WIND 2 (POST OAK) U1		LNCRK2_G871	SHACKELFORD	WIND	WEST	2007	100.0
471 LONE STAR WIND 2 (POST OAK) U2		LNCRK2_G872	SHACKELFORD	WIND	WEST	2007	100.0
472 LONGHORN WIND NORTH U1		LHORN_N_UNIT1	FLOYD	WIND	PANHANDLE	2015	100.0
473 LONGHORN WIND NORTH U2		LHORN_N_UNIT2	FLOYD	WIND	PANHANDLE	2015	100.0
474 LORAIN WINDPARK I		LONEWOLF_G1	MITCHELL	WIND	WEST	2009	49.5

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
475 LORAIN WINDPARK II		LONEWOLF_G2	MITCHELL	WIND	WEST	2009	51.0
476 LORAIN WINDPARK III		LONEWOLF_G3	MITCHELL	WIND	WEST	2011	25.5
477 LORAIN WINDPARK IV		LONEWOLF_G4	MITCHELL	WIND	WEST	2011	24.0
478 LOS VIENTOS III WIND		LV3_UNIT_1	STARR	WIND	SOUTH	2015	200.0
479 MESQUITE CREEK WIND 1		MESQCRK_WND1	DAWSON	WIND	WEST	2015	105.6
480 MESQUITE CREEK WIND 2		MESQCRK_WND2	DAWSON	WIND	WEST	2015	105.6
481 MIAMI WIND G1		MIAM1_G1	GRAY	WIND	PANHANDLE	2014	144.3
482 MIAMI WIND G2		MIAM1_G2	GRAY	WIND	PANHANDLE	2014	144.3
483 MCADOO WIND		MWEC_G1	DICKENS	WIND	PANHANDLE	2008	150.0
484 NOTREES WIND 1		NWF_NWF1	WINKLER	WIND	WEST	2009	92.6
485 NOTREES WIND 2		NWF_NWF2	WINKLER	WIND	WEST	2009	60.0
486 OCOTILLO WIND		OWF_OWF	HOWARD	WIND	WEST	2008	58.8
487 PANHANDLE WIND 1 U1		PH1_UNIT1	CARSON	WIND	PANHANDLE	2014	109.2
488 PANHANDLE WIND 1 U2		PH1_UNIT2	CARSON	WIND	PANHANDLE	2014	109.2
489 PANHANDLE WIND 2 U1		PH2_UNIT1	CARSON	WIND	PANHANDLE	2014	94.2
490 PANHANDLE WIND 2 U2		PH2_UNIT2	CARSON	WIND	PANHANDLE	2014	96.6
491 PANTHER CREEK WIND 1		PC_NORTH_PANTHER1	HOWARD	WIND	WEST	2008	142.5
492 PANTHER CREEK WIND 2		PC_SOUTH_PANTHER2	HOWARD	WIND	WEST	2008	115.5
493 PANTHER CREEK WIND 3		PC_SOUTH_PANTHER3	HOWARD	WIND	WEST	2009	199.5
494 PECOS WIND 1 (WOODWARD)		WOODWRD1_WOODWRD1	PECOS	WIND	WEST	2001	82.5
495 PECOS WIND 2 (WOODWARD)		WOODWRD2_WOODWRD2	PECOS	WIND	WEST	2001	77.2
496 PYRON WIND		PYR_PYRON1	SCURRY	WIND	WEST	2008	249.0
497 RATTLESNAKE DEN WIND PHASE 1 G1		RSNAKE_G1	GLASSCOCK	WIND	WEST	2015	104.3
498 RATTLESNAKE DEN WIND PHASE 1 G2		RSNAKE_G2	GLASSCOCK	WIND	WEST	2015	103.0
499 RED CANYON WIND		RDCANYON_RDCNY1	BORDEN	WIND	WEST	2006	84.0
500 ROSCOE WIND		TKWSW1_ROSCOE	NOLAN	WIND	WEST	2008	209.0
501 ROUTE 66 WIND		ROUTE_66_WIND1	CARSON	WIND	PANHANDLE	2015	150.0
502 SAND BLUFF WIND		MCDLD_SWB1	GLASSCOCK	WIND	WEST	2008	90.0
503 SENDERO WIND ENERGY		EXGNSND_WIND_1	JIM HOGG	WIND	SOUTH	2015	76.0
504 SENATE WIND		SENATEWD_UNIT1	JACK	WIND	NORTH	2012	150.0
505 SHANNON WIND		SHANNONW_UNIT_1	CLAY	WIND	WEST	2015	204.1
506 SHERBINO 1 WIND		KEO_KEO_SM1	PECOS	WIND	WEST	2008	150.0
507 SHERBINO 2 WIND		KEO_SHRBINO2	PECOS	WIND	WEST	2011	147.5
508 SILVER STAR WIND		FLTCKLSSI	EASTLAND	WIND	NORTH	2008	60.0
509 SNYDER WIND		ENAS_ENA1	SCURRY	WIND	WEST	2007	63.0
510 SOUTH PLAINS WIND I		SPLAIN1_WIND1	FLOYD	WIND	WEST	2015	102.0
511 SOUTH PLAINS WIND 2		SPLAIN1_WIND2	FLOYD	WIND	WEST	2015	98.0
512 SOUTH TRENT WIND		STWF_T1	NOLAN	WIND	WEST	2008	98.2
513 SPINNING SPUR WIND TWO		SSPURTWO_WIND_1	OLDHAM	WIND	PANHANDLE	2014	161.0
514 SPINNING SPUR 3 [WIND 1]		SSPURTWO_SS3WIND1	OLDHAM	WIND	PANHANDLE	2015	96.0
515 SPINNING SPUR 3 [WIND 2]		SSPURTWO_SS3WIND2	OLDHAM	WIND	PANHANDLE	2015	98.0
516 STANTON WIND ENERGY		SWEC_G1	MARTIN	WIND	WEST	2008	120.0
517 STEPHENS RANCH WIND 1		SRWE1_UNIT1	BORDEN	WIND	WEST	2014	211.2
518 STEPHENS RANCH WIND 2		SRWE1_SRWE2	BORDEN	WIND	WEST	2015	164.7
519 SWEETWATER WIND 1		SWEETWND_WND1	NOLAN	WIND	WEST	2003	36.6
520 SWEETWATER WIND 2A		SWEETWN2_WND24	NOLAN	WIND	WEST	2006	15.9
521 SWEETWATER WIND 2B		SWEETWN2_WND2	NOLAN	WIND	WEST	2004	97.5
522 SWEETWATER WIND 3A		SWEETWN3_WND3A	NOLAN	WIND	WEST	2011	28.5
523 SWEETWATER WIND 3B		SWEETWN3_WND3B	NOLAN	WIND	WEST	2011	100.5
524 SWEETWATER WIND 4-5		SWEETWN4_WND5	NOLAN	WIND	WEST	2007	79.2
525 SWEETWATER WIND 4-4B		SWEETWN4_WND4B	NOLAN	WIND	WEST	2007	103.7
526 SWEETWATER WIND 4-4A		SWEETWN4_WND4A	NOLAN	WIND	WEST	2007	117.8
527 TEXAS BIG SPRING WIND a		SGMTN_SIGNALMT	HOWARD	WIND	WEST	1999	27.7
528 TEXAS BIG SPRING WIND b		SGMTN_SIGNALM2	HOWARD	WIND	WEST	1999	6.6
529 TRENT WIND		TRENT_TRENT	NOLAN	WIND	WEST	2001	150.0
530 TRINITY HILLS WIND 1		TRINITY_TH1_BUS1	YOUNG	WIND	WEST	2012	117.5
531 TRINITY HILLS WIND 2		TRINITY_TH1_BUS2	YOUNG	WIND	WEST	2012	107.5
532 TURKEY TRACK WIND		TTWEC_G1	NOLAN	WIND	WEST	2008	169.5
533 WEST TEXAS WIND		SW_MESA_SW_MESA	UPTON	WIND	WEST	1999	80.3
534 WHIRLWIND ENERGY		WEC_WECG1	FLOYD	WIND	PANHANDLE	2007	57.0
535 WHITETAIL WIND		EXGNWTL_WIND_1	WEBB	WIND	SOUTH	2012	91.0
536 WINDTHORST 2 WIND		WNNDTHST2_UNIT1	ARCHER	WIND	WEST	2014	67.6
537 WKN MOZART WIND		MOZART_WIND_1	KENT	WIND	WEST	2012	30.0
538 WOLF RIDGE WIND		WHTTAIL_WR1	COOKE	WIND	NORTH	2008	112.5
539 TSTC WEST TEXAS WIND		DG_ROSC2_1UNIT	NOLAN	WIND	WEST	2008	2.0
540 WOLF FLATS WIND (WIND MGT)		DG_TURL_UNIT1	HALL	WIND	PANHANDLE	2007	1.0
541 Operational Wind Capacity Sub-total (Non-Coastal Counties)							14085.0
542 Wind Peak Average Capacity Percentage (Non-Coastal)		WIND_PEAK_PCT_NC	%				12.0
543							
544 CAMERON COUNTY WIND		CAMWIND_UNIT1	CAMERON	WIND-C	COASTAL	2015	165.0
545 GULF WIND I		TGW_T1	KENEDY	WIND-C	COASTAL	2010	141.6
546 GULF WIND II		TGW_T2	KENEDY	WIND-C	COASTAL	2010	141.6
547 LOS VIENTOS WIND I		LV1_LV1A	WILLACY	WIND-C	COASTAL	2013	200.1
548 LOS VIENTOS WIND II		LV1_LV1B	WILLACY	WIND-C	COASTAL	2013	201.6
549 MAGIC VALLEY WIND (REDFISH) 1A		REDFISH_MV1A	WILLACY	WIND-C	COASTAL	2012	99.8
550 MAGIC VALLEY WIND (REDFISH) 1B		REDFISH_MV1B	WILLACY	WIND-C	COASTAL	2012	103.5
551 PAPALOTE CREEK WIND		PAP1_PAP1	SAN PATRICIO	WIND-C	COASTAL	2009	179.9
552 PAPALOTE CREEK WIND II		COTTON_PAP2	SAN PATRICIO	WIND-C	COASTAL	2010	200.1
553 PENASCAL WIND 1		PENA_UNIT1	KENEDY	WIND-C	COASTAL	2009	160.8
554 PENASCAL WIND 2		PENA_UNIT2	KENEDY	WIND-C	COASTAL	2009	141.6
555 PENASCAL WIND 3		PENA3_UNIT3	KENEDY	WIND-C	COASTAL	2011	100.8
556 HARBOR WIND		DG_NUECE_6UNITS	NUECES	WIND-C	COASTAL	2012	9.0
557 Operational Wind Capacity Sub-total (Coastal Counties)							1845.4
558 Wind Peak Average Capacity Percentage (Coastal)		WIND_PEAK_PCT_C	%				55.0
559							
560 Operational Wind Capacity Total (All Counties)		WIND_OPERATIONAL					15930.4
561							
562 Operational Resources (Solar)							
563 ACACIA SOLAR		ACACIA_UNIT_1	PRESIDIO	SOLAR	WEST	2012	10.0
564 FS BARILLA SOLAR-PECOS		HOVEY_UNIT1	PECOS	SOLAR	WEST	2014	22.0
565 OCI ALAMO 1 SOLAR		OCL_ALM1_UNIT1	BEXAR	SOLAR	SOUTH	2013	39.2
566 OCI ALAMO 4 SOLAR-BRACKETVILLE		ECLIPSE_UNIT1	KINNEY	SOLAR	SOUTH	2014	37.6
567 OCI ALAMO 5 (DOWNIE RANCH)		HELIOS_UNIT1	UVALDE	SOLAR	SOUTH	2015	95.0
568 WEBBERVILLE SOLAR		WEBBER_S_WSP1	TRAVIS	SOLAR	SOUTH	2011	26.7
569 BLUE WING 1 SOLAR		DG_BROOK_1UNIT	BEXAR	SOLAR	SOUTH	2010	7.6

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
570 BLUE WING 2 SOLAR		DG_ELEM_1UNIT	BEXAR	SOLAR	SOUTH	2010	7.3
571 OCI ALAMO 2 SOLAR-ST. HEDWIG		DG_STHWG_UNIT1	BEXAR	SOLAR	SOUTH	2014	4.4
572 OCI ALAMO 3-WALZEM SOLAR		DG_WALZM_UNIT1	BEXAR	SOLAR	SOUTH	2014	5.5
573 RENEWABLE ENERGY ALTERNATIVES-CCS1		DG_COSERVSS_CCS1	DENTON	SOLAR	NORTH	2015	2.0
574 SUNEDISON CPS3 SOMERSET 1 SOLAR		DG_SOME1_1UNIT	BEXAR	SOLAR	SOUTH	2012	5.6
575 SUNEDISON SOMERSET 2 SOLAR		DG_SOME2_1UNIT	BEXAR	SOLAR	SOUTH	2012	5.0
576 SUNEDISON RABEL ROAD SOLAR		DG_VALL1_1UNIT	BEXAR	SOLAR	SOUTH	2012	9.9
577 SUNEDISON VALLEY ROAD SOLAR		DG_VALL2_1UNIT	BEXAR	SOLAR	SOUTH	2012	9.9
<b>578 Operational Capacity Total (Solar)</b>		<b>SOLAR_PEAK_PCT</b>	%				<b>287.7</b>
579 Solar Peak Average Capacity Percentage							80.0
580							
581 Reliability Must-Run (RMR) Capacity		RMR_CAP_CONT		GAS			0.0
582							
<b>583 Non-Synchronous Tie Resources</b>							
584 EAST TIE		DC_E	FANNIN		NORTH		600.0
585 NORTH TIE		DC_N	WILBARGER		WEST		220.0
586 EAGLE PASS TIE		DC_S	MAVERICK		SOUTH		30.0
587 LAREDO VFT TIE		DC_L	WEBB		SOUTH		100.0
588 SHARYLAND RAILROAD TIE		DC_R	HIDALGO		SOUTH		150.0
589 SHARYLAND RAILROAD TIE 2		DC_R2	HIDALGO		SOUTH		150.0
<b>590 Non-Synchronous Ties Total</b>							<b>1250.0</b>
591 Non-Synchronous Ties Capacity Contribution (Top 20 Hours)		DCTIE_CAP_CONT		OTHER			577.0
592							
<b>593 Planned Thermal Resources with Executed SGIA, Air Permit, GHG Permit and Water Rights</b>							
594 COLORADO BEND III	17INR0007		WHARTON	GAS	SOUTH	2017	0.0
595 TEXAS CLEAN ENERGY PROJECT	13INR0023		ECTOR	COAL	WEST	2019	0.0
596 FGE TEXAS I PROJECT	16INR0010		MITCHELL	GAS	WEST	2018	0.0
597 ANTELOPE 1-3 IC & ELK CTG 1 (SWITCHABLE)	13INR0028		HALE	GAS	PANHANDLE	2016	0.0
598 LA PALOMA ENERGY CENTER PROJECT	16INR0004		CAMERON	GAS	COASTAL	2018	0.0
599 PHR PEAKERS [BAC_CTG1-6]	14INR0038		GALVESTON	GAS	HOUSTON	2016	388.0
600 SKY GLOBAL POWER ONE	16INR0057		COLORADO	GAS	SOUTH	2016	51.4
601 INDECK WHARTON ENERGY CENTER PROJECT	15INR0023		WHARTON	GAS	SOUTH	2017	0.0
602 PINERECTION ENERGY CENTER PROJECT	16INR0006		ANGELINA	GAS	NORTH	2017	0.0
603 RED GATE IC PLANT [REDGATE_AGR_A-D]	14INR0040		HIDALGO	GAS	SOUTH	2016	225.0
604 ELK STATION CTG 2 (SWITCHABLE)	15INR0032		HALE	GAS	PANHANDLE	2016	202.0
605 ELK STATION CTG 3	15INR0033		HALE	GAS	PANHANDLE	2016	202.0
606 WOLF HOLLOW 2	17INR0009		HOOD	GAS	NORTH	2017	0.0
607 FRIENDSWOOD G	13INR0049		HARRIS	GAS	HOUSTON	2017	0.0
608 BETHEL CAES PROJECT	15INR0013		ANDERSON	STORAGE	NORTH	2018	0.0
<b>609 Planned Capacity Total (Coal, Gas &amp; Storage)</b>							<b>1068.4</b>
610							
<b>611 Planned Wind Resources with Executed SGIA</b>							
612 ALBERCAS WIND	15INR0049		ZAPATA	WIND	SOUTH	2016	0.0
613 GUNSLIGHT MOUNTAIN WIND	08INR0018		HOWARD	WIND	WEST	2016	0.0
614 BAFFIN WIND [BAFFIN_UNIT1-2]	06INR0022c		KENEDY	WIND-C	COASTAL	2016	202.0
615 MIDWAY FARMS WIND	11INR0054		SAN PATRICIO	WIND-C	COASTAL	2016	0.0
616 LONGHORN WIND SOUTH	14INR0023b		BRISCOE	WIND	PANHANDLE	2016	0.0
617 MARIAH WIND A	13INR0010a		PARMER	WIND	PANHANDLE	2017	0.0
618 MARIAH WIND B	13INR0010b		PARMER	WIND	PANHANDLE	2016	0.0
619 MIAMI WIND 1B	14INR0012b		GRAY	WIND	PANHANDLE	2016	111.0
620 RATTLESNAKE DEN WIND 2	13INR0020b		GLASSCOCK	WIND	WEST	2017	0.0
621 PATRIOT WIND (PETRONILLA)	11INR0062		NUECES	WIND-C	COASTAL	2016	0.0
622 COMANCHE RUN WIND	12INR0029		SWISHER	WIND	PANHANDLE	2016	0.0
623 PAMPA WIND	12INR0018		GRAY	WIND	PANHANDLE	2017	0.0
624 SOUTH PLAINS WIND II	14INR0025b		FLOYD	WIND	PANHANDLE	2016	151.8
625 SOUTH PLAINS WIND III	14INR0025c		FLOYD	WIND	PANHANDLE	2016	148.5
626 WAKE WIND	14INR0047		DICKENS	WIND	PANHANDLE	2016	0.0
627 DOUG COLBECK'S CORNER (CONWAY)	13INR0005b		CARSON	WIND	PANHANDLE	2016	0.0
628 GRANDVIEW WIND 3 (CONWAY)	13INR0005c		CARSON	WIND	PANHANDLE	2016	0.0
629 SCANDIA WIND DEF	13INR0010def		PARMER	WIND	PANHANDLE	2017	0.0
630 PULLMAN ROAD WIND	15INR0079		RANDALL	WIND	PANHANDLE	2016	0.0
631 PANHANDLE WIND 3	14INR0030c		CARSON	WIND	PANHANDLE	2016	0.0
632 SALT FORK WIND	14INR0062		GRAY	WIND	PANHANDLE	2016	0.0
633 LOS VIENTOS IV WIND	15INR0037		STARR	WIND	SOUTH	2016	0.0
634 LOS VIENTOS V WIND [LV5_UNIT_1]	15INR0021		STARR	WIND	SOUTH	2016	110.0
635 PALO DURO WIND	15INR0050		DEAF SMITH	WIND	PANHANDLE	2016	0.0
636 CAPROCK WIND	10INR0009		CASTRO	WIND	PANHANDLE	2017	0.0
637 SAN ROMAN WIND	14INR0013		CAMERON	WIND-C	COASTAL	2016	0.0
638 TORRECILLAS WIND A	14INR0045a		WEBB	WIND	SOUTH	2016	0.0
639 TORRECILLAS WIND B	14INR0045b		WEBB	WIND	SOUTH	2016	0.0
640 CHANGING WINDS	13INR0045		CASTRO	WIND	PANHANDLE	2017	0.0
641 ELECTRA WIND	16INR0062		WILBARGER	WIND	WEST	2016	0.0
642 HORSE CREEK WIND	14INR0060		HASKELL	WIND	WEST	2016	0.0
643 WILLOW SPRINGS WIND	14INR0060b		HASKELL	WIND	WEST	2016	0.0
644 MUENSTER WIND	15INR0085		COOKE	WIND	NORTH	2016	0.0
645 HAPPY WHITEFACE WIND	15INR0074		DEAF SMITH	WIND	PANHANDLE	2016	0.0
646 CHAPMAN RANCH WIND I	16INR0055		NUECES	WIND-C	COASTAL	2016	0.0
647 HIDALGO & STARR WIND	16INR0024		HIDALGO	WIND	SOUTH	2016	0.0
648 BLANCO CANYON WIND (COTTON PLAINS)	16INR0037		FLOYD	WIND	PANHANDLE	2016	0.0
649 BLANCO CANYON WIND (OLD SETTLER)	16INR0037b		FLOYD	WIND	PANHANDLE	2016	0.0
650 ROCK SPRINGS VAL VERDE WIND	11INR0082a		VAL VERDE	WIND	WEST	2016	0.0
651 MAGIC VALLEY WIND II (REDFISH 2A and 2B)	14INR0041a		WILLACY	WIND-C	COASTAL	2017	0.0
652 SALT FORK WIND 2	16INR0082		CARSON	WIND	PANHANDLE	2016	0.0
653 SANTA RITA WIND	16INR0091		REAGAN	WIND	WEST	2016	0.0
654 SWISHER WIND	13INR0038		SWISHER	WIND	PANHANDLE	2016	0.0
655 BUCKTHORN WIND 1	14INR0057		ERATH	WIND	NORTH	2016	0.0
656 FLUVANNA RENEWABLE 1	13INR0056		SCURRY	WIND	WEST	2017	0.0
657 RTS WIND	16INR0087		MCCULLOCH	WIND	SOUTH	2016	0.0
<b>658 Planned Capacity Total (Wind)</b>							<b>723.3</b>
659							
660 Planned Wind Capacity Sub-total (Non-Coastal Counties)		WIND_PLANNED_NC					521.3
661 Wind Peak Average Capacity Percentage (Non-Coastal)		WIND_PL_PEAK_PCT_NC	%				12.0
662							
663 Planned Wind Capacity Sub-total (Coastal Counties)		WIND_PLANNED_C					202.0
664 Wind Peak Average Capacity Percentage (Coastal)		WIND_PL_PEAK_PCT_C	%				55.0

UNIT NAME	GENERATION INTERCONNECTION PROJECT CODE	UNIT CODE	COUNTY	FUEL	ZONE	START YEAR	CAPACITY (MW)
665							
<b>666 Planned Solar Resources with Executed SGIA</b>							
667 FS BARILLA SOLAR 1B [HOVEY_UNIT2]	12INR0059b		PECOS	SOLAR	WEST	2016	7.4
668 FS BARILLA SOLAR 2	12INR0059c		PECOS	SOLAR	WEST	2016	0.0
669 RE ROSEROCK SOLAR	16INR0048		PECOS	SOLAR	WEST	2016	0.0
670 OCI ALAMO 6 (WEST TEXAS)	15INR0070_1		PECOS	SOLAR	WEST	2016	0.0
671 OCI ALAMO 6 (WEST TEXAS PHASE II)	15INR0070_1b		PECOS	SOLAR	WEST	2016	0.0
672 SE BUCKTHORN WESTEX SOLAR (RIGGINS SOLAR)	15INR0045		PECOS	SOLAR	WEST	2016	0.0
673 FS EAST PECOS SOLAR	16INR0073		PECOS	SOLAR	WEST	2016	0.0
674 OCI ALAMO 7 (PAINT CREEK)	16INR0052		HASKELL	SOLAR	WEST	2016	0.0
675 LC NAZARETH SOLAR	16INR0049		CASTRO	SOLAR	PANHANDLE	2016	0.0
676 PECOS SOLAR POWER I	15INR0059		PECOS	SOLAR	WEST	2017	0.0
677 BNB LAMESA SOLAR	16INR0023		DAWSON	SOLAR	WEST	2016	0.0
678 CAPRICORN RIDGE SOLAR	16INR0019		COKE	SOLAR	WEST	2016	0.0
679 UPCO POWER 1 (SP-TX-12)	16INR0065		UPTON	SOLAR	WEST	2016	0.0
680 SP-TX-12-PHASE B	16INR0065B		UPTON	SOLAR	WEST	2016	0.0
681 SOLAIREHOLMAN 1	15INR0061		BREWSTER	SOLAR	WEST	2016	0.0
682 Upton Solar	16INR0114		UPTON	SOLAR	WEST	2017	0.0
<b>683 Planned Capacity Total (Solar)</b>							
684 Solar Peak Average Capacity Percentage		SOLAR_PL_PEAK_PCT	%				80.0
685							
<b>686 Seasonal Mothballed Resources</b>							
687 MARTIN LAKE U2 (SINCE 10/10/2015)	MLSES_UNIT2		RUSK	COAL	NORTH	1978	805.0
<b>688 Total Seasonal Mothballed Capacity</b>							
689							
<b>690 Mothballed Resources</b>							
692 J T DEELY U1 (AS OF 12/31/2018)	CALAVERS_JTD1_M		BEXAR	COAL	SOUTH	2018	420.0
693 J T DEELY U2 (AS OF 12/31/2018)	CALAVERS_JTD2_M		BEXAR	COAL	SOUTH	2018	420.0
694 SILAS RAY CTG 5 (RETIREES ON 4/6/2016)	SILASRAY_SILAS_5		CAMERON	GAS	COASTAL	1953	10.0
695 S R BERTRON CTG 2 (SINCE 5/15/2013)	SRB_SRGBT_2		HARRIS	GAS	HOUSTON	1967	13.0
696 S R BERTRON U1 (SINCE 5/15/2013)	SRB_SR.B_G1		HARRIS	GAS	HOUSTON	1958	118.0
697 S R BERTRON U2 (SINCE 5/15/2013)	SRB_SR.B_G2		HARRIS	GAS	HOUSTON	1956	174.0
698 S R BERTRON U3 (SINCE 5/22/2013)	SRB_SR.B_G3		HARRIS	GAS	HOUSTON	1959	211.0
699 S R BERTRON U4 (SINCE 5/22/2013)	SRB_SR.B_G4		HARRIS	GAS	HOUSTON	1960	211.0
700 W A PARISH - PETRA NOVA CTG (AS OF 5/19/2016)	PNPL_GT2		FORT BEND	GAS	HOUSTON	2013	74.0
<b>701 Total Mothballed Capacity</b>							
							1651.0

## **Seasonal Assessment of Resource Adequacy for the ERCOT Region**

### **Background**

The Seasonal Assessment of Resource Adequacy (SARA) report is a deterministic approach to considering the impact of potential variables that may affect the sufficiency of installed resources to meet the peak electrical demand on the ERCOT System during a particular season.

The standard approach to assessing resource adequacy for one or more years into the future is to account for projected load and resources on a normalized basis and to require sufficient reserves (resources in excess of peak demand, on this normalized basis) to cover the uncertainty in peak demand and resource availability to meet a one-in-ten-years loss-of-load event criteria on a probabilistic basis.

For seasonal assessments that look ahead less than a year, specific information may be available (such as seasonal climate forecasts or anticipated common-mode events such as drought) which can be used to consider the range of resource adequacy in a more deterministic manner.

In contrast to the Capacity, Demand and Reserves (CDR) report, which addresses the sufficiency of planning reserves on an annual basis as described above, the SARA report focuses on the availability of sufficient operating reserves to avoid emergency actions such as deployment of voluntary load reduction resources. Consequently, load reduction resources included in the CDR report, such as Emergency Response Service (ERS) and Load Resources that provide operating reserves (LRs), are excluded from the SARA.

The SARA report is intended to illustrate the range of resource adequacy outcomes that might occur, and thus help fulfill the reporting requirement per Public Utility Commission of Texas rule 25.362(i)(2)(H). Several sensitivity analyses are developed by varying the value of certain parameters that affect resource adequacy. The variation in these parameters is based on historic values of these parameters or adjustments by any known or expected changes.