



## Lower Rio Grande Valley Regional Planning Group Projects


ERCOT System Planning

May 17, 2016

ERCOT Regional Planning Group Meeting

- Background
- Drivers for Development
- Assumption and Sensitivity Analysis
- Recommendation
- Next Step

# Valley Import Background




- The Lower Rio Grande Valley (LRGV) import paths currently include:
  - (3) 345 kV lines,
  - (3) 138 kV lines,
  - 300 MW DC tie to Mexico

Generation in and near LRGV Area		
Capacity (MW)	Gas	Wind
Existing (a)	1245	1737
Planning (Meet PG6.9)	225	2641
<b>Total</b>	<b>1470</b>	<b>4378</b>

(a) Exclude Frontera Facility

- **More Stringent NERC TPL-001-4 Criteria**
  - Upgrades, if identified, need to be Implemented by 2021 to prevent loss of non consequential load under NERC P3 Events (including G-1-G-1)
- **Frontera Plant Facilities (524MW) no longer plan to participate in the ERCOT**
  - <http://www.ercot.com/content/news/presentations/2014/ERCOT%20Frontera%20Letter.pdf>

# LRGV Existing Load Serving Capability and Load Forecast




- ERCOT 2016 Regional Planning Plan (RTP) is consistent with AEP's load projection
- Valley Summer Peak Load Serving Capability: 2700 MW (less than 100 MW UVLS)
- **Upgrades are required prior to 2021 Summer**



- **AEPSC proposed LRGV area transmission improvements in April, 2015**
  - Three +600/-200 MVAR SVCs (South McAllen, LaPalma, Weslaco)
  - New NSUBLH-Ajo-NSUBXING 345 kV BOLD Transmission Line
  - Two 345/138 kV transformers
- **Sharyland and CPS jointly proposed LRGV import project in September, 2015**
  - Three 400~600 MVAR SVCs (Loma Alta, Railroad, North Edinburg)
  - New Elm Creek-Palmito 345 kV double circuit
  - New La Palma-Palmito 345 kV single circuit
  - One 345/138kV transformer

- **Evaluated 2021 summer peak condition**
  - Steady State: from 2015 RTP case
  - Dynamic Stability: from 2015 DWG flat start case (include dynamic load models in the Valley region)
  - Dispatched wind output at 10% of rated capacity in the Valley region
- **Ten upgrade options were developed (appendix)**

# Voltage Stability Assessment and Cost Comparison





## Reduced to Three Alternatives

- Option 1: ~91 M\$
  - One 300 MVar SVC at LaPalma 138 kV substation, and one 300 MVar SVC at AEP Pharr 138 kV substation
- Option 4: 330 M\$~348 M\$ (higher cost estimate is based on “hot” construction)
  - Option1 with San Miguel-Lobo-North Edinburg string 2nd circuit, no series compensation
- Option 5: ~403 M\$
  - Option 1 with one new 345 kV circuit NSUBLH-Ajo-NSUBXING (BOLD), two 345/138 kV autotransformers

# Comparisons

Items	Option 1 (2 SVCs)	Option 4 (2 SVCs + 2 <sup>nd</sup> circuit)	Option 5 (2 SVCs + new import)
Load Serving Capability (MW)	2800	3300	3400
Reliability Criteria	2023	Beyond 2025	Beyond 2025
Cost Estimate (M\$)	91	330~348	403
Total New ROW Required (miles)	0	~7	~140
Implementation Time (year)	3	3	5

- **LNG Load**

- Currently, there is no LNG commitment in the Valley region
- Assumed 700 MW LNG load in Cameron County
- New import option terminated at east of Valley region will have better LNG load serving capability
- The actual LNG implementation may require a new import path or additional local generation

- **New Generation**

- Assumed one generation project (~780MW with SGIA) in Cameron County
- No upgrades were needed under 2021 summer peak conditions with a 780 MW generation addition
- No upgrades were needed under 2021 summer peak conditions with 700 MW of LNG load added along with a 780 MW generator addition

- Improvements associated with option 1:
  - One 300 MVAR SVC at La Palma 138 kV substation
  - One 300 MVAR SVC at AEP Pharr 138 kV substation
- Estimated Capital Cost: 91 M\$
- Further improvements will be needed to meet 2023 load conditions. Recommending option 1 at this time will allow ERCOT and TSPs time to:
  - Evaluate proper long-term solution with potentially more certainty about location generation and LNG load plans
  - Evaluate the dynamic load model assumptions


- Complete the study report
- Present the independent review results to
  - TAC on May 26, 2016
  - BOD on June 14, 2016

# Appendix




# Upgrade Options

- Ten upgrade options were developed.




system topology after 2016 summer


# Option 1: One 300 MVAR SVC at LaPalma 138 kV substation, and one 300 MVAR SVC at Pharr 138 kV substation




# Option 2: Option1 with one new 345 kV circuit NSUBLH-LaPalma (BOLD)




Option 3: Option 1 with one new 345 kV circuit NSUBLH-NSUBXING (BOLD), two 345/138 kV transformers



# Option 4: Option1 with San Miguel-Lobo-North Edinburg string 2nd circuit, no series compensation




Option 5: Option 1 with one new 345 kV circuit NSUBLH-Ajo-NSUBXING (BOLD), two 345/138 kV transformers







# Option 6: Option 1 with one new 345 kV circuit NSUBLH-Ajo-LaPalma (BOLD)




# Option 7: Option 1 with one new 345 kV circuit Elm Creek-Palmito



# Option 8: Option 1 with one new 345 kV circuit Elm Creek-Ajo-Palmito



# Option 9: Option1 with one new 345 kV circuit NSUBLH-Ajo-North Edinburg (BOLD)



# Option 10: Option 1 with one new 345 kV circuit San Miguel-North Edinburg

