



**Freeport Area Master Plan Project -  
ERCOT Independent Review Final  
Recommendation**

**System Development  
November 14, 2017**

# Overview

**CenterPoint submitted Freeport Masterplan Project for RPG review. This is a Tier 1 project that is estimated to cost \$ 246.7 million.**

- Proposed for 2019 –2021
- To serve new committed loads
- Reliability Issues
  - Severe low voltages
  - Overloads
  - Difficulty of maintenance outage Scheduling
- Provide Operational Flexibility

# Past RPG Presentations on Freeport Master Plan Project

- ERCOT presented the study scope in June 2017 RPG  
[http://www.ercot.com/content/wcm/key\\_documents\\_lists/108872/CNP\\_Freeport\\_Masterplan\\_Study\\_Scope\\_-\\_RPG.pdf](http://www.ercot.com/content/wcm/key_documents_lists/108872/CNP_Freeport_Masterplan_Study_Scope_-_RPG.pdf)
- ERCOT presented a status update during August 2017 RPG  
<http://www.ercot.com/calendar/2017/8/22/108879-RPG>
- ERCOT presented last status updates during October 2017 RPG  
[http://www.ercot.com/content/wcm/key\\_documents\\_lists/108888/CNPF\\_PFP\\_EIR\\_StatusUpdate\\_RPG\\_10192017.pdf](http://www.ercot.com/content/wcm/key_documents_lists/108888/CNPF_PFP_EIR_StatusUpdate_RPG_10192017.pdf)

# Near-Term Planning -> Bridge The Gap Upgrades

- To resolve the base case violations CNP's 'Bridge The Gap Upgrades' are recommended for 2019/2022 time period.
- The list of these upgrades include ->
  1. Loop 345 kV South Texas Project (STP) – Dow-Velasco circuit 27 into the Jones Creek Substation (approximately 0.9 mile)
  2. Install 7-ohm in-line reactors at the Jones Creek Substation on 345 kV STP – Jones Creek circuits 18 and 27
  3. Install 3<sup>rd</sup> 345/138 kV 800/1000 MVA Autotransformer at the Jones Creek Substation
  4. Install 4<sup>th</sup> 138 kV Capacitor Bank (120 MVAR) at Jones Creek Substation
  5. Install 1<sup>st</sup> 138 kV Automatically Switchable Capacitor Bank (140 MVAR) at Jones Creek Substation
  6. Install 2<sup>nd</sup> 138 kV Automatically Switchable Capacitor Bank (140 MVAR) at Jones Creek Substation
- Total cost estimate for all these upgrades is \$32.3M.

# 2020 Steady State Violations After Bridge The Gap Upgrades

- o Violation summary for 2020 Study Case after including 'Bridge the Gap Upgrades' ->

| Contingency Category | Branch Violations         |     |                  |
|----------------------|---------------------------|-----|------------------|
|                      | Element                   | KV  | Max. Loading (%) |
| P3 (G-1 + N-1)       | Oasis to WA Parish Ckt 99 | 345 | 100.4            |

# 2022 Steady State Violations After Bridge The Gap Upgrades

- Violations summary for 2022 Study Case with 'Bridge the Gap Upgrades' ->

| Contingency Category | Branch Violations         |     |                  |
|----------------------|---------------------------|-----|------------------|
|                      | Element                   | KV  | Max. Loading (%) |
| P3 (G-1 + N-1)       | Oasis to WA Parish Ckt 99 | 345 | 101.7            |
| P6-1, P6-3 (N-1-1)   | Oasis to Dow Ckt 27       | 345 | 135.8            |
|                      | STP to Jones Creek Ckt 27 | 345 | 109.2            |


# Options Studied

- **Option – 1**: New Double Circuit 345kV line from STP to Jones Creek (50.4 miles);
- **Option – 2**: New Double Circuit 345kV line from Hillje to Jones Creek (62.4 miles);
- **Option – 3**: New Double Circuit 345kV line from Bailey to Jones Creek (48 miles);

**Options 1-3 have a common upgrade of DOW to Jones Creek 345kV Circuits 18 & 27 (3 miles)**


- **Option – 4**: New Double Circuit 345kV line from PHR to Jones Creek (60 miles)
- **Option – 5**: Existing System Upgrade
  - Oasis to WAP 345kV Circuit 99
  - DOW to Oasis 345kV Circuits 18 & 27
  - DOW to Jones Creek 345kV Circuits 18 & 27
  - STP to Jones Creek 345kV Circuits 18 & 27

# New Line Options





# Option – 5 (Line Upgrades)



# Overview of further results

- Transfer Analysis
- High Load Sensitivity
- Dynamics Analysis
- Economics Analysis
- PG Section 3.1.3 (4) - Generation Addition and Load Scaling Sensitivity

# VSAT Transfer analysis – Voltage Stability

| Options | Description        | Base load level (MW) | Maximum transfer (MW) | Margin (MW) |
|---------|--------------------|----------------------|-----------------------|-------------|
| 1       | STP-JC             | 20451                | 22691                 | 2240        |
| 2       | HILLJE-JC          |                      | 22611                 | 2160        |
| 3       | BAILEY-JC          |                      | 22531                 | 2080        |
| 4       | PHR-JC             |                      | 22011                 | 1560        |
| 5       | Only line upgrades |                      | 20811                 | 360         |

|                               |   |
|-------------------------------|---|
| <b>Source Weather Zones</b>   | East, West, South Central, South  |
| <b>Sink Weather Zone</b>      | Coast   |
| <b>Monitored Buses</b>        | Freeport area and south side of Houston   |
| <b>Study base case source</b> | 2023 Summer peak case from LT 2023 SP dynamics data set                                       |
| <b>Contingencies studied</b>  | All 345 kV Branch, Generation outages and 345 kV Double circuit outages in Coast weather zone |

# High Load Sensitivity (P1, P2-1, P7)

*Uncommitted load of 657MW is added to the Freeport Area*

- Unsolved Contingency

| Contingency                            | Option 1 | Option 2 | Option 3 | Option 4 | Option 5             |
|--|----------|----------|----------|----------|----------------------|
| STP to Jones Creek Ckts 18 and 27 (P7) | -        | -        | -        | -        | Unsolved Contingency |


- 345kV Branch Violations, in %

| Element             | Option 1 | Option 2 | Option 3 | Option 4 | Option 5 |
|---------------------|----------|----------|----------|----------|----------|
| WAP to OASIS Ckt 99 | -        | -        | -        | 106.2    | -        |

# High Load Sensitivity (G-1 + N-1; X-1 + N-1)

| Contingency | 345kV Bus Violations |          |          | 345kV Branch Violations |   |   |
|-------------|----------------------|----------|----------|-------------------------|---|---|
|             | Option 1             | Option 2 | Option 3 | Option 1                | Option 2                                    | Option 3                                    |
| G-1 + N-1   | None                 | None     | None     | None                    | None  | Singleton to Zenith Double Circuit (100.5%) |
| X-1 + N-1   | None                 | None     | None     | None                    | Singleton to Zenith Double Circuit (101.5%) | Singleton to Zenith Double Circuit (101.3%) |

# High Load Sensitivity Summary



# Dynamics Analysis Results – Base case with BTG Upgrades

| Case      | Topological Changes                     | Contingency Category |        |        |        |        |        |
|-----------|---|----------------------|--------|--------|--------|--------|--------|
|           |   | P1                   | P2     | P3     | P4, P5 | P6     | P7     |
| LT2023 SP | BTG Upgrades + DOW 4 <sup>th</sup> Auto | Stable               | Stable | Stable | Stable | Stable | Stable |

# Dynamics Analysis Results – Option 2 or 3

| Case      | Topological Changes                                     | Contingency Category |        |        |        |        |        |
|-----------|---|----------------------|--------|--------|--------|--------|--------|
|           |   | P1                   | P2     | P3     | P4, P5 | P6     | P7     |
| LT2023 SP | BTG Upgrades + DOW 4 <sup>th</sup> Auto + Option 2 or 3 | Stable               | Stable | Stable | Stable | Stable | Stable |

# Economic Analysis

- 2023 RTP Economic case was used to run the Economic Analysis in UPLAN
- No load or generation changes were made to the base case
- The production cost savings of Option 2 and 3 are very similar



# Sensitivity Analysis – PG Section 3.1.3 (4)(a) Generation

- Generation Sensitivity study to meet PG Section 3.1.3 (4)(a)
- 2017 August Generation Interconnection Report
- The additional generation does not resolve any of the base case violations for 2022
- Generation sensitivity analysis does not have an impact on the project need

| GINR Number | Project Name                | MW  | Fuel | County   |
|-------------|-----------------------------|-----|------|----------|
| 15INR0023   | Indeck Wharton              | 654 | Gas  | Wharton  |
| 16INR0044   | Halyard Wharton             | 419 | Gas  | Wharton  |
| 16INR0074   | Chocolate Bayou W           | 150 | Wind | Brazoria |
| 17INR0022   | MIRAGE (NET Power LA Porte) | 11  | Gas  | Harris   |


# Sensitivity Analysis – PG Section 3.1.3 (4)(b) Load Scaling

- Load Scaling Sensitivity study to meet PG Section 3.1.3 (4)(b)
- Five 345 kV thermal violations in the study
- PTDFs calculated with Coast weather zone as sink and each of the other weather zones as source
- The RTP case load scaling did not have an impact on the project need

# Summary of Results

| Option #                              | Option 1 | Option 2  | Option 3  | Option 4 | Option 5           |
|---------------------------------------|----------|-----------|-----------|----------|--------------------|
| Description                           | STP-JC   | HILLJE-JC | BAILEY-JC | PHR-JC   | Only line upgrades |
| Extreme Contingency Limitation        | Yes      | No        | No        | Yes      | Yes                |
| Voltage Stability Transfer Limit (MW) | 2240     | 2160      | 2080      | 1560     | 360                |
| Dynamic Stability Issues              | --       | No        | No        | --       | --                 |
| Projected Load for 2022 issues        | No       | No        | No        | No       | No                 |
| Projected Load for 2022 + High Load   | None     | P6        | P3/P6     | --       | --                 |
| New ROW Distance (miles)              | 50.4     | 62.4      | 48        | 60       | --                 |
| Estimated Cost (Million \$)           | 223.2    | 272.5     | 214.4     | 220      | 281.8              |

# Final Recommendation



# Final Recommendation - Description

- ‘Bridge the Gap Upgrades’ are required to meet the reliability needs. Cost estimate: \$32,340,000:
  - Loop 345 kV South Texas Project (STP) – Dow-Velasco circuit 27 into the Jones Creek Substation (approximately 0.9 mile)
  - Install 7-ohm in-line reactors at the Jones Creek Substation on 345 kV STP – Jones Creek circuits 18 and 27
  - Install 3rd 345/138 kV 800/1000 MVA Autotransformer at the Jones Creek Substation
  - Install 4th 138 kV Capacitor Bank (120 MVar) at Jones Creek Substation
  - Install 1st 138 kV Automatically Switchable Capacitor Bank (140 MVar) at Jones Creek Substation
  - Install 2nd 138 kV Automatically Switchable Capacitor Bank (140 MVar) at Jones Creek Substation
  
- Option 3 meets the reliability criteria in the most cost effective manner. Option 3 has a cost estimate of \$214,400,000 and is described as follows:
  - Construct a new approximately 48 mile 345 kV double circuit transmission line from Bailey Substation to Jones Creek Substation (2988 MVA emergency rating)
  - Upgrade 345 kV Dow-Velasco to Jones Creek circuits 18 and 27 which is approximately 3 miles (minimum 1700 MVA emergency rating)



For any questions please email Ajay Pappu (Venkata.Pappu@ercot.com)