South Texas SSO Update



Shun Hsien (Fred) Huang Regional Planning


ERCOT ROS Meeting May 2, 2019

Background: South Texas SSO

- Recall that there were SSR events in 2017 2018 involving wind farms on the Lobo – North Edinburg line.
 - Wind farms have since tuned their SSR mitigation.
 - However, more wind and solar generation projects are coming to the area.
 - These changes are creating additional SSO and stability challenges.



Generation Interconnection Overview at LOBO-North Edinburg 345 kV Series Compensated Circuit



As of March, 2019





Constraints

- Total Committed WGR Capacity:
 - Existing + PG 6.9 = 2041 MW
- Challenges:
 - Thermal Constraint
 - Stability Constraints: voltage stability and weak grid
 - Subsynchronous Resonance



Constraints

- Thermal and stability limits (e.g. GTC) can be resolved through SCED disptach
- One SSCI constraint is at lower WGR dispatch
 - Weak Grid + High Series Compensation at Lobo-North Edinburg 345 kV circuit could cause the existing WGRs to reach their physical and controller design capability to reliably ride through faults and SSCI as required/expected
 - Reliance on specific tuning of controllers is a concern.
 - Recurring tuning of the existing and new generation projects involves various REs and vendors
 - Diminishing reliability margin of controllers may not be easily identified in the studies.



SSCI at Lobo-North Edinburg 345 kV Circuit

- SSCI potential has been identified in the SSR study of proposed generation projects.
 - All the latest SSR improvements through 2017/2018 SSCI events investigation were included.
 - No issues at single-line-to-ground faults for any tested events at different WGRs' output levels.
 - SSCI observed:
 - Following a 3 Phase fault
 - Radial connection to Lobo or North Edinburg
 - At lower WGR output
 - SSCI observed in the study results is possibly a result of the WGRs not having much margin for grid changes (the area is very challenging from a control design perspective)



Study Challenges

- Generally, only manufacturers tune the models
 - There is little available published documentation on how the models work and what all the parameters do.
 - Controllers becoming increasingly complex.
- Visibility/Data Sharing problem:
 - Manufacturers cannot receive an area model including other turbine models.
- Also, tuning challenges
 - Fixing the SSO issues last year took months of redesign. And even still it appears there may not be much margin to accommodate future grid changes.
- We may have reached the practical limit for control tuning.

Next Steps

- Work with TSPs on potential mitigation options
- Identify system changes/improvements to address SSCI issues
 - To be considered as reliability projects?

