



## **Item 4.2: Summer Intern Presentations**

*Bill Magness*

ERCOT President & CEO

Board of Directors Meeting

ERCOT Public

August 13, 2019

## 2019 Summer Interns



- 17 students representing 9 universities across the U.S.
- Contributed to 15 different departments this summer
- Recruiting received more than 1,400 applications for 17 summer internship openings

## 2019 Summer Interns Attend the Following Universities

UT Austin	6
UT Dallas	1
Texas A&M University	4
Baylor University	1
Texas State University	1
Arizona State University	1
University of Washington	1
Rensselaer Polytechnic Institute	1
Pennsylvania State University	1
<b>Total</b>	<b>17</b>

# Jessica Wert

---

Master of Science in Electrical Engineering  
Texas A&M University (May 2020)

2019 Transmission Operations Planning







# Overview

## Goals


- Foundation for dynamic simulation studies in real-time systems
- Benchmark dynamic responses
- Demonstrate functionality in production environment



# Benchmarking TSAT Against PSS®E Across ERCOT



# Benchmarking TSAT Against PMU Data



TSAT demonstrates shallower frequency drops

- Governor deadband modeling
- Governor response status
- Load-frequency dependence

# Conclusions

## Achievements

Benchmark dynamic contingency response in key areas

- Establishes trust in TSAT performance

Demonstrate functionality in production system (study mode)

- Contribute to reliable and efficient grid operations
- Can enhance operator training experience

## Key Takeaway

Foundation to find stability-related operating limits in real time

- Stable operations of grid can be achieved more reliably and efficiently




# Vijay Singh

---

Master of Science in Electrical Engineering  
University of Texas (December 2019)


2019 Resource Integration

## New Interconnection Requests




All interconnection requests require a screening study.

# Current Screening Study Process



# Screening Study Process with Tool



# Screening Study with Tool

## Benefits

### ERCOT

- Shorter study times
- Reduced potential errors
- Standardized process

### Market Participants

- Faster turnaround
- Concise report
- Consistent results

### Personal

- Gained new skills
- Experience
- Personal connections

## Caleb Holland

Bachelor of Science Electrical and Computer Engineering  
University of Texas (December 2020)

## John Lawson

Bachelor of Science Electrical and Computer Engineering  
Baylor University (December 2019)

## David Zhou

Bachelor of Science Electrical and Computer Engineering  
University of Texas (May 2020)


---

## 2019 Grid Planning and Operations Administration

# Problems with Current RARF Implementation

DESCRIPTION OF CHANGE	BREAKER / SWITCH					Static Ratings for Planning				
	Switch Name	Ercot Station Code Mnemonic	Switch Code	Normal Operating Status (when In-service)	Voltage Level	Continuous Rating	2-hr Emergency Rating	15 Min Rating	Connected Device 1	
List	enter all caps	enter all caps	Automatic	Open/Closed	kV	MVA	MVA	MVA	enter all caps	
CHANGE	SWITCH_1	STATION_1	STATION_1_STATION_1_SWITCH_1	CLOSED	138	200.00	200.00	200.00	SWITCH_2	BREAK
CHANGE	SWITCH_2	STATION_1	STATION_1_STATION_1_SWITCH_2	CLOSED	138	200.00	200.00	200.00	SWITCH_1	BREAK
CHANGE	BREAKER_1	STATION_1	STATION_1_STATION_1_BREAKER_1	OPEN	138	200.00	200.00	200.00	BREAKER_4	
CHANGE	BREAKER_2	STATION_1	STATION_1_STATION_1_BREAKER_2	CLOSED	138	200.00	200.00	200.00	SWITCH_4	
	SWITCH_3	STATION_1	STATION_1_STATION_1_SWITCH_3	CLOSED	138	200.00	200.00	200.00	SWITCH_6	
	SWITCH_4	STATION_1	STATION_1_STATION_1_SWITCH_4	CLOSED	138	200.00	200.00	200.00	BREAKER_X_Y	
	SWITCH_5	STATION_1	STATION_1_STATION_1_SWITCH_5	CLOSED	138	200.00	200.00	200.00	SWITCH_3	SWITC
CHANGE	BREAKER_3	STATION_1	STATION_1_STATION_1_BREAKER_3	CLOSED	138	200.00	200.00	200.00	SWITCH_8	
	BREAKER_4	STATION_1	STATION_1_STATION_1_BREAKER_4	OPEN	138	200.00	200.00	200.00	BREAKER_3	SWITC
	SWITCH_6	STATION_1	STATION_1_STATION_1_SWITCH_6	CLOSED	138	200.00	200.00	200.00	BREAKER_G_H	
CHANGE	BREAKER_5	STATION_1	STATION_1_STATION_1_BREAKER_5	CLOSED	138	200.00	200.00	200.00	SWITCH_I_J	
	BREAKER_6	STATION_1	STATION_1_STATION_1_BREAKER_6	CLOSED	138	200.00	200.00	200.00	BREAKER_2	SWITC
	SWITCH_7	STATION_1	STATION_1_STATION_1_SWITCH_7	CLOSED	13.8	200.00	200.00	200.00	SWITCH_X_Y	
	SWITCH_8	STATION_1	STATION_1_STATION_1_SWITCH_8	CLOSED	13.8	200.00	200.00	200.00	TRANSFORMER_1	
CHANGE	SWITCH_9	STATION_1	STATION_1_STATION_1_SWITCH_9	CLOSED	13.8	200.00	200.00	200.00	TRANSFORMER_2	
CHANGE	SWITCH_10	STATION_1	STATION_1_STATION_1_SWITCH_10	CLOSED	13.8	200.00	200.00	200.00	CAPACITOR_1	
CHANGE	BREAKER_X_Y	STATION_1	STATION_1_STATION_1_BREAKER_X_Y	CLOSED	13.8	200.00	200.00	200.00	CAPACITOR_2	
	BREAKER_A_B	STATION_1	STATION_1_STATION_1_BREAKER_A_B	CLOSED	13.8	200.00	200.00	200.00	REACTOR_1	SWITC
	BREAKER_C_D	STATION_1	STATION_1_STATION_1_BREAKER_C_D	OPEN	13.8	200.00	200.00	200.00	REACTOR_2	
CHANGE	SWITCH_X_Y	STATION_1	STATION_1_STATION_1_SWITCH_X_Y	CLOSED	13.8	200.00	200.00	200.00	LINE_1	
	SWITCH_A_B	STATION_1	STATION_1_STATION_1_SWITCH_A_B	CLOSED	13.8	200.00	200.00	200.00	LINE_2	
	SWITCH_C_D	STATION_1	STATION_1_STATION_1_SWITCH_C_D	CLOSED	13.8	200.00	200.00	200.00	STATIC_VAR_1	
	BREAKER_E_F	STATION_1	STATION_1_STATION_1_BREAKER_E_F	CLOSED	13.8	200.00	200.00	200.00	STATIC_VAR_2	
CHANGE	BREAKER_G_H	STATION_1	STATION_1_STATION_1_BREAKER_G_H	CLOSED	13.8	200.00	200.00	200.00	LOAD_1	
CHANGE	BREAKER_I_J	STATION_1	STATION_1_STATION_1_BREAKER_I_J	OPEN	13.8	200.00	200.00	200.00	LOAD_2	SWITC
	SWITCH_E_F	STATION_1	STATION_1_STATION_1_SWITCH_E_F	CLOSED	13.8	200.00	200.00	200.00	SWITCH_X_Y	
	SWITCH_G_H	STATION_1	STATION_1_STATION_1_SWITCH_G_H	CLOSED	13.8	200.00	200.00	200.00	BREAKER_5	
CHANGE	SWITCH_I_J	STATION_1	STATION_1_STATION_1_SWITCH_I_J	CLOSED	13.8	200.00	200.00	200.00	SWITCH_8	SWITC

[Line Data](#)
[Line Temperature](#)
[Most Limiting Series Element](#)
[Breaker\\_Switch Data](#)
[Capacitor and Reactor Data](#)
[Transformer Data](#)
[Transformer Tap Settings](#)
[Static\\_Var\\_Compensator Data](#)
[Series Device Data](#)
[Load data](#)
[PUN\\_LOAD](#)
[One Line](#)
[Tran ...](#)



Connection Error

Error at Site :  
All Terminals not defined for : SW-BT1: [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
All Terminals not defined for : SW-3: [2= [SW-1, SW-2]]  
Item referenced but not documented : SW-BT1 : [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
Item referenced but not documented : SW-BT1 : [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
Item referenced but not documented : 52-PSEUDO1 : [2= [UNIT1, 1= [52-PSEUDO2, LOAD1, SW-BT1, SW-C1, SW-T1]]]  
Item referenced but not documented : 52-PSEUDO2 : [2= [UNIT2, 1= [52-PSEUDO1, LOAD1, SW-BT1, SW-C1, SW-T1]]]  
Item referenced but not documented : LOAD1 : [LOAD= [52-PSEUDO1, 52-PSEUDO2, SW-C1, SW-T1, SW-T1]]  
Item referenced but not documented : SW-C1 : [2= [52-C1], 1= [SW-T1, 52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-BT1]]  
Item referenced but not documented : SW-T1 : [2= [52-PSEUDO1, 52-PSEUDO2, 1= [C1, SW-BT1, SW-C1], 1= [T1]]]  
Item referenced but not documented : SW-BT1 : [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
Item referenced but not documented : SW-1 : [2= [SW-2, SW-3], 1= [ ]]  
Item referenced but not documented : SW-2 : [2= [52-T1], 1= [SW-1, SW-3]]  
Item referenced but not documented : SW-BT1 : [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
Item referenced but not documented : SW-3 : [2= [SW-1, SW-2]]  
Item referenced but not documented : SW-3 : [2= [SW-1, SW-2]]  
Item referenced but not documented : SW-BT1 : [2= [52-PSEUDO1, 52-PSEUDO2, LOAD1, SW-C1, SW-T1]]  
Transformer Node : T1[XFORM Maybe missing connection point, Possible connection points : 52-T1]

OK



# Resource Integration and Ongoing Operations - Resource Services

BigSky Solar

RI00

Resource Svc

Breaker Switch

Category

Category

Category

Category

Sub Category

Sub Category

Sub Category

Sub Category

Sub Category

Breaker Switch Details

Technology1

Technology 2

Add a New Breaker Switch

New

Unit : Unit Name

Prod Load: 10-31-2019

All fields are required unless marked optional

Breaker / Switch

Switch Name

e.g. a circuit breaker

Is this a fault isolating device?

☐ Yes
☐ No

What is the normal operating status when in-service?

☐ Open
☐ Closed

Voltage Level in kV

Static Ratings for Planning in MVA

Continuous Rating

2-hr Emergency Rating

15 Min Rating

Modify

Unit : Unit Name

Show More

Prod Load: 10-31-2019

RI00-RS

Breaker / Switch

Switch Name

e.g. a circuit breaker

Is this a fault isolating device?

☐ Yes
☐ No

What is the normal operating status when in-service?

☐ Open
☐ Closed

Voltage Level in kV

Static Ratings for Planning in MVA

Continuous Rating

2-hr Emergency Rating

15 Min Rating

Modify

Unit : Unit Name

Show More

Request Prod Load: 10-31-2019

RI00-RS

Existing Change Requests

8-1-2019

Breaker / Switch

Name

e.g. a circuit breaker

Is this a fault Isolating device?

☐ Yes
☐ No

What is the normal operating status when in-service?

☐ Open
☐ Closed

Voltage Level in kV

Static Ratings for Planning in MVA

Continuous Rating

2-hr Emergency Rating

15 Min Rating