

Inverter-Based Resource Workshop Follow Up Update

ROS November 7, 2019

Inverter-Based Resource Workshop Follow Up Status Dashboard

| Issues | Status (Tentative Schedule) | Workgroups | Target Dates |
|--|--|--|---|
| Better Communication of Existing Requirements | Develop a reference document to facilitate the understanding of the existing requirements, procedures, and practices. (Q4, 2019) Consider a NPRR on IBR definition. (Q4, 2019) | Resource Integration Workshop (RIW) Resource Definition Task Force (RTF) | RIW (9/26/2019, 11/21/2019) To be included in the DGR NPRR |
| Nuisance Tripping and Artificially Limiting Plant Capability | Continue discussion on this topic. | | No scheduled activity |
| Voltage Ride Through and Momentary Cessation | Consider a NOGRR to clarify VRT and momentary cessation (Q3, 2019) Consider a NOGRR to add transient overvoltage ride through requirement (Q1, 2020) Identify the need of more detailed FIS stability analysis (like PSCAD study) (Q1, 2020) | Dynamics Working Group (DWG) DWG | DWG (8/27/2019, 11/20/2019) |
| Dynamic Models | Consider a PGRR to improve dynamic model quality (Q3, 2019) => PGRR075 To strengthen the model validation requirements (Q4, 2019) | DWG, RIW | RIW (6/20/2019, 7/30/2019, 9/26/2019) DWG (8/27/2019, 11/20/2019) |
| Battery Energy Storage Operational Requirements | Develop requirements for battery energy storage (Q1, 2020) (Will be covered in the BESTF) | ROS, RIW | ROS (Covered in BESTF) |
| Advanced Features and Others | Continue discussion on this topic. Zero MW reactive support | | No scheduled activity |



Dynamic Models – Generic and User Defined Models (UDM)

 Total of 62 IRR sites are now using generic models – about half of these sites have recently switched from UDM to generic models

| Dynamic Model | | Generic |
|---|-----|---------|
| Compatible with different PSS/e version | No | Yes |
| Maintenance Cost for different PSS/e version | | No |
| Open format, good documentation, and clear model implementation | | Yes |
| Vetted by OEMs | Yes | ? |

- Observations from provided generic IRR models:
 - Generic models contain approximations
 - Generic models may not function well under weak grid
 - Could result in instability (numerical or real?) in the ERCOT studies and potentially lower the stability limits
 - MOD26/27 is to validate an existing model, not sufficient to create a new model



Dynamic Models – Generic and User Defined Models (UDM)

- ERCOT will explore the options to ensure the model quality and accuracy
 - All the models should undergo a standard set of model quality tests (PGRR075)
 - Should all the models be reviewed and approved by the manufactures?
 - Should all the models be benchmarked with OEM provided PSCAD model?



Questions

Comments are welcome

Shun Hsien (Fred) Huang shuang@ercot.com

