Recent Valley GTC Updates




ROS Meeting 12/03/2020

Transmission Operations Planning

GTCs in the Valley Region prior to the GTC Updates

• 5 GTCs in the Valley region: 4 Export + 1 Import




Valley Import GTC (345kV & 138kV)

ercot 😓

For visualization purposes only. Does not represent exact study area boundaries or GTC interface.

Recent GTC Updates in the Valley Region (Nov. 2020)

- Update Lobo & Ajo GTL table with the same GTC interface
- Add Valley Export GTC (the same interface as Valley Import)
- Add Zapata Starr GTC



Why to update Valley GTCs

- Many new GRs (all WGRs) are connecting to the Valley region and most of them are outside Ajo and Lobo GTCs
 - 2020 Q2 QSA: 376MW
 - 2020 Q3 QSA: 538MW
 - 2020 Q4 QSA: 410MW (210MW inside Lobo GTC)
 - Total: ~1300MW
- The Stability issue (dynamic voltage stability) has shifted from local stability to regional stability in most of the operational conditions
- Existing Ajo and Lobo GTCs are insufficient to manage the regional stability
- There is a need of GTC updates to manage the regional stability





Dynamic Voltage Stability Issues

Oscillatory response, voltage collapse and unacceptable voltage recovery 1.1

1.1

0.9








GTC Option #1 Greater Valley Export GTC

- Works well under no-prior outage and prior outages that Valley still remains intact
 - Challenging to deal with non-uniform dispatch
- Challenging to deal with prior outages with Valley divided into two parts
- Nested GTC may be needed




For visualization purposes only. Does not represent exact study area boundaries or GTC interface.

erco

GTC Option #2 Lower Valley Export GTC

- A new Valley Export GTC (the same interface as Valley Import GTC) was proposed to work with Ajo and Lobo GTCs to deal with the regional stability
 - Properly manage non-uniform dispatch
 - Properly manage the situation when Valley is divided into two parts





Ajo GTC

Valley Export GTC

For visualization purposes only. Does not represent exact study area boundaries or GTC interface.




PUBLIC

GTC Option #2 Lower Valley Export GTC

- GTC Methodology:
 - For no-prior outage and prior outages related to regional stability, limit 3 GTCs output all together (assume uniform dispatch for all the renewables in 3 GTC areas)






Valley Export GTC

For visualization purposes only. Does not represent exact study area boundaries or GTC interface.



GTC Option #2 Lower Valley Export GTC

- GTC Methodology:
 - For prior outages related to local stability, limit the local GTC output; the other GTC areas are still subject to the no prior outage GTLs



GTC Study Case and Results

- Based on 2020 Q4 QSA study case (HWLL)
 - Valley thermal units dispatched at ~200MW
 - Valley load: ~900MW
- No prior outage GTLs (GTC interface flow limits)
 - Ajo: 906MW
 - Lobo:1426MW
 - Valley Export: 652MW
 - Sum of 3 GTLs: ~3000MW
- Prior outage GTLs available in the GTC methodology documents at ERCOT MIS




Comparison with Previous GTLs

- Total GTL of Ajo and Lobo remains almost the same for noprior outage condition as the previous GTL:
 - Ajo: 906MW (current) vs 1098MW(previous)
 - Lobo: 1426MW (current) vs 1283 (previous)
 - Ajo and Lobo GTLs (no-prior outage) are proportional to the WGR installed capacity
- Significant increase for both Ajo and Lobo GTLs under many prior outage conditions, for example:
 - Ajo GTL (Ajo Nelson Sharpe 345 kV prior outage)
 - 583MW (current) vs 128MW(previous)
 - Lobo GTL (N. Edinburg Lon Hill 345 kV prior outage)
 - 1023MW (current) vs 550MW(previous)
 - It is because of the proposed GTC methodology



Historical Flow on Valley Export GTC Interface

- Highest monthly flow on the Valley Export GTC interface
 - 12 hours of flow exceeding 652MW (2019/1 2020/10)



Moving Forward

- The Valley GTCs (Ajo, Lobo and Valley Export) definitions are subject to future change with additional generation capacity and transmission upgrade.
- The Valley GTCs (Ajo, Lobo and Valley Export) interfaces may be more efficient once online TSAT is available and will be revisited at that time.

