

# **NDSWG Report to ROS**

## **November 2021**

**Chair: J-M Yatar, Vice-Chair: Kenesha King**

**NDSWG last met on October 19, 2021 (Webex)**

### **Discussion/Review Items:**

#### **Derating Lines for Temporary Configurations (NMMS)**

-CRR requesting new process for line derates to better reflect actual line ratings in future studies

##### **-Option 1**

TSPs to submit two NOMCRs, to derate and restore

##### **-Option 2**

Checkbox to identify if lower ratings are temporary

##### **-Option 3**

New entry field for expected end date of lower rating

##### **-Option 4**

Modify Outage Scheduler to include ratings changes

##### **-Option 5**

Keep current process

#### **New NMMS Validation Rule**

-All modeled transformers to have impedance information in 1 winding only instead of 2 windings

-Request will be sent out to TSPs to fix existing transformers, TSPs to submit NOMCR to correct

## **ICCP Handbook Review**

- Completed review for language that's possibly binding
- May need to change language in ERCOT Protocols/Guides
- Check with ERCOT Compliance for binding language in other documents
- Further discussion if document needs to become binding

**Future NDSWG meeting: November 15, 2021 (Webex)**