



Minimum Deliverability Criteria Thresholds

Version 1.0

Document Revisions

Date	Version	Description	Author(s)
06/28/2022	1.0	Initial version	ERCOT Grid Planning

1. Background

The purpose of this document is to satisfy the ERCOT Planning Guide posting requirements outlined in paragraph (5)(a) of Section 4.1.1.7, Minimum Deliverability Criteria.

2. Thresholds Approved by the ERCOT Board

At the time this document was prepared, the ERCOT Board approved thresholds for the minimum deliverability criteria are listed below.

1. The minimum percentage of capacity is set to 100%
2. The minimum duration threshold for Energy Storage Resources (ESRs) is set to 2 hours; and lower duration Resources will be prorated to their continuous real power capability for 2 hours