



IEEE P2800 Perspective

08 July 2022

Table of content / Agenda

1 Introduction

2 Ambiguities in the standard

3 Wind Turbines Design/Production Cycle

4 Status of the Turbines in the Market

5 Conclusion



Introduction

IEEE Standard for Interconnection and Interoperability of Inverter-Based Resources (IBRs) Interconnecting with Associated Transmission Electric Power Systems.

- SGRE has been an active participant as a voting member throughout the initiation/evolution of P2800, including P2800-2.
- As such, SGRE welcomes/encourages the adaption of the standard.
 - Performance specific to the technology (DFIGs Vs Full converters)
 - Easier on OEMs (need to comply with one universal standard)
- Currently, requirement without guidance : Guidance to be addressed on 2800-2
- Applicable on the High Side of MPT/POI: How does that translate to the Generator Terminal?
- Some requirements are impossible to confirm with a regular testing set-up.



Items to be clarified

- Precise testing requirements is essential
 - Ability to withstand multiple dips (Consecutive voltage deviation ride-through capabilities)
 - X numbers within X seconds → Multiple possible combinations. Some are detrimental to the integrity of converters.
 - Transient Overvoltage ride through ($V > 1.7$ p.u. for 0.2 ms)
 - Typical reaction time < 10 ms

New WTGs Design/Production Cycle

- New WTGs typically have Four (4) years of design/production cycle.
 - New converter and/or rotor.
 - Typical lead time at around 2 yrs (for both new products and existing ones)
 - Turbines that are going to be commissioned in next two years would have been the ones that have already been sold/selling now.
 - For New Turbines not all the tests can be completed before commissioning.
 - Internal tests, Simulation etc before a certification from third party?

Status of the Turbine in the Market

- New WTGs
 - Getting energized in next two years.
 - Design, prototype, and major testing already completed/planned.
 - Extremely difficult to go back to the drawing board.
 - Gap analysis on-going.
 - Note that lots of projects come online towards the end of CY, due to the PTC
 - Getting energized after CY 2025
 - Design on-going. Will be able to meet/self certify the requirements as listed in the standard
- Existing/Mature WTGs
 - Actively being sold now and have been producing for a while.
 - Gap analysis on-going.

Status of the Turbine in the Market

- Safe Harbor Units
 - Sold couple of years ago with the technology that was available then.
 - We estimate that across all OEM's there are around 1.5 GW of non-energized SH turbines that were built between 2016-2021.
 - Will not be able to meet the new requirements.
 - Also, the PTC continuity windows are all running out Dec 31, 2025 - so if no changes are made in legislation, then majority SH should be used up not later than 2025.
- Repowering units
 - Majority of repowering projects retain the same original converter with slight modification to accommodate new rotors.
 - Cross-OEMs (one OEM repowering other OEM's original turbines)
 - Includes OEMs that are no longer active
 - Will not be able to meet new requirements.

Summary



SGRE welcomes/recommends implementation of P2800

- However, requirement without guidance creates a lot of confusion
 - Entities should be aware of the testing limitation until P2800-2 is approved.
 - Reference Point of Applicability (RPA) should be considered.
-
- SGREs new products will be fully compliant with P2800 performance requirement
 - Gap analysis on-going for existing products.
-
- SGRE encourages RTO's to consider the Safe Harbor units and Repowering units while adopting the requirements.
-



Thank you!

Samir Dahal
Global Engineering
samir.dahal@siemensgamesa.com