



**The Reliability and Markets (R&M) Committee
is expected to consider
R&M Committee Agenda Item 14:**

***Recommendation regarding
2024 ERCOT Methodologies for Determining
Minimum Ancillary Service Requirements***

at its meeting on December 18-19, 2023.

**The Board of Directors is expected to hear
the R&M Committee's recommendation on
this matter at the Board meeting on
December 19, 2023.**

**Attached are the Board and Committee
materials in relation to these agenda items.**



Date: December 12, 2023
To: ERCOT Board of Directors
From: Dan Woodfin, Vice President, System Operations
Subject: 2024 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements

Issue for the ERCOT Board of Directors

ERCOT Board of Directors Meeting Date: December 19, 2023

Item No.: 14.1

Issue:

Whether the Board of Directors (Board) of Electric Reliability Council of Texas, Inc. (ERCOT) should approve the proposed 2024 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements (2024 AS Methodology) as presented herein, to be effective January 1, 2024.

Background/History:

Ancillary Services are necessary to maintain the reliability of the ERCOT System. The ERCOT Protocols define these Ancillary Services and charge ERCOT with determining a methodology for the minimum levels of Ancillary Services required. Paragraph (2) of Protocol Section 3.16 requires ERCOT to review the methodology at least annually, and paragraph (3) of Section 3.16 requires the Board to review and approve ERCOT's methodology.

ERCOT staff previously presented the 2023 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements (2023 AS Methodology) to the Board on December 20, 2022, which the Board approved to be effective January 1, 2023 as requested.

The primary changes for the 2024 AS Methodology in comparison to 2023 AS Methodology are related to Responsive Reserve Service, ERCOT Contingency Reserve Service (ECRS) and Non-Spinning Reserve (Non-Spin) Service. No change has been proposed to the methodology used to compute Regulation Service. The changes that are shown in red-line in **Attachment A** and can be summarized as follows:

- Regulation Service
 - No change—*i.e.*, same methodology as approved on December 20, 2022.
 - Updates to Wind Adjustment tables and Solar Adjustment tables that track the incremental effects of increases in installed wind and solar capacity, respectively, on Regulation Service quantities.
- Responsive Reserve Service
 - Remove 2,800 MW floor during the peak hours.
- ERCOT Contingency Reserve Service

- A floor on the percentile coverage for sunset hours such that the ECRS requirements for these hours are determined using at least 90th percentile of historical intra-hour net load uncertainty.
- Change the frequency recovery related computations such that ECRS requirements are determined using 2 years of historic information, cover 60% of historic net load and inertia conditions and account for Regulation requirement in the hour.
- Updates to Solar Intra-Hour Over-Forecast Error Adjustment Table that tracks the estimated increase in intra-hour solar over-forecast error per 1,000 MW increase in the installed solar capacity.
- Non-Spinning Reserve Service
 - Change the percentile coverage for HE23 to HE02 in Winter and HE23 to HE06 rest of the year such that Non-Spin requirements for these hours is determined using 68th percentile of historical hourly net load forecast uncertainty.
 - Updates to Wind Over-Forecast Error Adjustment Table and Solar Over-Forecast Error Adjustment Table that track estimated increase in over-forecast error per 1,000 MW increase in installed wind and solar capacity, respectively.
 - Updates to Intra-day Forced Outage table that tracks incremental increase in Non-Spin needed to account for intra-day forced outages of thermal resources.

In addition to the changes proposed in 2024 AS Methodology as outlined above, **Attachment A** updates the minimum level of RRS from Resources providing RRS using Primary Frequency Response to 1,185 MW.

On December 4, 2023, the Technical Advisory Committee (TAC) endorsed the proposed 2024 AS Methodology, with an effective date of January 1, 2024. The Reliability and Markets (R&M) Committee is expected to review the proposed 2024 AS Methodology at its meeting on December 18-19, 2023, and is expected to recommend that the Board approve the proposed 2024 AS Methodology.

Key Factors Influencing Issue:

Regulation Service: The proposed changes to the Wind Adjustment tables and Solar Adjustment tables used to add incremental amounts of Regulation Service quantities are part of a routine update that ERCOT makes annually based on anticipated growth in installed wind and solar generation, respectively in 2024. Further, to better reflect the balancing needs in the historic Net Load variability that is used in the methodology, its calculation will be updated to include additional accounting based on accumulated Area Control Error (ACE).

Responsive Reserve Service: The 2,800 MW floor during peak hours was included in 2022 to provide additional RRS quantities that will help maintain an increased operating margin measured as Physical Responsive Capability (PRC) in Real Time. The

implementation of NPPR 989 that improved accounting of PRC from Energy Storage Resources (ESRs) and the recent implementation of ERCOT Contingency Reserve Service (ECRS) are helping in maintaining PRC at sufficient levels during peak hours. With these, the 2,800 MW floor during peak hours is not needed and hence is being removed. Note that a minimum of 2,300 MW of RRS will continue to be procured in all hours.

ERCOT Contingency Reserve Service: ECRS quantities are computed as sum of capacity needed to recover frequency following a large unit trip and capacity needed to support intra-hour net load forecast errors. ERCOT has seen significant growth in installed solar capacity from one year to the next. With the growth in solar resources, peak net load (load – wind – solar) have shifted to occur just after sunsets. The proposed change to set ECRS requirements for sunset hours using at least 90th percentile of historical intra-hour net load uncertainty will ensure that reliability risks during these hours will be appropriately captured in the ECRS requirements for the sunset hours. Further, the proposed adjustments in frequency recovery related calculations in the ECRS methodology (a) make the historic information used consistent with the RRS and (b) improve accounting of risks of large units trips and large net load uncertainties occurring simultaneously.

The proposed changes to the Solar Intra-Hour Over-Forecast Error Adjustment table used to add incremental amounts of ECRS quantities are part of a routine update that ERCOT makes annually and are based on a projected increase in over-forecast error due to the anticipated growth in installed wind and solar generation, respectively in 2024.

Non-Spinning Reserve Service: The reliability risks that may require Non-Spin deployment are typically lower during HE23 to HE02 in Winter and HE23 to HE06 rest of year tighter grid operating conditions. The proposed 68th percentile approach for computing Non-Spin quantities in these hours better reflects the reliability risks associated with these hours.

The proposed changes to the Wind Over-Forecast Adjustment table and Solar Over-Forecast Adjustment table used to add incremental amounts of Non-Spin quantities are part of a routine update that ERCOT makes annually and are based on a projected increase in over-forecast error due to the anticipated growth in installed wind and solar generation, respectively in 2024. Similarly, the proposed changes to the Intra-day Forced Outage table used to add incremental amounts of Non-Spin quantities are part of a routine update that ERCOT makes annually as well and are based on forced outage data from thermal resources in 2023.

These changes were endorsed by the Reliability and Operations Subcommittee (ROS), Wholesale Markets Subcommittee (WMS) and TAC.

Conclusion/Recommendation:

ERCOT staff recommends, and the R&M Committee is expected to recommend, that the Board approve the proposed 2024 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements, attached as **Attachment A**, as endorsed by TAC, to be effective January 1, 2024.



ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC.
BOARD OF DIRECTORS RESOLUTION

WHEREAS, Protocol Section 3.16 requires that the Board of Directors (Board) of Electric Reliability Council of Texas, Inc. (ERCOT), at least annually, review and approve the deems it desirable and in the best interest of ERCOT to annually review the ERCOT Methodologies for Determining Minimum Ancillary Service Requirements;

WHEREAS, the Reliability and Markets (R&M) Committee has reviewed the 2024 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements (2024 AS Methodology) recommended by ERCOT staff and as endorsed by the Technical Advisory Committee (TAC), as set forth in **Attachment A**, to be effective on January 1, 2024, and has recommended that the Board approve the 2024 AS Methodology; and

WHEREAS, after due consideration of the alternatives, the Board deems it desirable and in the best interest of ERCOT to approve the 2024 AS Methodology as recommended by the R&M Committee; and

THEREFORE, BE IT RESOLVED, that ERCOT is hereby authorized and approved to implement the 2024 AS Methodology, as set forth in **Attachment A**, as recommended by the R&M Committee and as endorsed by TAC, to be effective on January 1, 2024.

CORPORATE SECRETARY'S CERTIFICATE

I, Jonathan M. Levine, Assistant Corporate Secretary of ERCOT, do hereby certify that, at its December 19, 2023 meeting, the Board passed a motion approving the above Resolution by _____.

IN WITNESS WHEREOF, I have hereunto set my hand this ____ day of December, 2023.

Jonathan M. Levine
Assistant Corporate Secretary

ERCOT Methodologies for Determining Minimum Ancillary Service Requirements

ERCOT Board approved on ~~12XX/20XX/2022XXXX~~

Effective Date of ~~61/19/20234~~

Style Definition: TOC 3: Tab stops: 6.49", Right,Leader: ...

TABLE OF CONTENTS

INTRODUCTION	2
REGULATION SERVICE REQUIREMENT DETAILS	3
NON-SPINNING RESERVE (NON-SPIN) REQUIREMENT DETAILS.....	9
RESPONSIVE RESERVE (RRS) REQUIREMENT DETAILS.....	15
ERCOT CONTINGENCY RESERVE SERVICE (ECRS) DETAILS	16

Introduction

Paragraph (2) of Protocol Section 3.16, Standards for Determining Ancillary Service Quantities, requires that methodologies for determining the amounts of Ancillary Services to be required by ERCOT must be developed at least annually. Paragraph (3) of Protocol Section 3.16 requires approval of this methodology by the ERCOT Board of Directors.

This document discusses the various Ancillary Services for which requirements are to be developed. Further, detailed methodologies for determining those requirements are included as part of this document.

Specifically, methodologies are required for the determination of the quantities of Regulation Service, ERCOT Contingency Reserve Service (ECRS), Non-Spinning Reserve (Non-Spin) and Responsive Reserve (RRS) that are required to maintain system reliability. Those procedures are discussed below.

These procedures are intended for determining each of the Ancillary Service requirements for all months of the upcoming year. This procedure will be performed annually. The Ancillary Service requirements are determined annually and will be posted to the Market Information System (MIS) by December 20th for the upcoming year. If necessary, any additional incremental adjustment to the posted Ancillary Service requirements for a particular month will be made using this procedure and will be posted to the MIS prior to the 20th of each month for the upcoming month. If the Ancillary Service requirements identified through this process for a particular operating day are found to be insufficient based on the expected operating conditions for that day, ERCOT may make an updated Ancillary Service requirements posting for that day if the need for incremental adjustments is identified day-ahead and may use the Supplemental Ancillary Service Market (SASM) process for similar adjustments made closer to Real-Time. For any additional months for which ERCOT is required to provide an Ancillary Service requirement forecast, the forecasted requirement will be set to the historical requirement for the same month of the previous year.

Regulation Service Requirement Details

Introduction

Regulation Service consists of resources that can be deployed by ERCOT in response to changes in ERCOT System frequency to maintain the target ERCOT System frequency within predetermined limits according to the Operating Guides. ERCOT is required to evaluate normal requirements for Reg-Up Service and Reg-Down Service on an annual basis. It is ERCOT's practice to use historical rates of Regulation Service usage to perform evaluation and determine the required quantities for this service. Regulation Service is deployed in order to correct actual frequency to scheduled frequency and to ensure North American Electric Reliability Corporation (NERC) requirements are met.

Summary

The Regulation Service requirements are calculated with the expectation that sufficient Regulation Service will be available to cover the 95th percentile of deployed regulation or net load variability. An adjustment may also be made based on historic CPS1 performance.

Procedure

To evaluate Regulation Service requirements, ERCOT will collect historical Resource Registration information, CPS1 data, Regulation Service deployment data, aggregate output data, and ERCOT system load data. For determining the base Reg-Up requirements for a particular hour, ERCOT will take the largest of the 95th percentile of Reg-Up deployments for the same month of the previous two years, and the 95th percentile of the positive net load (load – wind – solar) changes for the same month of the previous two years. For determining the base Reg-Down requirements, ERCOT will take the largest of the 95th percentile of Reg-Down deployments for the same month of the previous two years and the 95th percentile of the negative net load (load – wind – solar) changes for the same month of the previous two years. To better reflect balancing needs within the hours, the net load variability may be updated to account for accumulated Area Control Error (ACE).

In order to consider the increased amount of wind and solar penetration, ERCOT will calculate the increase in installed wind and solar generation capacity, respectively. Then, depending on the month of the year and the hour of the day, ERCOT will add incremental MWs that are derived using the wind and solar adjustment tables and associated increase in wind and solar generation capacity, to the maximum values determined above. The wind and solar adjustment tables for incremental MWs for Reg-Up and Reg-Down come from the study ERCOT performs annually, using similar techniques as the 2008 GE wind study, but using actual wind and solar data respectively. The increase in wind (or solar) generation capacity will be calculated by taking the total nameplate capacity of wind (or solar) resources in the ERCOT network model at the time of the procurement study and subtracting out the total nameplate capacity of wind (or solar) resources in the ERCOT model at the end of the month being studied from the previous year.

ERCOT will post these monthly amounts for Regulation Service requirements for the upcoming year on the MIS.

If any incremental changes to the annually posted amounts are needed then the revised amounts for the following month will be posted to the MIS prior to the 20th of the current month. ERCOT

Attachment A

may include adjustments for hours in a month considering monthly average for CPS1 and 12-month rolling average CPS1 scores. If it is determined that during the course of the year that the ERCOT monthly average for CPS1 score was less than 140% for a specific month, ERCOT will apply an extra 10% of both Reg-Up and Reg-Down for hours in which the CPS1 score was less than 140%. Additionally, if the ERCOT 12-month rolling average CPS1 score is less than 140%, for the next month ERCOT will procure an extra 10% of both Reg-Up and Reg-Down for hours in which the hourly CPS1 score was less than 140%. This value will increase to 20% if the CPS1 score falls below 100%.

DRAFT

Attachment A

Incremental MW Adjustment to Prior-Year Up-Regulation Value, per 1000 MW of Incremental Wind Generation Capacity, to Account for Wind Capacity Growth																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	1.31-0.3	0.71-0.2	1.31-0.4	1.11-0.6	2.11-0.8	1.31-0.0	1.21-0.8	1.31-0.8	4.13-1.3	3.82-1.1	1.01-0.2	0.91-0.4	1.51-0.5	1.91-0.7	1.11-0.7	1.41-0.8	2.42-0.6	1.82-0.6	-0.5-0.9	-0.7-0.8	=0.30-0.6	0.01-0.4	0.00-0.5	0.00-0.7
Feb.	0.71-0.9	0.81-0.4	1.41-0.3	0.71-0.2	1.01-0.5	1.41-0.2	1.11-0.0	1.91-0.6	3.52-0.4	3.32-1.2	2.21-0.3	1.71-0.5	2.02-1.1	1.12-0.4	0.22-0.2	1.12-1.1	0.52-0.4	2.41-0.9	0.60-0.3	-1.4-0.2	=0.50-0.6	=0.71-1.1	=0.21-0.2	0.21-0.6
Mar.	1.31-0.6	0.61-0.7	1.01-0.7	0.61-0.7	0.61-0.7	1.32-0.1	1.42-0.1	1.42-0.8	5.13-0.7	4.02-0.8	1.42-0.3	2.42-0.4	3.02-0.5	1.12-0.7	1.32-0.2	1.31-0.9	1.71-0.9	3.11-0.5	2.71-1.1	2.91-0.0	0.90-0.8	0.10-0.4	0.30-0.5	0.50-0.8
Apr.	=0.30-0.9	0.01-0.4	0.91-0.7	1.21-0.8	1.11-0.8	0.91-0.7	1.32-0.2	2.13-0.3	3.33-0.9	0.52-1.2	2.22-0.7	3.02-0.9	4.32-0.8	2.92-0.8	2.51-0.7	1.01-0.2	0.90-0.9	1.20-0.9	1.31-0.4	2.61-0.5	0.71-0.3	=0.10-0.6	=0.10-0.6	=0.31-1.1
May	0.22-0.2	0.81-0.7	0.62-0.6	1.72-0.8	1.63-0.3	3.22-0.3	1.42-0.4	3.73-0.2	3.92-0.5	1.81-0.3	3.32-0.6	3.72-0.7	2.62-0.5	2.62-0.8	0.31-0.7	1.00-0.5	0.10-0.0	0.3-0.2	0.40-0.2	1.00-0.6	1.11-0.0	=0.20-0.4	0.00-0.6	0.01-0.3
Jun.	0.20-0.3	0.31-1.0	0.62-0.2	1.62-0.6	2.03-1.2	2.12-0.7	2.72-0.6	6.54-1.2	2.33-0.2	1.42-1.2	2.93-1.4	2.22-0.6	3.21-0.6	1.41-0.3	0.00-0.9	0.10-1.1	-0.1-0.2	-0.2-0.3	-0.1-0.2	0.00-1.1	0.3-0.2	-0.4-0.3	0.00-1.1	0.00-0.3
Jul.	0.10-0.5	0.20-0.5	1.01-0.2	1.71-0.7	1.62-0.2	2.72-0.2	2.52-0.2	6.34-0.0	2.03-0.8	2.31-0.4	5.12-0.7	4.32-0.7	2.41-0.3	0.30-0.4	-0.2-0.2	-0.6-0.3	=0.20-1.1	=0.20-0.3	=0.60-0.4	=0.10-0.5	0.9-0.1	-0.1-0.4	0.0-0.1	0.0-0.1
Aug.	0.70-0.4	0.80-0.5	1.01-1.1	1.11-0.5	1.92-0.1	1.42-1.1	0.72-1.5	5.03-0.9	4.25-0.0	0.51-0.3	3.02-0.3	3.23-0.2	1.32-1.1	0.30-0.5	-0.8-0.4	-0.7-0.5	0.0-0.4	-0.2-0.4	=0.30-0.3	0.40-0.4	0.9-0.1	-0.1-0.1	0.00-0.0	0.00-0.0
Sep.	=0.10-0.3	0.50-0.7	0.91-1.1	1.51-0.6	1.52-0.2	2.12-0.2	1.32-0.0	2.33-1.6	6.46-0.3	2.33-0.5	1.52-1.1	1.82-0.8	1.12-1.1	0.40-0.8	0.80-0.4	=0.90-0.5	=0.20-0.4	=0.50-0.6	0.30-1.1	0.1-0.4	-0.8-0.5	-0.4-0.1	0.00-0.0	0.00-0.0
Oct.	=0.30-0.7	0.40-0.6	1.61-0.0	1.31-0.2	1.51-0.7	1.12-0.2	1.32-0.4	1.62-0.3	4.95-0.4	5.04-0.3	0.21-0.6	0.91-0.9	0.71-0.8	0.80-0.7	0.10-0.2	=0.30-0.5	0.40-0.7	0.90-0.7	0.70-0.7	-1.0-0.3	-0.6-0.5	-0.2-0.1	=0.10-0.0	0.40-0.2
Nov.	0.50-0.3	1.20-0.3	1.50-0.8	1.01-0.3	0.91-0.7	0.51-0.8	2.82-0.3	3.12-0.9	3.25-0.5	1.34-0.2	0.42-1.0	0.12-0.5	0.42-0.2	0.51-0.3	0.60-0.8	1.21-0.0	1.61-0.4	0.70-1.1	0.4-0.8	-0.2-0.8	0.4-0.4	0.10-0.0	0.20-0.0	0.3-0.1
Dec.	0.50-0.7	0.00-0.5	1.51-1.1	1.52-0.2	1.12-1.1	1.02-0.0	0.81-0.9	1.22-0.6	2.74-0.9	2.25-1.0	0.51-0.0	0.71-0.3	0.30-0.8	0.81-0.3	0.91-0.7	0.81-0.5	2.32-0.0	1.1-0.3	-0.8-1.2	-0.2-0.5	0.0-0.1	0.40-0.5	0.10-0.5	0.40-0.3

Formatted Table

Attachment A

Incremental MW Adjustment to Prior-Year Down-Regulation Value, per 1000 MW of Incremental Wind Generation Capacity, to Account for Wind Capacity Growth

Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	0.81+4	1.60+7	1.00+7	0.8-0.3	0.30+2	=	=	=	-2.7-1.7	-3.3-1.2	1.51+5	2.61+2	1.21+0	1.20+9	1.11+5	1.20+8	0.91+2	0.71+0	5.93+9	3.83+8	3.42+6	2.31+8	1.63+3	1.51+4
Feb.	0.70+8	=	=	=	0.10+3	=	=	=	-4.8-0.9	-2.80+4	0.31+9	1.42+0	1.51+4	0.61+2	0.31+5	1.11+2	1.91+4	3.12+4	2.34+4	5.35+5	3.03+6	1.32+0	2.81+2	0.8-0.1
Mar.	0.12+8	0.30+2	1.1-0.2	1.1-0.2	0.50+1	0.10+1	0.00+1	=	-3.9-0.7	0.31+9	3.02+4	1.01+5	2.21+0	0.51+4	1.52+0	1.72+2	1.92+2	1.32+6	2.33+6	4.44+7	5.94+4	4.34+1	3.32+9	3.43+1
Apr.	1.21+1	0.40+0	-0.4-0.3	0.3-0.1	-0.2-0.2	-0.7-0.4	-0.4-0.1	-0.3-0.2	0.00+2	4.32+5	0.82+5	0.21+4	=	0.21+1	1.11+8	1.92+3	2.12+8	2.03+1	1.83+1	1.43+6	3.24+8	4.35+5	3.73+3	1.91+9
May	1.40+7	0.4-0.3	-0.4-0.9	-1.1-0.9	-0.2-0.6	-0.5-0.7	-0.9-0.3	-0.4-0.3	0.90+6	0.91+3	=	=	0.30+2	0.80+8	1.41+3	1.82+3	2.93+2	3.23+8	3.83+8	3.63+5	3.94+3	4.15+6	3.43+1	2.51+0
Jun.	1.10+9	0.1-0.1	-1.3-0.8	-2.1-1.5	-1.3-1.2	-1.4-1.0	-1.6-0.9	-1.0-0.9	0.70+2	0.10+3	=	0.0-0.1	0.2-0.2	0.70+1	1.20+6	1.81+6	2.62+5	2.73+1	2.73+4	2.33+0	2.53+8	5.45+8	4.03+5	2.11+9
Jul.	1.00+9	-0.8-0.7	-1.3-1.2	-1.5-1.6	-1.6-1.7	-2.5-1.5	-1.7-1.3	-1.4-1.0	0.60+0	0.00+2	0.0-0.1	0.0-0.2	-0.1-0.2	0.60+5	2.11+2	2.91+8	3.52+4	4.42+7	3.63+1	3.22+5	1.93+8	6.85+0	4.73+3	2.02+1
Aug.	0.40+5	-0.5-0.8	-0.9-1.3	-2.2-1.6	-1.2-1.6	-1.5-1.5	-1.0-1.3	-0.6-0.9	0.1-0.2	0.70+4	=	-0.3-0.1	0.40+0	0.81+0	2.01+8	2.72+2	2.82+9	2.63+2	3.43+1	2.22+2	2.84+8	4.84+6	2.73+1	1.31+6
Sep.	0.10+6	-1.4-0.6	-0.6-1.1	-1.2-1.3	-1.6-1.2	-1.0-1.3	-0.6-0.9	-0.8-0.6	-0.8-0.7	0.0-0.2	0.10+0	-0.1-0.2	0.1-0.1	0.10+7	1.01+7	1.11+8	1.92+2	2.22+8	2.33+3	2.84+8	6.47+2	5.15+2	3.42+7	1.50+8
Oct.	0.10+3	-0.6-0.5	-0.9-0.9	-0.5-0.9	-0.1-0.8	-0.5-0.8	-0.5-0.4	0.0-0.4	-1.2-1.1	-0.9-0.5	1.50+7	0.60+7	1.40+6	0.70+6	1.31+3	1.81+2	1.31+6	1.32+4	0.44+0	4.66+3	4.46+2	3.33+3	1.81+7	0.70+6
Nov.	=	0.00+1	-0.4-0.3	-0.7-0.2	-0.2-0.4	-0.4-0.4	-0.4-0.3	-1.0-0.7	-1.0-1.6	0.3-0.4	2.30+7	1.40+7	1.40+8	1.30+8	0.91+2	1.30+9	0.90+7	1.02+0	3.55+5	3.95+6	1.94+1	1.92+2	1.21+7	0.11+8
Dec.	=	=	=	0.3-0.3	0.4-0.6	0.2-0.2	0.70+4	0.40+4	-1.6-2.0	-0.2-0.9	2.01+1	2.20+7	0.41+6	=	0.31+7	0.31+5	0.10+9	0.71+0	4.16+0	2.13+6	1.72+9	1.92+3	1.01+9	0.32+7

Formatted Table

Incremental MW Adjustment to Prior-Year Up-Regulation Value, per 1000 MW of Incremental Solar Generation Capacity, to Account for Solar Capacity Growth																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	2.66-4	4.211-3	5.312-0	5.915-6	7.210-7	7.616-2	9.916-6	18.024-8	15.118-4	1.40-9	0.10-0	0.00-0	0.00-0	0.00-0	0.00-0
Feb.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.01-3	8.59-3	7.09-2	9.212-9	7.614-5	7.916-4	12.017-4	13.325-0	13.025-4	18.320-8	8.85-6	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0
Mar.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-4	8.68-3	8.611-6	10.615-2	12.317-1	13.419-2	13.219-2	15.920-7	15.521-2	17.223-6	16.620-6	11.711-7	0.10-0	0.00-0	0.00-0	0.00-0
Apr.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.10-0	7.110-5	9.49-2	10.110-7	9.812-8	10.210-9	8.610-0	11.414-0	13.819-3	15.817-5	15.623-0	14.514-8	1.81-4	0.00-0	0.00-0	0.00-0
May	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.13-9	3.813-3	6.212-5	7.511-8	6.68-7	6.910-2	8.114-5	8.613-2	10.812-9	12.316-8	10.517-9	11.713-4	4.66-4	0.00-0	0.00-0	0.00-0
Jun.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	3.78-9	3.06-1	3.05-9	4.47-6	6.67-4	5.48-9	6.312-9	11.015-8	8.017-1	10.217-5	12.517-9	6.28-5	0.00-0	0.00-0	0.00-0
Jul.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	2.87-2	1.45-6	3.35-5	4.510-2	4.68-1	7.29-6	6.611-8	7.013-5	9.513-7	9.414-3	12.116-3	6.28-2	0.00-0	0.00-0	0.00-0
Aug.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.55-0	4.15-8	4.77-8	5.79-6	6.311-0	6.612-0	8.312-3	8.911-3	8.515-8	10.415-1	11.114-3	3.33-2	0.00-0	0.00-0	0.00-0
Sep.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.83-4	3.95-4	4.18-5	5.29-3	6.011-6	7.412-2	6.912-3	7.210-8	9.515-7	13.915-5	8.08-1	0.00-3	0.00-0	0.00-0	0.00-0
Oct.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.13-8	4.37-0	5.97-3	6.26-0	5.96-2	8.47-0	9.912-2	11.513-0	14.315-0	14.012-8	0.81-9	0.10-0	0.00-0	0.00-0	0.00-0
Nov.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	1.41-8	4.75-9	5.65-5	8.57-2	8.95-4	8.05-1	9.410-0	11.08-2	14.318-1	8.88-8	5.60-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0
Dec.	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-2	4.95-5	6.18-1	5.38-9	6.94-9	6.99-2	8.212-1	10.115-9	13.618-0	7.610-0	0.10-0	0.00-0	0.00-0	0.00-0	0.00-0	0.00-0

Incremental MW Adjustment to Prior-Year Down-Regulation Value, per 1000 MW of Incremental Solar Generation Capacity, to Account for Solar Capacity Growth

Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>2.80-3</u>	<u>17.21</u> <u>5.6</u>	<u>11.122</u> <u>4</u>	<u>6.411</u> <u>8</u>	<u>5.315</u> <u>5</u>	<u>4.89-3</u>	<u>7.010</u> <u>6</u>	<u>6.312</u> <u>9</u>	<u>5.112</u> <u>6</u>	<u>2.78-9</u>	<u>0.0-</u> <u>2.1</u>	<u>0.0-</u> <u>0.4</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Feb.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>11.13</u> <u>0</u>	<u>19.72</u> <u>1.2</u>	<u>16.145</u> <u>4</u>	<u>8.613</u> <u>3</u>	<u>8.611</u> <u>8</u>	<u>8.413</u> <u>6</u>	<u>7.913</u> <u>1</u>	<u>9.515</u> <u>1</u>	<u>9.215</u> <u>5</u>	<u>8.517</u> <u>4</u>	<u>1.95-</u> <u>0</u>	<u>0.0-</u> <u>0.5</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Mar.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>13.34</u> <u>1</u>	<u>18.91</u> <u>4.1</u>	<u>13.120</u> <u>4</u>	<u>10.11</u> <u>4.3</u>	<u>11.41</u> <u>4.7</u>	<u>12.02</u> <u>0.6</u>	<u>12.91</u> <u>3.2</u>	<u>12.71</u> <u>5.2</u>	<u>11.51</u> <u>4.3</u>	<u>12.82</u> <u>1.2</u>	<u>9.615</u> <u>5</u>	<u>2.87-</u> <u>7</u>	<u>0.00-</u> <u>8</u>	<u>0.0-</u> <u>0.5</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Apr.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>8.45-5</u>	<u>14.51</u> <u>8.4</u>	<u>11.616</u> <u>5</u>	<u>11.21</u> <u>3.7</u>	<u>10.61</u> <u>3.5</u>	<u>8.610</u> <u>9</u>	<u>8.510</u> <u>4</u>	<u>11.21</u> <u>1.2</u>	<u>12.01</u> <u>1.8</u>	<u>10.21</u> <u>5.6</u>	<u>10.71</u> <u>3.3</u>	<u>4.113</u> <u>3</u>	<u>0.0-</u> <u>1.4</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
May	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>10.81</u> <u>3.7</u>	<u>12.21</u> <u>7.9</u>	<u>8.711</u> <u>8</u>	<u>9.010</u> <u>6</u>	<u>8.812</u> <u>6</u>	<u>7.212</u> <u>9</u>	<u>7.010</u> <u>9</u>	<u>6.210</u> <u>8</u>	<u>7.110</u> <u>5</u>	<u>6.09-7</u>	<u>5.69-</u> <u>8</u>	<u>2.39-</u> <u>3</u>	<u>0.0-</u> <u>2.8</u>	<u>0.0-</u> <u>1.4</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Jun.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>11.21</u> <u>3.9</u>	<u>12.01</u> <u>7.3</u>	<u>7.712</u> <u>0</u>	<u>5.58-6</u>	<u>4.07-9</u>	<u>5.110</u> <u>5</u>	<u>5.18-3</u>	<u>5.27-3</u>	<u>5.88-9</u>	<u>8.210</u> <u>3</u>	<u>5.79-</u> <u>0</u>	<u>2.910</u> <u>0</u>	<u>0.0-</u> <u>0.4</u>	<u>0.0-</u> <u>2.7</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Jul.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>10.98-</u> <u>8</u>	<u>11.41</u> <u>6.5</u>	<u>6.812</u> <u>2</u>	<u>3.85-9</u>	<u>3.04-4</u>	<u>3.54-7</u>	<u>3.48-5</u>	<u>5.19-1</u>	<u>5.811</u> <u>1</u>	<u>6.18-7</u>	<u>6.412</u> <u>8</u>	<u>1.77-</u> <u>8</u>	<u>0.0-</u> <u>3.7</u>	<u>0.0-</u> <u>2.5</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Aug.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>8.46-7</u>	<u>11.91</u> <u>4.7</u>	<u>6.811</u> <u>8</u>	<u>5.28-6</u>	<u>4.36-2</u>	<u>4.06-6</u>	<u>5.37-5</u>	<u>5.27-3</u>	<u>5.89-8</u>	<u>5.611</u> <u>6</u>	<u>4.58-</u> <u>7</u>	<u>1.82-</u> <u>5</u>	<u>0.0-</u> <u>4.7</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Sep.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>6.41-3</u>	<u>15.51</u> <u>3.2</u>	<u>8.510</u> <u>9</u>	<u>5.910</u> <u>6</u>	<u>3.68-4</u>	<u>4.08-8</u>	<u>4.68-5</u>	<u>4.68-7</u>	<u>5.010</u> <u>4</u>	<u>5.67-6</u>	<u>3.39-</u> <u>0</u>	<u>0.01-</u> <u>2</u>	<u>0.0-</u> <u>1.1</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Oct.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>2.00-2</u>	<u>16.21</u> <u>3.0</u>	<u>12.513</u> <u>7</u>	<u>8.16-5</u>	<u>6.19-2</u>	<u>5.67-0</u>	<u>8.26-8</u>	<u>5.88-4</u>	<u>5.59-0</u>	<u>6.210</u> <u>1</u>	<u>4.25-</u> <u>3</u>	<u>0.0-</u> <u>4.8</u>	<u>0.0-</u> <u>0.2</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Nov.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>8.88-0</u>	<u>12.41</u> <u>7.1</u>	<u>10.59-</u> <u>8</u>	<u>8.36-0</u>	<u>9.16-7</u>	<u>8.77-7</u>	<u>7.05-9</u>	<u>7.37-6</u>	<u>8.96-2</u>	<u>3.72-1</u>	<u>0.0-</u> <u>1.4</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>
Dec.	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>0.00-0</u>	<u>3.31-7</u>	<u>13.51</u> <u>7.9</u>	<u>9.514</u> <u>0</u>	<u>6.66-5</u>	<u>6.55-4</u>	<u>7.15-2</u>	<u>6.67-9</u>	<u>5.78-4</u>	<u>6.18-9</u>	<u>1.33-4</u>	<u>0.0-</u> <u>0.6</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-</u> <u>0</u>	<u>0.00-0</u>

Non-Spinning Reserve (Non-Spin) Requirement Details

Introduction

Non-Spinning Reserve (Non-Spin) consists of Generation Resources capable of being ramped to a specified output level within 30 minutes or Controllable Load Resources that are capable of being interrupted within 30 minutes and that are capable of running (or being interrupted) at a specified output level for at least four consecutive hours. Non-Spin may also be provided by Load Resources that are not Controllable Load Resources and are capable of reducing consumption based on an ERCOT Extensible Markup Language (XML) instruction within 30 minutes and maintaining that deployment until recalled. Non-Spin may be deployed to replace loss of generating capacity, to compensate for Load forecast and/or forecast uncertainty on days in which large amounts of reserve are not available online, to address the risk of net load ramp, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

The periods when load is increasing and wind and/or solar are decreasing requires other generation resources to increase output or come online quickly to compensate for the sudden net load increases. As a result, net load ramp risk should be accounted for in the determination of Non-Spin requirements. While net load forecast analysis may cover reserves required for forecast uncertainty, it may not necessarily cover exposure to the loss of generation and net load ramp risk. Due to this risk, it may be necessary for ERCOT to have additional reserves available to protect against forecast uncertainty and Forced Outages of thermal Resources within an Operating Day.

Summary

Analysis for Non-Spin requirements are conducted using data from the same month of previous three years. For the purpose of determining the amount of Non-Spin to purchase for each hour of the day, hours will be placed into 4-hour blocks. The net load uncertainty for the analyzed days for all hours which are considered to be part of a 4-hour block will be calculated and a percentile will be assigned to this block of hours based on the risk of net load ramp. The same calculation will be done separately for each block. The Non-Spin requirement for the month for each block is calculated using the assigned percentile (based on risk of net load ramp) for the block minus the average Reg-Up requirement during the same block of hours (“Non-Spin block”). The Non-Spin requirement for each hour in the month is calculated by adding an adjustment that accounts for intra-day Forced Outage of thermal Resources to the previously calculated “Non-Spin block” quantity that the hour falls in.

ERCOT will post the monthly amounts for Non-Spin requirements for the upcoming year on the MIS. Following this posting, ERCOT will monitor the weather and net load forecast (i.e. load, wind and solar forecasts) near Real-Time and may procure up to an additional 1,000 MW of Non-Spin for Operating Hours that are (a) identified as having an increased potential of high forecast variability, (b) there is a risk that the actual net load during these Operating Hours could be higher than forecast (after making appropriate forecast model selection) and (c) the expected available capacity and expected reserves including the posted minimum Non-Spin requirements during these Operating Hours is not sufficient to cover the projected net load forecast uncertainty risk.

The minimum amount of Non-Spin procured from SCED dispatchable Resources in any hour shall not be less than ERCOT’s Most Severe Single Contingency (MSSC) value.

Procedure

ERCOT will determine the Non-Spin requirement using the 75th to 95th percentile of hourly net load uncertainty from the same month of the previous three years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR) at a point in time. The forecast of net load is computed by subtracting the aggregate IRR High Sustained Limits (HSLs) in the Current Operating Plans (COPs) from the Mid-Term Load Forecast (MTLF). The COPs and MTLF used are the updated values as of six hours prior to each Operating Hour. The net load uncertainty is then defined as the difference between the average 5-minute net load within the hour and the forecasted net load.

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. A fixed value of 68th percentile will be assigned to HE23, HE24, HE01 and HE02 to the net load forecast uncertainty calculated previously. In all seasons excluding Winter, a fixed value of 68th percentile will also be assigned to HE03, HE04, HE05, HE06 to the net load forecast uncertainty calculated previously. For the remaining hours, a fixed value of percentile ranging between 75th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 75th percentile for periods with lowest risks.

ERCOT has seen significant growth in installed wind and solar capacity from one year to the next; an increase in wind and solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical wind and solar forecast errors alone creates a possibility of under-estimation of the Non-Spin requirement.

To address this, ERCOT will include the impact of increase in over-forecast error from the expected growth in wind and solar generation installed capacity into the future Non-Spin requirement. The net wind impact is calculated by a multiplication of the projected wind capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental wind generation capacity. The incremental MW wind adjustment to the Non-Spin value per 1000 MW increase in wind installed capacity is calculated as the change in 50th percentile of the historical wind over-forecast error for 4-hour blocks of each month in the past 5 years, which is then normalized to per 1000 MW of installed wind capacity. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the Non-Spin value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar over-forecast error for 4-hour blocks of each month in the past 3 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflect the additional Non-Spin adjustments per 1000 MW of installed wind and solar capacity.

To account for increased capacity needs due to unplanned generation Outages that occur during an Operating Day, ERCOT will include an incremental adjustment in the Non-Spin requirements that accounts for intra-day Forced Outages of thermal Resources. This Forced Outage adjustment is calculated as the 75th percentile of the historical intra-day Forced Outages (accumulated since midnight) for six-hour blocks of each month in the past three years. The table below reflects

Attachment A

additional Non-Spin adjustments to account for intra-day Forced Outages of thermal Resources. ERCOT will purchase Non-Spin such that the combination of Non-Spin and Reg-Up Services cover the uncertainties of net load forecast errors depending on the net load ramp risk and intra-day Forced Outages.

DRAFT

Attachment A

Incremental MW Adjustment to Non-Spinning Reserve Service, per 1000 MW of Incremental Wind Generation Capacity																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	2734	2734	2734	2734	2734	2734	2933	2933	2933	2933	2226	2226	2226	2226	2327	2327	2327	2327	2835	2835	2835	2835	273 +	2734
Feb.	2734	2734	2734	2734	2734	2734	2933	2933	2933	2933	2226	2226	2226	2226	2327	2327	2327	2327	2835	2835	2835	2835	273 +	2734
Mar.	2934	2934	3136	3136	3136	3136	3032	3032	3032	3032	2527	2527	2527	2527	2628	2628	2628	2628	2934	2934	2934	2934	293 4	2934
Apr.	2934	2934	3136	3136	3136	3136	3032	3032	3032	3032	2527	2527	2527	2527	2628	2628	2628	2628	2934	2934	2934	2934	293 4	2934
May	2934	2934	3136	3136	3136	3136	3032	3032	3032	3032	2527	2527	2527	2527	2628	2628	2628	2628	2934	2934	2934	2934	293 4	2934
Jun.	2733	2733	2634	2634	2634	2634	2634	2634	2634	2634	1920	1920	1920	1920	2124	2124	2124	2124	2829	2829	2829	2829	273 3	2733
Jul.	2733	2733	2634	2634	2634	2634	2634	2634	2634	2634	1920	1920	1920	1920	2124	2124	2124	2124	2829	2829	2829	2829	273 3	2733
Aug.	2733	2733	2634	2634	2634	2634	2634	2634	2634	2634	1920	1920	1920	1920	2124	2124	2124	2124	2829	2829	2829	2829	273 3	2733
Sep.	2127	2127	2127	2127	2127	2127	2228	2228	2228	2228	1724	1724	1724	1724	2123	2123	2123	2123	2227	2227	2227	2227	212 7	2127
Oct.	2127	2127	2127	2127	2127	2127	2228	2228	2228	2228	1724	1724	1724	1724	2123	2123	2123	2123	2227	2227	2227	2227	212 7	2127
Nov.	2127	2127	2127	2127	2127	2127	2228	2228	2228	2228	1724	1724	1724	1724	2123	2123	2123	2123	2227	2227	2227	2227	212 7	2127
Dec.	2734	2734	2734	2734	2734	2734	2933	2933	2933	2933	2226	2226	2226	2226	2327	2327	2327	2327	2835	2835	2835	2835	273 +	2734

Attachment A

Incremental MW Adjustment to Non-Spinning Reserve Service, per 1000 MW of Incremental Solar Generation Capacity																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	00	00	00	00	00	00	3+	3+	3+	3+	3750	3750	3750	3750	3136	3136	3136	3136	00	00	00	00	00	00
Feb.	00	00	00	00	00	00	3+	3+	3+	3+	3750	3750	3750	3750	3136	3136	3136	3136	00	00	00	00	00	00
Mar.	00	00	00	00	00	00	748	748	748	748	4461	4461	4461	4461	4861	4861	4861	4861	23	23	23	23	00	00
Apr.	00	00	00	00	00	00	748	748	748	748	4461	4461	4461	4461	4861	4861	4861	4861	23	23	23	23	00	00
May	00	00	00	00	00	00	748	748	748	748	4461	4461	4461	4461	4861	4861	4861	4861	23	23	23	23	00	00
Jun.	00	00	00	00	00	00	1143	1143	1143	1143	3438	3438	3438	3438	3632	3632	3632	3632	86	86	86	86	00	00
Jul.	00	00	00	00	00	00	1143	1143	1143	1143	3438	3438	3438	3438	3632	3632	3632	3632	86	86	86	86	00	00
Aug.	00	00	00	00	00	00	1143	1143	1143	1143	3438	3438	3438	3438	3632	3632	3632	3632	86	86	86	86	00	00
Sep.	00	00	00	00	00	00	42	42	42	42	2631	2631	2631	2631	2320	2320	2320	2320	10	10	10	10	00	00
Oct.	00	00	00	00	00	00	42	42	42	42	2631	2631	2631	2631	2320	2320	2320	2320	10	10	10	10	00	00
Nov.	00	00	00	00	00	00	42	42	42	42	2631	2631	2631	2631	2320	2320	2320	2320	10	10	10	10	00	00
Dec.	00	00	00	00	00	00	3+	3+	3+	3+	3750	3750	3750	3750	3136	3136	3136	3136	00	00	00	00	00	00

Attachment A

Incremental MW Adjustment to Non-Spinning Reserve Service to account for Intra-day Forced Outages of thermal resources																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	51135 5	51135 5	51135 5	51135 5	51135 5	51135 5	95273 0	95273 0	9527 30	95273 0	95273 0	95273 0	92182 4	92182 4	92182 4	92182 4	92182 4	9218 24	9587 21	9587 21	9587 21	9587 21	95872 1	95
Feb.	43243 0	43243 0	43243 0	43243 0	43243 0	43243 0	80576 9	80576 9	8057 69	80576 9	80576 9	80576 9	10139 00	10139 00	10139 00	10139 00	10139 00	1013 900	7046 58	7046 58	7046 58	7046 58	70465 8	704658
Mar.	51554 8	51554 8	51554 8	51554 8	51554 8	51554 8	83977 4	83977 4	8397 74	83977 4	83977 4	83977 4	83980 5	83980 5	83980 5	83980 5	83980 5	8398 05	7007 03	7007 03	7007 03	7007 03	70070 3	700703
Apr.	62164 3	62164 3	62164 3	62164 3	62164 3	62164 3	86993 6	86993 6	8699 36	86993 6	86993 6	86993 6	81579 2	81579 2	81579 2	81579 2	81579 2	8157 92	7597 52	7597 52	7597 52	7597 52	75975 2	759752
May	78666 4	78666 4	78666 4	78666 4	78666 4	78666 4	88197 7	88197 7	8819 77	88197 7	88197 7	88197 7	10529 84	10529 84	10529 84	10529 84	10529 84	1052 984	9848 83	9848 83	9848 83	9848 83	98488 3	984883
Jun.	61263 3	61263 3	61263 3	61263 3	61263 3	61263 3	77185 2	77185 2	7718 52	77185 2	77185 2	77185 2	81798 7	81798 7	81798 7	81798 7	81798 7	8179 87	9974 015	9974 015	9974 015	9974 015	99740 15	997401
Jul.	63554 5	63554 5	63554 5	63554 5	63554 5	63554 5	76376 0	76376 0	7637 60	76376 0	76376 0	76376 0	52564 5	52564 5	52564 5	52564 5	52564 5	5256 45	7238 75	7238 75	7238 75	7238 75	72387 5	723875
Aug.	55848 5	55848 5	55848 5	55848 5	55848 5	55848 5	67157 6	67157 6	6715 76	67157 6	67157 6	67157 6	44947 7	44947 7	44947 7	44947 7	44947 7	4494 77	5496 28	5496 28	5496 28	5496 28	54962 8	549628
Sep.	43548 8	43548 8	43548 8	43548 8	43548 8	43548 8	77789 5	77789 5	7778 95	77789 5	77789 5	77789 5	53373 8	53373 8	53373 8	53373 8	53373 8	5337 38	5107 29	5107 29	5107 29	5107 29	51072 9	510729
Oct.	58146 7	58146 7	58146 7	58146 7	58146 7	58146 7	10167 95	10167 95	1016 795	10167 95	10167 95	10167 95	99588 0	99588 0	99588 0	99588 0	99588 0	9958 80	8638 24	8638 24	8638 24	8638 24	86382 4	863824
Nov.	63958 5	63958 5	63958 5	63958 5	63958 5	63958 5	83576 7	83576 7	8357 67	83576 7	83576 7	83576 7	97497 0	97497 0	97497 0	97497 0	97497 0	9749 70	1055 1020	1055 1020	1055 1020	1055 1020	10554 020	105540
Dec.	66852 5	66852 5	66852 5	66852 5	66852 5	66852 5	77576 6	77576 6	7757 66	77576 6	77576 6	77576 6	10188 24	10188 24	10188 24	10188 24	10188 24	1018 824	6175 64	6175 64	6175 64	6175 64	61756 4	617564

Formatted Table

Responsive Reserve (RRS) Requirement Details

Nodal Operating Guide Section 2.3.1.1, Obligation, sets the minimum RRS requirement for all hours under normal conditions. ERCOT will procure amounts of RRS that vary by hour of the day and by month. These RRS amounts will be published by month in six separate blocks covering four-hour intervals. These amounts will be based on expected diurnal load, solar, and wind patterns for the month, will cover 70% of historic system inertia conditions for each block of hours for the month, and will use the equivalency ratio for RRS between Load Resources and Generation Resources to establish the conditions for each block of hours. The equivalency ratio will be used to establish the total reserves assuming the Day-Ahead Market (DAM) will use a one to one equivalency ratio. The minimum level of RRS procured from Resources providing RRS using Primary Frequency Response shall be determined for each month by ERCOT through the use of studies and shall not be less than 1,185,390 MWs. The remaining capacity required for RRS will be procured from all Resources qualified to provide RRS including Load Resources. The maximum amount of RRS that can be provided by Resources providing Fast Frequency Response (FFR) is limited to 450 MW. DAM will limit the combined RRS procured from Load Resources controlled by high set under frequency relay and Resources providing FFR to 60% of the total RRS requirement. ~~A floor of 2,800 MW will be applied to RRS quantities during the peak hours. During the peak hours, this additional RRS will help maintain an increased operating margin and operate the grid more conservatively.~~ ERCOT may increase the minimum capacity required from Resources providing RRS using Primary Frequency Response if it believes that the current posted quantity will have a negative impact on reliability or if it would require additional Regulation Service to be deployed. ERCOT will procure additional 200 MW of RRS for each percent of Reserve Discount Factor (RDF) when ERCOT estimates RDF to be less than 1. This adjustment will only apply for those 4-hour blocks where the 85th percentile of weighted average temperature is greater than 95°F. RDFs are reviewed and adjusted based on the generators performance during an unannounced test. RRS amount will be published as a monthly requirement along with the equivalency ratio for each 4-hour block. Additionally, ERCOT will make incremental adjustments to account for Resources operating in synchronous condenser fast response mode providing RRS. This adjustment will only apply to those 4-hour blocks when system inertia is typically expected to be less than 250 GW*s. ERCOT will post these monthly amounts for the upcoming year on the MIS. These annually published amounts are the minimum quantity that will be procured in the DAM for each hour of the year.

Self-arranged RRS used to fulfill a Qualified Scheduling Entity's (QSE's) RRS requirement will be limited to 60% from Resources providing FFR and Load Resources excluding Controllable Load Resources.

If the percentage level for Resources providing FFR and Load Resources, excluding Controllable Load Resources, specified in the Protocols is changed, that change will be reflected in these requirements.

ERCOT Contingency Reserve Service (ECRS) Details

Introduction

ECRS is a service that is provided using capacity that is capable of being ramped to a specified output level within 10 minutes that can be sustained at a specified level for two consecutive hours. ECRS may be provided by unloaded, On-Line Generation Resource capacity; Quick Start Generation Resources (QSGRs); Load Resources that may or may not be controlled by high-set, underfrequency relays; Controllable Load Resources; and Generation Resources operating in synchronous condenser fast-response mode as defined in the Operating Guides. ECRS may be deployed to restore frequency within 10 minutes of a significant frequency deviation to recover deployed Regulation Service, to compensate for intra-hour net load forecast uncertainty and variability on days in which large amounts of online thermal ramping capability is not available, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

Procedure

ERCOT will procure amounts of ECRS that vary by hour of the day and by month. ERCOT will determine the ECRS requirement as the sum of capacity needed to recover frequency following a large unit trip and capacity needed to cover for intra-hour net load forecast errors.

The frequency recovery related capacity for ECRS is computed for each hour in every month as capacity needed following a supply-side trip to recover frequency; will be based on expected diurnal load, solar, and wind patterns; ~~and~~ will cover ~~67~~0% of historic system inertia conditions for each hour for the month and will include an adjustment to account for Regulation Up requirement in the hour.

Intra-hour net load forecast is utilized in establishing Base Points for SCED dispatchable Resources. ERCOT has observed larger intra-hour net load forecast errors during times when there are sudden net load ramps. Through including intra-hour net load forecast errors in calculating ECRS quantities, uncertainty in forecasting intra-hour net load (and hence intra-hour net load ramps) will be accounted for. Specifically, the intra-hour net load forecast error related capacity for ECRS is computed using the 85th to 95th percentile of intra-hour net load uncertainty from the same hour and same month in the previous two years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR). The forecast of net load is computed by subtracting the Intra-Hour Wind Power Forecast (IHWPF) and Intra-Hour Photo Voltaic Power Forecast (IHPPF) from the Intra-Hour Load Forecast (IHLF). The IHWPF, IHPPF and IHLF used are the updated values as of thirty minutes prior to each Security Constrained Economic Dispatch (SCED) interval. The net load uncertainty is then defined as the difference between the average net load within the SCED interval and the forecasted net load.

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. The fixed value of percentile ranging between 85th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 85th

Attachment A

percentile for periods with lowest risks. A value of at least 90th percentile will be assigned to the net load forecast uncertainty calculated during sunset hours.

ERCOT has seen significant growth in installed solar capacity from one year to the next; an increase in solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical solar forecast errors alone creates a possibility of under-estimation of the ECRS requirement. To address this, ERCOT will include the estimated impact of increase in over-forecast error from the expected growth in solar generation installed capacity into the future ECRS requirement. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to ECRS value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the ECRS value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar over-forecast error for 4-hour blocks of each month in the past 2 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflects the additional ECRS adjustments per 1000 MW of installed solar capacity.

Attachment A

Incremental MW Adjustment to ERCOT Contingency Reserve Service, per 1000 MW of Incremental Solar Generation Capacity																								
Hour Ending																								
Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan.	00	00	00	00	00	00	00	00	00	00	2125	2125	2125	2125	2049	2049	2049	2049	00	00	00	00	00	00
Feb.	00	00	00	00	00	00	00	00	00	00	3346	3346	3346	3346	2039	2039	2039	2039	03	03	03	03	00	00
Mar.	00	00	00	00	00	00	00	00	00	00	3332	3332	3332	3332	7337	7337	7337	7337	040	040	040	040	00	00
Apr.	00	00	00	00	00	00	00	00	00	00	3048	3048	3048	3048	5542	5542	5542	5542	043	043	043	043	00	00
May	00	00	00	00	00	00	00	00	00	00	5920	5920	5920	5920	9648	9648	9648	9648	2645	2645	2645	2645	00	00
Jun.	00	00	00	00	00	00	00	00	00	00	1732	1732	1732	1732	4130	4130	4130	4130	3736	3736	3736	3736	00	00
Jul.	00	00	00	00	00	00	00	00	00	00	2325	2325	2325	2325	2324	2324	2324	2324	846	846	846	846	00	00
Aug.	00	00	00	00	00	00	00	00	00	00	4524	4524	4524	4524	5338	5338	5338	5338	447	447	447	447	00	00
Sep.	00	00	00	00	00	00	00	00	00	00	6447	6447	6447	6447	5627	5627	5627	5627	07	07	07	07	00	00
Oct.	00	00	00	00	00	00	00	00	00	00	267	267	267	267	3749	3749	3749	3749	00	00	00	00	00	00
Nov.	00	00	00	00	00	00	00	00	00	00	122	122	122	122	425	425	425	425	00	00	00	00	00	00
Dec.	00	00	00	00	00	00	00	00	00	00	339	339	339	339	042	042	042	042	00	00	00	00	00	00