



Ancillary Services and Large Loads in ERCOT

ERCOT Staff
Large Load Integration

May 6, 2024

ERCOT Ancillary Services Overview

Services procured by ERCOT in the Day-Ahead-Market to balance next day's supply and demand of electricity.

Real Time Issues that might cause imbalance:

- Daily load patterns
- Instantaneous load variation
- Changes in variable generation output
- Generators tripping offline

What type of resources can provide AS?

- Generation resources
- Non-Controllable load resources
- Controllable load resources
- Aggregate load resources
- Energy storage resources

Ancillary Service Types

- **Regulation Service (Reg Up/Dn):**
 - Reserved capacity that is deployed every 4 seconds to balance supply and demand.
- **Responsive Reserve Service (RRS):**
 - Reserve capacity that can balance supply and demand if a generator trips offline.
- **Non-Spin Reserve Service (NSRS):**
 - Capacity that can respond within 30 minutes to address forecasting errors or to replaced deployed reserves.
- **ERCOT Contingency Reserve Service (ECRS):**
 - Capacity that can be available within 10 minutes to cover errors in forecasts, replace deployed reserves, and recover frequency.

Large Loads Providing Ancillary Services

- Qualifying Large Loads can participate in the Ancillary Service market as either a Non-Controllable Load Resource (NCLR) or a Controllable Load Resource (CLR).
- ERCOT has observed Large Load ([Interim LLI](#)) participation in...
 - Responsive Reserve Service (RRS)
 - Non-Spin Reserve Service (NSRS)
 - ERCOT Contingency Reserve Service (ECRS)
- Less than 20% of Large Load ([Interim LLI](#)) capacity provides AS on average.

Large Load Behavioral Impacts

- Most Large Loads have been observed to independently respond to...
 - Price Signals
 - 4CP
 - Extreme Weather Events
- An independent response refers to load behavior that is not coordinated with ERCOT through a direct dispatch instruction.
- This independent response often causes an increase in...
 - Load and Net-Load Variability
 - Load and Net-Load Uncertainty (Forecast Error)

Large Load Impacts on Ancillary Services

- **Regulation Service:**
 - Higher net-load variability due to Large Load increases total procurement.
- **Non-Spin Reserve Service:**
 - Higher net-load uncertainty due to Large Load increases total procurement.
- **ERCOT Contingency Reserve Service:**
 - Higher net-load uncertainty due to Large Load increases total procurement.
 - Significant net-load forecast error can distort the effectiveness of the ECRS manual release triggers.
 - See next slide for example.

ECRS Manual Release Trigger w/ Large Load Ramp Example

- Manual release triggers are currently based on the following two assessments of available dispatchable capacity to serve forecasted 10 minute ahead net load:
 - ❑ 10-min Net Load Ramp Capability
 - 10-min Remaining Ramping Capability minus 10-min Net Load Ramp Forecast
 - ❑ PRC Trigger
 - $PRC - 3200 - (10\text{-min Net Load Ramp Forecast}) + QSGR$
- Both triggers are more likely to occur during intervals of elevated system prices, which ERCOT has observed is also when many Large Loads independently curtail (totaling over 2 GW).
 - For example, during the evening solar down ramp.
- This independent price response is not well accounted for in 10-min Net Load Forecasts and can result in the forecasted 10-min Net Load Ramp to be larger than is observed in real-time.
 - As a result, ECRS may be manually triggered when it otherwise would not have if Large Load ramps could be better incorporated into the 10-min forecasts.

Ancillary Service Procurement Lag

- Most AS products are procured based on historical data.
- Current AS procurement methodologies do not account for rapid year-to-year changes in demand.
- For example, Regulation Services are procured at the 95th percentile of 5-min net-load ramps (HE 1 – 24 for every month) during the previous year.
 - Manual adjustments to procurement totals are made for Wind & Solar generation growth projections.
 - Currently, no manual adjustments are made for flexible load growth projections.
- Large Loads independently responding to market signals that energized less than a year ago are not currently accounted for in regulation procurement.

Regulation Service Procurement Lag Example

- ERCOT performed an analysis in November 2023 that evaluated what the change in Regulation (Up & Dn) procurement would be for 2024 if past Large Load ([Interim LLI](#)) ramping behavior was scaled up to a future projected load total.
 - Large Load ([Interim LLI](#)) ramping behavior was scaled to correspond to 4,479 MW of approved to energize Large Load.
 - A new 95th percentile for net-load ramps was then calculated and the deltas were recorded.
- The deltas indicate how much more (or less) regulation would need to be procured to account for year-to-year Large Load growth while still achieving a 95th percentile net load ramp target.
 - *Assumes 4,479 MW build out that behaves similar to already existing Large Loads.
- In total, the increase in regulation procurement for Jan – Oct 2024 would be...
 - Regulation Up: **88,207 MWh**
 - Regulation Dn: **110,739 MWh**

Regulation Procurement by Hour Ending (MW)			
HE	Up	Down	Total
1	1	10	11
2	6	2	8
3	8	10	18
4	11	15	26
5	9	18	26
6	7	6	13
7	5	11	16
8	6	15	22
9	10	4	14
10	6	8	14
11	2	10	12
12	-1	16	15
13	-4	17	13
14	-1	24	23
15	4	51	55
16	2	24	27
17	1	26	27
18	5	21	25
19	23	42	65
20	5	26	31
21	51	4	55
22	79	-4	75
23	22	6	28
24	31	1	32

Average Change from Current Regulation Procurement by Month (MW)										
Reg	1	2	3	4	5	6	7	8	9	10
Up	15	12	15	6	0	6	16	33	11	6
Down	14	26	12	10	2	6	14	43	10	15
Total	29	39	27	16	2	12	30	76	21	22



Questions?

Email: evan.neel@ercot.com

Appendix – Regulation Procurement Deltas

Regulation Up Procurement Differences Due to LFL Growth Projection (MW)										
HE	Month									
	1	2	3	4	5	6	7	8	9	10
1	-20	-1	20	48	-1	0	4	2	-23	-21
2	0	19	27	9	-5	8	5	1	1	-8
3	4	24	-1	2	-6	3	11	-1	24	22
4	9	36	21	-4	-1	-4	10	30	16	0
5	1	5	24	-5	23	1	0	13	5	18
6	16	12	18	5	-8	7	6	9	9	0
7	10	20	-5	7	-3	-3	-12	2	11	25
8	17	17	2	7	2	-4	0	14	3	5
9	73	-1	26	-5	8	-4	-1	13	-7	0
10	26	-9	38	4	5	-3	2	7	-5	-2
11	-9	1	17	2	-2	3	11	5	1	-7
12	2	22	-6	-3	-4	-6	-6	-17	-1	12
13	-13	2	0	-1	0	-18	-3	-8	-3	1
14	-4	4	-8	-14	1	-1	-4	18	-4	0
15	12	-9	18	7	5	-15	16	-15	8	16
16	2	-5	2	14	4	-7	4	2	12	-4
17	17	-5	-5	3	7	-11	5	-1	0	-3
18	0	-1	10	-19	9	19	0	23	4	1
19	21	-2	8	-4	-4	72	68	78	-13	4
20	109	11	-12	-33	-16	-6	49	13	-50	-10
21	12	45	92	23	9	59	52	61	85	68
22	29	44	58	55	48	52	28	194	149	133
23	64	41	27	40	-94	-5	135	123	-14	-97
24	-19	19	-2	-4	16	9	-2	230	53	5

Regulation Down Procurement Differences Due to LFL Growth Projection (MW)										
HE	Month									
	1	2	3	4	5	6	7	8	9	10
1	-6	36	24	11	0	2	-2	7	2	24
2	4	45	-20	-1	-15	1	3	3	-1	3
3	6	18	32	7	-3	4	0	5	25	6
4	43	23	32	13	4	-1	2	4	34	-6
5	-2	69	21	34	2	-1	7	3	30	13
6	-14	45	36	-9	-11	3	-5	6	-5	8
7	27	114	-1	1	0	3	1	5	-27	-10
8	42	20	22	15	-3	8	3	2	7	38
9	-1	-3	19	-2	-2	15	8	0	-4	10
10	18	16	1	9	6	1	-1	18	11	2
11	2	31	0	0	17	2	18	25	4	2
12	-19	12	-4	-2	-2	-6	0	190	-2	-8
13	-2	1	-6	-6	15	-3	5	193	-2	-22
14	-2	9	5	9	14	-25	35	193	13	-10
15	-6	-5	-1	5	3	168	133	157	58	-6
16	0	-2	-30	16	3	8	61	131	47	11
17	99	15	14	12	12	6	23	90	2	-11
18	94	43	29	0	5	2	-17	30	10	10
19	-16	85	57	4	1	6	6	15	1	260
20	9	15	10	116	-4	-10	36	61	15	8
21	20	24	23	0	8	-10	25	-49	-13	11
22	16	0	9	0	-5	-13	-6	-53	7	9
23	22	21	18	2	1	-23	-6	-13	17	23
24	4	2	-10	4	7	7	1	-1	1	-3

These tables indicate the difference in regulation procurement schedules if Large Load ([Interim LLI](#)) was scaled up to the total approved to energize amount for 2024 (4,479 MW) as described in the methodology on slide 9.

