



# ERCOT GTC Updates

Yunzhi Cheng  
ERCOT Operations Support

ROS Meeting  
6/6/2023

## A New Uvalde GTC

- 2024 Q2 QSA identified the stability constraints due to a new Generation Resource connected to 138-kV grid at Kinney and Uvalde county.
- A follow up GTC study confirmed the need to establish the Uvalde GTC to address the stability constraints under some specific N-1-1 conditions
- This GTC is not IROL.
- This GTC became effective on June 5, 2024. This GTC interface and associated Generic Transmission Limit (GTLs) are available in the posted Generic Transmission Constraints Methodology.

<https://mis.ercot.com/secure/data-products/grid/transmission?id=NP3-770-M>