



Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double- Circuit Line Project – ERCOT Independent Review Status Update


Ben Richardson

RPG Meeting
November 11, 2025

Introduction

- Oncor submitted the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Project for Regional Planning Group (RPG) review in June 2024
 - This Tier 1 project is estimated to cost \$110.62 million and will require a Certificate of Convenience and Necessity (CCN)
 - Estimated in-service date (ISD) is December 2026
 - Addresses low voltages and thermal overloads expected as early as summer 2025 as a result of significant load growth primarily in oil and gas industry
- Oncor presented overview August 2024 RPG Meeting:
 - <https://www.ercot.com/calendar/08132024-RPG-Meeting>
- ERCOT provided status updates at previous RPG Meetings:
 - <https://www.ercot.com/calendar/09252024-RPG-Meeting>
 - <https://www.ercot.com/calendar/07292025-RPG-Meeting>
 - <https://www.ercot.com/calendar/09252025-RPG-Meeting>
 - <https://www.ercot.com/calendar/10282025-RPG-Meeting>
- This project is currently under ERCOT Independent Review (EIR)

Study Area Map with Violations seen by Oncor



Study Assumptions – Update (Cont.)

- Load in study area
 - Loads in the WFW Weather Zones have been updated to be consistent with the 2024 RTP Assumptions
 - Oil & Gas loads in the FW Weather Zone were updated based the S&P Global Load Forecast
 - New confirmed loads were added to the study base case
- Study Region focused on transmission elements in the Martin and Midland Counties resulting from confirmed load updates

Preliminary Results of Reliability Assessment – Need Analysis

- ERCOT conducted steady-state load flow analysis for the study base case according to the NERC TPL-001-5.1 and ERCOT Planning Criteria

Contingency Category*	# of Unsolved Contingencies	# of Thermal Overloads	# of Bus Voltage Violations
N-0 (P0)	None	None	None
N-1 (P1, P2-1, P7)	None	0	0
G-1+N-1 (P3)*	None	0	0
X-1+N-1 (P6-2)**	None	2***	0

*G-1 Generator tested: Odessa Ector CC1

**X-1 Transformers tested: Midland East T1, Morgan Creek T3, Rockhound T1

*** Violations seen in the basecase under P1 events were also seen under G-1 and X-1 events

Option 1 (Oncor proposed project)




Option 1 (Oncor proposed project)

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate) 345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;
- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0 mile) right of way (ROW), installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;

Option 1 (Oncor proposed project) – cont.

- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;
- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and
- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.


Option 2



Option 2

- Add a new 600 MVA (nameplate) 345/138-kV transformers to the existing Rockhound substation.

Option 3



Option 3

- Install 6 capacitor banks (18.4 MVAR each) to a feasible location near the Expanse 138-kV substation; and
- Install 6 capacitor banks (18.4 MVAR each) to a feasible location near the Lazy Ranch 138-kV substation.

Results of Reliability Assessment – Options

Option	N-1		G-1*+N-1		X-1**+N-1	
	Thermal Violations	Voltage Violations	Thermal Violations	Voltage Violations	Thermal Violations	Voltage Violations
1	None	None	None	None	None	None
2	None	None	None	None	None	None
3	None	None	None	None	2	None

*G-1 Generator tested: Odessa Ector CC1

**X-1 Transformers tested: Midland East T1, Morgan Creek T3, Rockhound T1

Long-Term Load-Serving Capability Assessment

- Assumptions
 - Adjusted load up in the study area, excluding Flexible Loads in the area
 - Adjusted conforming load down outside of the West and Far-West Weather Zones to balance power
 - Based on N-1 contingency
- Findings:

Option	Incremental Load-Serving Capability(~MW)
1	80
2	43

Cost Estimate and Feasibility Assessment

- Transmission Service Providers (TSPs) performed feasibility assessments and provided cost estimates for the options

Option	Cost Estimates (~\$M)	CCN Required (~miles)	Feasibility
1	\$110.62	Yes (13.2)	Yes
2	N/A	N/A	No

- Based on inputs from Oncor, Option 2 is deemed infeasible due to Oncor policy to limit 345/138-kV transformers in substation to 2

Results of Planned Maintenance Outage Evaluation

- ERCOT conducted planned maintenance outage evaluation on the study base case
 - Load level in the West was scaled down to 88.4% of the summer peak loads in the study base case based on ERCOT load forecast and historical load, in order to the study off-peak load condition
- Planned maintenance outage analysis results

Voltage Violations	Thermal Overloads	Unsolved Power Flow
0	0	0

Comparison of Options

	Option		
	1	2	3
Meets ERCOT and NERC Reliability Criteria	Yes	Yes	No
Improves Operational Flexibility	Yes	Yes	Yes
Improves Long-Term Load-Serving Capability	Yes	Yes	Yes
Require CCN (~miles)	Yes (13.2)	No	No
Cost Estimate* (~\$M)	\$110.62	N/A*	N/A*
Feasible	Yes	No	Yes

* The cost estimates were not provided because the option was deemed infeasible by Oncor

- Based on feedback from Oncor, Option 2 was deemed as not feasible
- Option 3 does not address the reliability need

ERCOT Preferred Option

- Option 1 was selected as the preferred option because it:
 - Addresses the project need in the study area
 - Meets both ERCOT and NERC reliability criteria
 - Improves long-term load-serving capability
 - Is a feasible option

Sensitivity Analyses

- Generation Addition Sensitivity Analysis
 - Planning Guide Section 3.1.3(4)(a)

GINR	Unit Name	Fuel Type	Projected COD	Capacity (~MW)	County
None	None	None	None	None	None

- Load Scaling Sensitivity Analysis
 - ERCOT performed a load scaling sensitivity per Planning Guide Section 3.1.3(4)(b) and concluded that the load scaling did not have a material impact on project need

Additional Analyses

- Congestion Analysis
 - Congestion analysis was performed for the preferred option using the 2023 RTP 2028 economic case
 - The preferred option did not result in any significant congestion within the study area
- Subsynchronous Resonance (SSR) Assessment
 - Subsynchronous Resonance (SSR) Assessment was conducted for the preferred option
 - ERCOT found no significant SSR impacts to the existing and planned generation resources at the time of this study

ERCOT Recommendation

- ERCOT recommends Option 1
 - Estimated Cost: approximately \$110.62 million
 - Expected ISD: December 2026
 - The completion date may change depending on material acquisition, outage coordination, construction, or other project related requirements.
 - CCN filling will be required to
 - Construct the new 345-kV double-circuit line from Connell to Rockhound, requiring approximately 13-mile new ROW;

Map of ERCOT Recommended Option



ERCOT Recommendation

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate) 345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;
- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0-mile) ROW, installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;

ERCOT Recommendation

- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;
- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and
- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.

Next Steps and Tentative Timeline

- Tentative timeline
 - EIR report to be posted in the MIS in November 2025
 - EIR recommendation to TAC in November 2025
 - Seek ERCOT Board of Directors endorsement in December 2025

Thank you!



Stakeholder comments also welcomed through:

Ben.Richardson@ercot.com

Robert.Golen@ercot.com

Appendix A – Transmission Projects

- List of transmission projects added to study base case

TPIT No	Project Name	Tier	Project ISD	County
72007	Ranger Camp 345/138/69 kV Switch	Tier 1	In-service	Mitchell
78374	Rockhound 345/138 kV Switch	Tier 3	In-service	Midland Martin
73368	Grey Well Draw – Buffalo 138 kV Second Circuit	Tier 3	In-service	Midland Martin
76705	Prairieland 345/138 kV Switch and 138 kV Line	Tier 2	In-service	Glasscock
80913	Sloan 138 kV Switch	Tier 4	5/1/2025	Midland
71960	Upgrade Grady – Expanse 138 kV Line	Tier 4	12/1/2024	Martin
81223	Range Rider 138 kV Switch	Tier 1	12/1/2025	Mitchell
72009	Cattleman 345/138 kV Switch	Tier 1	12/1/2025	Mitchell
87861	Range Rider – Ranger Camp 138 kV Double-Circuit Line	Tier 1	12/1/2025	Mitchell
81274	Ranger Camp – Cattleman 345 kV Double-Circuit Line	Tier 1	12/1/2025	Mitchell
81270	Construct the new Prong Moss 345 kV switch	Tier 1	12/1/2025	Howard

Appendix A – Transmission Projects (Cont.)

- List of transmission projects added to study base case

TPIT No	Project Name	Tier	Project ISD	County
81232	Cattleman – Bitter Creek/Champion Creek 345 kV Reroute	Tier 1	12/1/2026	Mitchell
81410	Reiter Switch Synchronous Condenser	Tier 1	1/1/2027	Ector
81415	Tonkawa Switch Synchronous Condenser	Tier 1	1/1/2027	Scurry
80870	Bakersfield Dynamic Reactive Substation Upgrade	Tier 1	5/1/2027	Pecos
81299	Ranger Camp – Prong Moss 345 kV Line Rebuild	Tier 1	5/1/2027	Mitchell Howard
81227	Cattleman – Gasconades 345 kV Reroute	Tier 1	6/1/2027	Mitchell
87633	WETT Buck Canyon Synchronous Condenser	Tier 1	7/1/2027	Borden
87635	WETT Pitchfork Synchronous Condenser	Tier 1	9/1/2027	Dickens
87629	WETT Binturong Synchronous Condenser	Tier 1	11/1/2027	Glasscock
72011	Tonkawa – Ranger Camp 345 kV Line Rebuild	Tier 1	12/1/2027	Mitchell Scurry
81296	Prong Moss – Rockhound 345 kV Line Rebuild	Tier 1	12/1/2027	Midland Howard

Appendix A – Transmission Projects (Cont.)

- List of transmission projects added to study base case

TPIT No	Project Name	Tier	Project ISD	County
81175	Salt Flat Road 138 kV Switch and Salt Flat Road - Barr Ranch - Reiter 138 kV Second Circuit	Tier 3	12/1/2025	Ector, Midland
81305	Expanse - Vealmoor 138 kV Line Rebuild (Tredway 138-kV Switch and Expanse to Tredway 138-kV 2nd Circuit)	Tier 1	12/1/2025	Borden, Howard, Martin

Appendix B – Transmission Projects - Updated

- List of transmission projects removed from the study base case

TPIT No	Project Name	County
2021-FW4	Rio Pecos – Rankin – Texon Tap – Atlantic Best Tap – Kemper Tap – Big Lake 69-kV to 138-kV Line Conversion	Pecos, Upton, Reagan
2021-FW19	Morgan Creek SES - Longshore Switch 345-kV Line Upgrade	Mitchell, Howard
2021-FW20	Lamesa – Key Sub – Gail Sub – Willow Valley Switch 138-kV Line Upgrade	Dawson, Borden
2023-FW4	Buzzard Draw Switch – Koch Tap – Vealmoor 138-kV Line Upgrade	Howard
2023-FW9	East Stiles 138-kV Cap Bank Addition	Reagon
2023-FW13	Bulldog – Elbow – Eiland – Einstein – Carterville 138-kV Line Upgrade	Howard, Midland
2022-WFW1	Twin Buttes – Hargrove – Pumpjack – Jerry – Russek Street – Big Lake 138-kV line Upgrade	Tom Green, Irion, Reagan

Appendix C – Generation Projects

- List of generation projects added to study base case

GINR	Project Name	Fuel	Project COD	Capacity (~MW)	County
None	None	None	None	None	None