



PUBLIC

Item 14.3: Recommendation Regarding Oncor Connell 345/138-kV Switch and Connell to Rockhound 345- kV Double-Circuit Line Regional Planning Group (RPG) Project

Kristi Hobbs

Vice President, System Planning and
Weatherization

Board of Directors Meeting
December 8-9, 2025

- **Purpose**

Provide an overview of the \$110.62 million Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Tier 1 Reliability Project. Per ERCOT Protocol Section 3.11.4.7 Tier 1 projects require Board endorsement

- **Voting Items / Request**

ERCOT staff requests and recommends that the Board of Directors (Board) endorse the Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line RPG Project (Option 1) based on North American Electric Reliability Corporation (NERC) and Electric Reliability Council of Texas, Inc (ERCOT) reliability planning criteria

Key Takeaways


- Ensuring ERCOT's leadership for grid reliability and resilience, the Project has completed RPG review and received an independent assessment from ERCOT staff and unanimous endorsement by the Technical Advisory Committee (TAC)
- ERCOT studied several options and recommends Option 1 as it addresses all project needs with no reliability violations and improves long-term load-serving capability

Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line RPG Project

- Oncor submitted the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Project for Regional Planning Group (RPG) review in June 2024
- The purpose of the project is to address the reliability issues in Martin and Midland Counties in the Far West Weather Zone
- ERCOT performed an independent review of the project and identified thermal overloads in Midland County
- ERCOT's endorsement of the project is based on the reliability need to relieve thermal overloads on two (2) 345/138-kV autotransformers in Midland County to meet NERC and ERCOT reliability planning criteria
- ERCOT presented the project and TAC voted unanimously to endorse the project on November 19, 2025

Key Takeaway: The Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project has completed RPG review and received unanimous endorsement by TAC.

Thermal Overloads Seen by ERCOT



Basis for ERCOT Board Endorsement

ERCOT's independent review identified a reliability need for the Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project to satisfy:

NERC TPL-001-5.1 Table 1 Reliability Criteria for category:

- P6-2: The contingency is the loss of a transformer with System adjustments followed by a transmission circuit outage

ERCOT Planning Guide Section Reliability Performance Criteria contingency:

- 4.1.1.2(1)(d): The contingency is a loss of a single transformer followed by a single transmission element or common tower outage

Key Takeaway: The Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project is needed to meet reliability under NERC and ERCOT Planning Guide criteria.



Overall Project Summary

One (1) new 345/138-kV substation

Approximately 13 miles of new 345-kV double-circuit transmission lines

Rebuild of approximately 9 miles of 138-kV single-circuit transmission lines

Two (2) new 345/138-kV transformers

Eight (8) new 345-kV circuit breakers

Twelve (12) new 138-kV circuit breakers

Key Takeaway: The Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project (Option 1) will require a Certificate of Convenience and Necessity (CCN) for the new 345-kV double-circuit transmission lines




Request for Board Vote

ERCOT staff requests and recommends that the Board:

- Endorse the need for the Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project (Option 1) based on NERC and ERCOT reliability planning criteria
- The ERCOT Independent Review (EIR) is included as **Attachment A** to the Board Decision Template

Key Takeaway: ERCOT studied several options and recommends Option 1 to address the reliability violations and improve long-term load-serving capability.

ERCOT Recommendation





Date: December 1, 2025
To: Board of Directors
From: Kristi Hobbs, Vice President, System Planning and Weatherization (ERCOT)
Subject: Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Regional Planning Group (RPG) Project

Issue for the ERCOT Board of Directors

ERCOT Board of Directors Meeting Date: December 8-9, 2025

Item No.: 14.3

Issue:

Whether the Board of Directors (Board) of Electric Reliability Council of Texas, Inc. (ERCOT) should accept the recommendation of ERCOT staff to endorse the need for the Tier 1 Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Regional Planning Group (RPG) Project in order to meet the reliability requirements for the ERCOT System and address thermal overloads due to load growth in the Far West Weather Zone, which ERCOT staff has independently reviewed and which the Technical Advisory Committee (TAC) has voted unanimously to endorse.

Background/History:

Oncor proposed the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project in June 2024, a \$110.62 million, Tier 1 project with the expected in-service date of December 2026, to meet reliability planning criteria due to load growth in the Far West Weather Zone. Protocol Section 3.11.4.7, Processing of Tier 1 Projects, requires ERCOT to independently review submitted projects. ERCOT performed an independent review of the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project and identified thermal overloads in Midland County. The ERCOT project recommendation (Option 1), a \$110.62 million, Tier 1 project with the expected in-service date of December 2026 addresses the need for a project under North American Electric Reliability Corporation (NERC) and ERCOT Planning Criteria to address thermal overloads on two (2) 345/138-kV autotransformers in Midland County with the following ERCOT System improvements:

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate)

345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;

- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0 mile) right of way (ROW), installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;
- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;
- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and
- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.

ERCOT's independent review verified the reliability need for the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project to satisfy ERCOT Planning Guide Section 4.1.1.2(1)(d), Reliability Performance Criteria, contingencies are for the loss of a single transformer followed by a single transmission element or common tower outage, respectively.

RPG considered project overviews during meetings in August 2024 and November 2025. Between August 2024 and November 2025, ERCOT staff presented scope and status updates at RPG meetings in August, September, July, August, October and November. Pursuant to paragraph (2) of Protocol Section 3.11.4.9, Regional Planning Group Acceptance and ERCOT Endorsement, ERCOT presented the Tier 1 project to the Technical Advisory Committee (TAC) for review and comment, and on November 19, 2025, TAC unanimously endorsed the project as recommended by ERCOT. Pursuant to

paragraph (1)(a) of Protocol Section 3.11.4.3, Categorization of Proposed Transmission Projects, projects with an estimated capital cost of \$100 million or greater are Tier 1 projects, for which Protocol Section 3.11.4.7(2) requires endorsement by the Board. Pursuant to Section 3.11.4.9, ERCOT's endorsement of a Tier 1 project is obtained upon affirmative vote of the Board.

ERCOT's assessment of the Sub-Synchronous Resonance (SSR) of existing facilities in Midland and Martin Counties in the Far West Weather Zone, conducted pursuant to Protocol Section 3.22.1.3, Transmission Project Assessment, yielded no adverse SSR impacts to the existing and planned generation resources at the time of the study. Results of the congestion analysis ERCOT conducted pursuant to Planning Guide Section 3.1.3, Project Evaluation, indicated no significant new congestion in the area with the addition of the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project (Option 1).

The report describing the ERCOT Independent Review of the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project (Option 1), including ERCOT staff's recommendation, is included as Attachment A.

Key Factors Influencing Issue:

1. ERCOT System improvements are needed to meet reliability planning criteria due to load growth in the Far West Weather Zone.
2. ERCOT staff found the recommended set of improvements to be the most efficient solution for meeting the planning reliability criteria, addressing thermal overloads and facilitating future transmission expansion for future load in the area.
3. Protocol Section 3.11.4.7 requires Board endorsement of a Tier 1 project, which is a project with an estimated capital cost of \$100 million or greater pursuant to Protocol Section 3.11.4.3(1)(a).
4. TAC voted unanimously to endorse the Tier 1 Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Regional Planning Group (RPG) Project (Option 1), as recommended by ERCOT, on November 19, 2025.

Conclusion/Recommendation:

ERCOT staff recommends that the Board endorse the need for the Tier 1 Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line RPG Project (Option 1), which ERCOT staff has independently reviewed, and which TAC has voted unanimously to endorse based on North American Electric Reliability Corporation (NERC) and ERCOT reliability planning criteria.



ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC.

BOARD OF DIRECTORS RESOLUTION

WHEREAS, pursuant to Section 3.11.4.3(1)(a) of the Electric Reliability Council of Texas, Inc. (ERCOT) Protocols, projects with an estimated capital cost of \$100 million or greater are Tier 1 projects, for which Section 3.11.4.7 requires endorsement by the ERCOT Board of Directors (Board); and

WHEREAS, after due consideration of the alternatives, the Board of Directors (Board) of Electric Reliability Council of Texas, Inc. (ERCOT) deems it desirable and in the best interest of ERCOT to accept ERCOT staff's recommendation to endorse the need for the Tier 1 Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Regional Planning Group Project (Option 1), which ERCOT staff has independently reviewed and which the Technical Advisory Committee (TAC) has voted unanimously to endorse based on North American Electric Reliability Corporation (NERC) and ERCOT reliability planning criteria;

THEREFORE, BE IT RESOLVED, that ERCOT is hereby authorized and approved to endorse the need for the Tier 1 Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Regional Planning Group Project (Option 1), which ERCOT staff has independently reviewed, and which TAC has voted unanimously to endorse based on NERC and ERCOT reliability planning criteria.

CORPORATE SECRETARY'S CERTIFICATE

I, Brandon Gleason, Assistant Corporate Secretary of ERCOT, do hereby certify that, at its _____ meeting, the Board passed a motion approving the above Resolution by _____.

IN WITNESS WHEREOF, I have hereunto set my hand this ____ day of _____, 2025.

Brandon Gleason

Assistant Corporate Secretary



ERCOT Independent Review of the Oncor Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project

Document Revisions

Date	Version	Description	Author(s)
11/19/2025	1.0	Final	Ben Richardson
		Reviewed by	Robert Golen, Prabhu Gnanam

Executive Summary

Oncor submitted the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Project in June 2024. Oncor proposed this project to address North American Electric Reliability Corporation (NERC) Reliability Standard TPL-001-5.1 and ERCOT Planning Guide criteria thermal overloads and voltage violations in Martin and Midland Counties due to new loads confirmed by Transmission Service Provider (TSP) Attestation Letters.

The Oncor proposed project was estimated to cost approximately \$110.62 million and was classified as a Tier 1 project per ERCOT Protocol Section 3.11.4.3. The proposed project will require a Certificate of Convenience and Necessity (CCN) application.

ERCOT performed an Independent Review, identified reliability issues (thermal overloads identified in Oncor's project submission) and evaluated three different transmission project options.

The ERCOT Independent Review (EIR) evaluated three different transmission project options. Based on the study results described in Sections 5 and 6 of this report, ERCOT recommends the following option (Option 1) to address the reliability issues mentioned. Option 1 consists of the following:

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate) 345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;
- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0 mile) right of way (ROW), installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;
- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;
- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-

circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and

- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.

The cost estimate for Option 1 is approximately \$110.62 million and is classified as a Tier 1 project per ERCOT Protocol Section 3.11.4.3(a). One or more CCN applications will be required for the new 345-kV double-circuit transmission line from Connell to Rockhound due to an approximately 13.0-mile of new ROW. The expected in-service date (ISD) of the project is December 2026.

Table of Contents

Executive Summary	ii
1 Introduction	1
2 Study Assumptions and Methodology	2
2.1 Study Assumptions for Reliability Analysis	2
2.1.1 Steady-State Study Base Case	2
2.1.2 Transmission Topology	2
2.1.3 Generation	3
2.1.4 Loads	4
2.2 Long-Term Load-Serving Capability Assessment	4
2.3 Maintenance Outage Scenario	4
2.4 Study Assumptions for Economic Study	4
2.5 Methodology	5
2.5.1 Contingencies and Criteria	5
2.5.2 Study Tools	6
3 Project Need	6
4 Description of Project Options	7
5 Option Evaluations	10
5.1 Results of Reliability Analysis	10
5.2 Short-Listed Options	11
5.3 Long-Term Load-Serving Capability Assessment	12
5.4 Planned Maintenance Outage Evaluation	12
5.5 Cost Estimate and Feasibility Assessment	13
6 Comparison of Options	13
7 Additional Analysis and Assessment	14
7.1 Generation Addition Sensitivity Analysis	14
7.2 Load Scaling Sensitivity Analysis	14
7.3 Congestion Analysis	14

7.4	Sub-synchronous Resonance (SSR) Assessment	15
8	Conclusion	15
	Appendix A	17

1 Introduction

In June 2024, Oncor submitted the Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project for Regional Planning Group (RPG) to address North American Electric Reliability Corporation (NERC) Reliability Standard TPL-001-5.1 and ERCOT Planning Guide criteria thermal overloads and voltage violations in Martin and Midland Counties due to new loads confirmed by Transmission Service Provider (TSP) Attestation Letters. The proposed project is in the Far West Weather Zone in Martin and Midland Counties.

The Oncor proposed project was estimated to cost approximately \$110.62 million and was classified as a Tier 1 project per ERCOT Protocol Section 3.11.4.3. The proposed project will require a Certificate of Convenience and Necessity (CCN) application for an approximately 13.0-mile right of way (ROW). The expected in-service date (ISD) of the project is December 2026.

ERCOT conducted an Independent Review for this RPG project to identify any reliability needs in the area and evaluate various transmission upgrade options. This report describes the study assumptions, methodology, and the results of the ERCOT Independent Review (EIR) for the project.



Figure 1.1: Map of Transmission System in Study Area

2 Study Assumptions and Methodology

ERCOT performed studies under various system conditions to identify potential reliability issues and corresponding transmission upgrades that will be necessary to support the proposed Connell 345/138-kV Switch and Connell to Rockhound 345-kV Double-Circuit Line Project. This section describes the study assumptions and criteria used to conduct this independent study.

2.1 Study Assumptions for Reliability Analysis

The project is in the Far West Weather Zone in Martin and Midland Counties.

2.1.1 Steady-State Study Base Case

A Final 2023 Regional Transmission Plan (RTP) case, published on the Market Information System (MIS) on December 20, 2023, was used as the reference case for this study and the 2026 study year was selected to create the base case. The steady-state study base case was constructed by updating transmission, generation, and loads of the following 2026 Summer peak load case¹:

- Summer Peak Case: 2023RTP_2026_SUM_12222023.

2.1.2 Transmission Topology

Transmission projects within the study area with ISDs by June 1, 2026, were added to the study base case. The ERCOT Transmission Project Information and Tracking (TPIT)² report posted in June 2024 was used as a reference. The added TPIT projects are listed in Table 2.1.

Table 2.1: List of Transmission Projects Added to the Study Base Case

TPIT	Project Name	Tier	Project ISD	County
72007	Ranger Camp 345/138/69 kV Switch	Tier 1	In-service	Mitchell
78374	Rockhound 345/138 kV Switch	Tier 3	In-service	Midland Martin
73368	Grey Well Draw – Buffalo 138 kV Second Circuit	Tier 3	In-service	Midland Martin
76705	Prairieland 345/138 kV Switch and 138 kV Line	Tier 2	In-service	Glasscock
80913	Sloan 138 kV Switch	Tier 4	5/1/2025	Midland
71960	Upgrade Grady – Expanse 138 kV Line	Tier 4	12/1/2024	Martin
81223	Range Rider 138 kV Switch	Tier 1	12/1/2025	Mitchell
72009	Cattleman 345/138 kV Switch	Tier 1	12/1/2025	Mitchell
87861	Range Rider – Ranger Camp 138 kV Double-Circuit Line	Tier 1	12/1/2025	Mitchell
81274	Ranger Camp – Cattleman 345 kV Double-Circuit Line	Tier 1	12/1/2025	Mitchell
81270	Construct the new Prong Moss 345 kV switch	Tier 1	12/1/2025	Howard
81232	Cattleman – Bitter Creek/Champion Creek 345 kV Reroute	Tier 1	12/1/2026	Mitchell
81410	Reiter Switch Synchronous Condenser	Tier 1	1/1/2027	Ector

¹ 2023 Regional Transmission Plan Postings: <https://mis.ercot.com/secure/data-products/grid/regional-planning?id=pg3-3200-m>

² TPIT Report: <https://www.ercot.com/gridinfo/sysplan/index.html>

TPIT	Project Name	Tier	Project ISD	County
81415	Tonkawa Switch Synchronous Condenser	Tier 1	1/1/2027	Scurry
80870	Bakersfield Dynamic Reactive Substation Upgrade	Tier 1	5/1/2027	Pecos
81299	Ranger Camp – Prong Moss 345 kV Line Rebuild	Tier 1	5/1/2027	Mitchell Howard
81227	Cattleman – Gasconada 345 kV Reroute	Tier 1	6/1/2027	Mitchell
87633	WETT Buck Canyon Synchronous Condenser	Tier 1	7/1/2027	Borden
87635	WETT Pitchfork Synchronous Condenser	Tier 1	9/1/2027	Dickens
87629	WETT Binturong Synchronous Condenser	Tier 1	11/1/2027	Glasscock
72011	Tonkawa – Ranger Camp 345 kV Line Rebuild	Tier 1	12/1/2027	Mitchell Scurry
81296	Prong Moss – Rockhound 345 kV Line Rebuild	Tier 1	12/1/2027	Mitchell Howard
81175	Salt Flat Road 138 kV Switch and Salt Flat Road - Barr Ranch - Reiter 138 kV Second Circuit	Tier 3	12/1/2025	Ector, Midland
81305	Expanse - Vealmoor 138 kV Line Rebuild (Tredway 138-kV Switch and Expanse to Tredway 138-kV 2nd Circuit)	Tier 1	12/1/2025	Borden, Howard, Martin

The transmission projects, listed in Table 2.2, identified in the 2023 RTP as placeholder projects in the study area and were not approved by RPG were removed from the study base case.

Table 2.2: List of Transmission Project Removed from the Study Base Case

RTP Project ID	Project Name	County
2021-FW4	Rio Pecos – Rankin – Texon Tap – Atlantic Best Tap – Kemper Tap – Big Lake 69-kV to 138-kV Line Conversion	Pecos, Upton, Reagan
2021-FW19	Morgan Creek SES - Longshore Switch 345-kV Line Upgrade	Mitchell, Howard
2021-FW20	Lamesa – Key Sub – Gail Sub – Willow Valley Switch 138-kV Line Upgrade	Dawson, Borden
2023-FW4	Buzzard Draw Switch – Koch Tap – Vealmoor 138-kV Line Upgrade	Howard
2023-FW9	East Stiles 138-kV Cap Bank Addition	Reagon
2023-FW13	Bulldog – Elbow – Eiland – Einstein – Carterville 138-kV Line Upgrade	Howard, Midland
2022-WFW1	Twin Buttes – Hargrove – Pumpjack – Jerry – Russek Street – Big Lake 138-kV line Upgrade	Tom Green, Irion, Reagan

2.1.3 Generation

Based on the September 2024 Generator Interconnection Status (GIS)³ report posted on the ERCOT website in October 2024, there were no generators that met Planning Guide Section 6.9(1) conditions with Commercial Operations Date (COD) prior to June 1, 2026.

The status of each unit that was projected to be either indefinitely mothballed or retired at the time of the study was reviewed. The units listed in Table 2.3 were opened (turned off) in the study base case to reflect their mothballed/retired status.

³ GIS Report: <https://www.ercot.com/mp/data-products/data-product-details?id=PG7-200-ER>

Table 2.3: List of Generation Opened to Reflect Mothballed/Retired/Forced Outage Status

Bus No	Unit Name	Max Capacity (~MW)	Weather Zone
150711	STEA_STEAM_1	17.5	NORTH_CE
130121	SGM_SIGNALMT	7.5	FAR_WEST

Generation listed in Table 2.4 were closed (turned on) in the study base case to reflect the change in their Generation Resource as this resource is returning to year-round service.

Table 2.4: List of Generation Closed to Reflect Returning to Service Status

Bus No	Unit Name	Max Capacity (~MW)	Weather Zone
151361	CHSMGRD_BES1	101.7	NORTH_CE

2.1.4 Loads

Loads in the ERCOT system were consistent with 2023 RTP. This project is driven by confirmed by TSP Attestation Letters. Load was adjusted outside the West and Far West Weather Zones to maintain the minimum reserve requirements consistent with the 2023 RTP methodology.

2.2 Long-Term Load-Serving Capability Assessment

ERCOT performed a long-term load-serving capability assessment to compare the performance of the study options.

Incremental load serving capability was evaluated to assess the long-term load-serving capability. The loads in the study area were increased (customer designated as non-scalable remained at the same level as in the study base case), and conforming loads outside of West and Far West Weather Zones were decreased to balance power.

2.3 Maintenance Outage Scenario

ERCOT performed a planned maintenance outage evaluation based on historic off-peak system load. Conforming loads in the West Weather Zone was scaled down to 88.4% of the summer peak load to create the off-peak case. Loads designated as non-scalable remained at the same level as in the study base case. Next, ERCOT Planning Guide Section 4.1.1.8 Maintenance Outage Reliability Criteria was evaluated to identify and address violations.

2.4 Study Assumptions for Economic Study

An economic study was performed to further evaluate the study options and to identify any new congestion in the study area with the addition of the respective transmission upgrade options.

The 2023 RTP 2028 economic case was updated based on the February 2025 GIS⁴ report for generation updates and the February 2025 TPIT⁵ report for transmission updates to conduct the economic study. The 2028 study year was selected as it's the future year case currently available.

New transmission project additions are listed in Table A.1 in Appendix A of this document.

New generation additions listed in Table A.2 in Appendix A of this document were added to the economic base case and all generation listed in Table 2.3 were opened (turned off) in the study base case to reflect their mothballed/retired status. Furthermore, generation listed in Table 2.4 was removed from seasonal settings in the study base case as this resource is returned to year-round service.

2.5 Methodology

This section lists the Contingencies and Criteria used for project review along with tools used to perform the various analyses.

2.5.1 Contingencies and Criteria

The reliability assessments were performed based on NERC Reliability Standard TPL-001-5.1, ERCOT Protocols, and ERCOT Planning Criteria.⁶

Contingencies⁷ were updated based on the changes made to the topology as described in Section 2.1 of this document. The following steady-state contingencies were simulated for the study region:

- P0 (System Intact);
- P1, P2-1, P7 (N-1 conditions);
- P2-2, P2-3, P4, and P5 (345-kV only);
- P3: G-1+N-1 (G-1: generation outage) {Cedar Bayou G2, Exxon G4, Baytown Energy G1 and Diamon Shamrock Battleground G3}; and
- P6-2: X-1+N-1 (X-1: 345/138-kV transformer only) {Cedar Bayou A3, Greens Bayou A1, Bellaire A4, PH Robinson A4 and Jordan A1}.

All 60-kV and above buses, transmission lines, and transformers in the study region were monitored (excluding generator step-up transformers) and the following thermal and voltage limits were enforced:

- Thermal limits
 - Rate A (normal rating) for pre-contingency conditions; and
 - Rate B (emergency rating) for post-contingency conditions.
- Voltage limits
 - Voltages exceeding pre-contingency and post-contingency limits; and
 - Voltage deviations exceeding 8% on non-radial load buses.

⁴ GIS Report: <https://www.ercot.com/mp/data-products/data-product-details?id=PG7-200-ER>

⁵ TPIT Report: <https://www.ercot.com/gridinfo/planning>

⁶ ERCOT Planning Criteria: <http://www.ercot.com/mktrules/guides/planning/current>

⁷ Details of each event and contingency category is defined in the NERC Reliability Standard TPL-001-5.1

2.5.2 Study Tools

ERCOT utilized the following software tools to perform this independent study:

- PowerWorld Simulator version 23 for Security Constrained Optimal Power Flow (SCOPF) and steady-state contingency analysis; and
- UPLAN version 12.3.0.30786 to perform congestion analysis.

3 Project Need

Steady-state reliability analysis was performed in accordance with NERC TPL-001-5.1 and ERCOT Planning Criteria described in Section 2 of this document. This analysis indicated thermal overloads in Midland County under NERC P6-2(X-1+N-1). These issues are summarized in Table 3.1 and visually illustrated in Figure 3.1. Detailed thermal overloads are listed in Table 3.2.

Table 3.1: Reliability Issues Seen Under NERC TPL-001-5.1 and ERCOT Planning Criteria in the Study Area

NERC Contingency Category	Voltage Violations	Thermal Overloads	Unsolved Power Flow
P0: N-0	None	None	None
P1, P2-1, P7: N-1	None	None	None
P3: G-1+N-1	None	None	None
P6-2: X-1+N-1	None	2	None

Table 3.2: Thermal Overloads Observed in the Study Area

NERC Contingency Category	Overloaded Element	Voltage Level (kV)	Length (~miles)	Max Loading (%)
P6-2	Rockhound 345/138-kV Auto #1	345/138	0	132
P6-2	Rockhound 345/138-kV Auto #2	345/138	0	132




Figure 3.1: Study Area Map Showing Project Need Seen by ERCOT

4 Description of Project Options

ERCOT evaluated three system improvement options to address the reliability violations observed in the study base case in the study area.

Option 1 (Oncor proposed solution) consists of the following:

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate) 345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;
- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0 mile) ROW, installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;
- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion

with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;

- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and
- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.



Figure 4.1: Map of Option 1

Option 2 consists of the following:

- Add a new 600 MVA (nameplate) 345/138-kV transformer to the existing Rockhound substation.




Figure 4.2: Map of Option 2

Option 3 consists of the following:

- Install 6 capacitor banks (18.4 MVAR each) to a feasible location near the Expanse 138-kV substation; and
- Install 6 capacitor banks (18.4 MVAR each) to a feasible location near the Lazy Ranch 138-kV substation.




Figure 4.3: Map of Option 3

5 Option Evaluations

ERCOT performed a reliability analysis, planned maintenance outage evaluation and long-term load-serving capability to evaluate the options and to identify any reliability impacts of the options in the study area. This section details these studies and their results and compares the options.

5.1 Results of Reliability Analysis


All three options were evaluated based on the contingencies described in Section 2 of this report. Option 3 observed thermal overloads under X-1+N-1 contingency conditions. No reliability criteria violations were identified for Option 1 and Option 2, as shown in Table 5.1.

Table 5.1: Results of Initial Reliability Assessment of All Three Options

Option	Unsolved Power Flow	N-1		X-1+N-1		G-1+N-1	
		Thermal Overload	Voltage Violation	Thermal Overload	Voltage Violation	Thermal Overload	Voltage Violation
1	None	None	None	None	None	None	None
2	None	None	None	None	None	None	None
3	None	None	None	2	None	None	None

5.2 Short-Listed Options

Based on the results shown in Section 5.1, Option 1 and Option 2 were selected as short-listed options for further evaluations. These two short-listed options are illustrated in Figures 5.1 and 5.2

**Figure 5.1: Map of Option 1**




Figure 5.2: Map of Option 2

5.3 Long-Term Load-Serving Capability Assessment

ERCOT conducted a long-term load-serving capability assessment for the two short-listed options to compare the relative performance.

The results show that both short-listed options provided additional long-term load-serving capability, with Option 1 providing the most incremental capability. These results are shown in Table 5.2

Table 5.2: Results of Long-Term Load-Serving Capability Assessment of the Two Short-Listed Options

Option	Incremental Load-Serving Capability (~MW)
1	80
2	43

5.4 Planned Maintenance Outage Evaluation

Using the P1, P2.1, and P7 contingencies based on the review of the system topology of the area, ERCOT conducted an N-2 contingency analysis to represent system element outage(s) under planned maintenance condition (N-1-1) in the area. Then, each N-2 violation was run as an N-1-1 contingency scenario, with system adjustments between the contingencies. The transmission elements in the study area were monitored in the maintenance outage evaluation.

As shown in Table 5.3, the results of this planned maintenance assessment indicate no reliability violations for Option 1 or Option 2.

Table 5.3: Results of Planned Maintenance Outage Evaluation of the Two Short-Listed Options

Option	Voltage Violations	Thermal Violations	Unsolved Power Flow
1	None	None	None
2	None	None	None

5.5 Cost Estimate and Feasibility Assessment

TSPs performed feasibility assessments and provided final cost estimates for the two short-listed options. Table 5.4 summarizes the cost estimate, estimated mileage of CCN required, and option feasibility for the two short-listed options.

Table 5.4: Cost Estimates and Feasibility for the Two Short-Listed Options

Option	Cost Estimates (~\$M)	CCN Required (~miles)	Feasible
1	110.62	Yes (13.0)	Yes
2	None	None	No

6 Comparison of Options

Based on the results from Option Evaluations in Section 5, the two short-listed options are summarized in Table 6.1.

Table 6.1: Comparison of the Two Short-Listed Options

	Option 1	Option 2
Meets ERCOT and NERC Reliability Criteria	Yes	Yes
Improves Long-Term Load-Serving Capability	Yes	Yes
CCN Required (~miles)	Yes (13.0)	No
Construction Feasibility ⁸	Yes	No
Capital Cost Estimates ⁹ (~\$M)	110.62	N/A

ERCOT recommends Option 1 as the preferred option to address the reliability need in the study area based on the following considerations:

- Option 1 addresses the project need in the study area;
- Option 1 meets ERCOT and NERC Reliability criteria; and
- Option 1 improves long-term load-serving capability.

⁸ The construction feasibility was based on TSP(s) assessment.

⁹ The cost estimates were provided by the TSPs.

7 Additional Analysis and Assessment

The recommended option (Option 1, with a cost estimate of approximately \$110.62 million) is categorized as a Tier 1 project, pursuant to ERCOT Protocol 3.11.4.3(1)(a). ERCOT performed generation and load sensitivity studies to identify the recommended option performance, as required under Planning Guide Section 3.1.3(4). Additionally, a Sub-synchronous Resonance (SSR) Assessment was performed.

7.1 Generation Addition Sensitivity Analysis

ERCOT performed a generation addition sensitivity analysis based on Planning Guide Section 3.1.3(4)(a).

Based on a review of the September 2024 GIS¹⁰ report, no units were found within the study area that could have an impact on the identified reliability issues.

Table 7.1: List of Units that Could Have Impact on the Identified Reliability Issues

GINR	Unit Name	Fuel Type	Max Capacity (~MW)	County
	NONE			

7.2 Load Scaling Sensitivity Analysis

Planning Guide Section 3.1.3(4)(b) requires an evaluation of the potential impact of load scaling on the criteria violations seen in this EIR. Before 2024, ERCOT RTP adopted the methodology of developing four sets of summer peak cases with each case representing one study region for each study year. For each summer peak case, the loads outside of the study region may be scaled down from the respective non-coincident summer peak levels to maintain a certain reserve requirement. This methodology may cause potential impact of load scaling on the criteria violations.

The Power Transfer Distribution Factors (PTDFs) of overloaded elements with respect to the load transfer for each Weather Zone (excluding West and Far West) were calculated using PowerWorld Simulator. The PTDFs were 2.5% or less for each of the overloaded elements, i.e., they were not significant enough to have an impact on the overloaded element. ERCOT concluded that the load scaling used to develop the base case in this study did not have a material impact on the project need, which was primarily driven by thermal overloads in Midland County.

7.3 Congestion Analysis

ERCOT conducted a congestion analysis to identify any potential impact on system congestion related to the addition of the recommend option (Option 1) using the 2023 RTP 2028 economic study case.

¹⁰ GIS Report: <https://www.ercot.com/mp/data-products/data-product-details?id=PG7-200-ER>

The results of the congestion analysis indicated no significant congestion in the area due to the addition of the recommended transmission upgrades of Option 1.

7.4 Sub-synchronous Resonance (SSR) Assessment

Pursuant to Protocol Section 3.22.1.3(2), ERCOT conducted a SSR screening for the recommended option (Option 1) and found no adverse SSR impacts to the existing and planned generation resources in the study area.

8 Conclusion

ERCOT evaluated three transmission upgrade options to resolve the thermal overloads identified in the study area. Based on the results of the independent review, ERCOT recommends Option 1 as the preferred solution because it addresses the project need in the study area, meets ERCOT and NERC Reliability criteria and improves long-term load-serving capability.

Option 1 (Oncor proposed solution) consists of the following:

- Construct a new Connell 345/138-kV switching station approximately 1.0 mile west of existing Oncor Glass Ranch Switch, with two new 600 MVA (nameplate) 345/138-kV transformers, in a 6-breaker 345-kV breaker-and-a-half bus arrangement and a 10-breaker 138-kV breaker-and-a-half bus arrangement, with all 345-kV equipment will be rating at least 2988 MVA and 138-kV at least 765 MVA;
- Construct two new Connell to Rockhound 345-kV lines, with conductors rated to at least 2988 MVA, in a new (estimated 13.0 mile) ROW, installed on new, common double-circuit towers;
- Install two new 345-kV circuit breakers at Oncor's existing Rockhound 345-kV Switch, rated at least 2988 MVA;
- Install two new 138-kV circuit breakers at Oncor's existing Sale Ranch 138-kV Switch, rated at least 765 MVA;
- Disconnect Oncor's existing Tall City to Sale Ranch 138-kV line at structure 1/9;
- Rebuild 9.0-mile portion of Oncor's existing single circuit 19.2-mile Sale Ranch to Glass Ranch to Tall City 138-kV line from Sale Ranch to existing 1/9 Structure and replace 9.0-mile portion with two new conductors, rated to at least 614 MVA, installed on new, common double-circuit towers;
- Construct two new Connell Switch to 1/9 structure 138-kV lines, with conductors rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed on new, common double-circuit towers configured to create a Connell Switch to Sale Ranch 138-kV double-circuit line;
- Construct a new single Connell Switch to 1/9 structure 138-kV line, with conductor rated to at least 614 MVA, in a new (estimated 0.1-mile) ROW, installed in one position on new double-circuit towers leaving one position vacant and configured to create a new Connell Switch to Tall City 138-kV line; and

- Reconfigure Oncor's existing Red Sand 138-kV POD to be connected to the south circuit on the new Connell to Sale Ranch 138-kV double circuit line.



Figure 8.1: Map of Option 1

The cost estimate for this project is approximately \$110.62 million and is classified as Tier 1 project per ERCOT Protocol Section 3.11.4.3(1)(a). The expected ISD of this project is December 2026.

CCN applications will be required for the new 345-kV double-circuit transmission line from Connell to Rockhound due to an approximately 13.0-mile of new ROW.

Appendix A


Table A.1: List of Transmission Projects added to the Economic Base Case

TPIT No	Project Name	Tier	Project ISD	County
80404	Reroute East to Rodgers 69-kV line to create East to Rayburn 69-kV line to accommodate the TXDOT SH6 project	Tier 4	Jun-26	Brazos
80424	Rebuild / Reconductor Dansby to Business Park 69-kV for Rail Spur	Tier 4	Jun-26	Brazos
80342	BEPC_TPIT80342_Hilltoplakes_Secondauto	Tier 4	Mar-27	Leon
80340	BEPC_TPIT80340_Keithsw_lola	Tier 4	Mar-27	Grimes
80346	BEPC_TPIT80346_Sandysw_Crutchfield	Tier 4	Mar-29	Grimes
80373	BEPC_TPIT80373_lola_Crutchfield	Tier 4	Mar-29	Grimes

Table A.2: List of Generation Added to the Economic Base Case Based on February 2025 GIS Report

GINR	Project Name	Fuel	Project COD	Max Capacity (~MW)	County
23INR0079	Chillingham Storage	OTH	5/1/2025	153.9	Bell
23INR0249	Limewood Solar	SOL	12/31/2025	204.6	Bell
23INR0344	Hermes Solar	SOL	9/30/2025	100.4	Bell
23INR0469	Big Elm Storage	OTH	8/15/2026	100.8	Bell
24INR0166	Stillhouse Solar	SOL	9/1/2025	210.8	Bell
24INR0365	Hermes Storage	OTH	9/30/2025	100.4	Bell
23INR0079	Chillingham Storage	OTH	5/1/2025	153.9	Bell
21INR0517	Tidwell Prairie Storage 1	OTH	07/31/2025	204.0	Robertson
22INR0356	Jungmann Solar	SOL	06/30/2025	40.2	Milam
22INR0511	Gransolar Texas One	SOL	06/30/2025	50.8	Milam
23INR0235	Hoyte Solar	SOL	12/15/2026	206.8	Milam
24INR0031	Stoneridge Solar	SOL	09/04/2025	201.6	Milam
26INR0023	Leon Solar Park	SOL	07/01/2026	210.1	Leon

Table A.3: Project Related Document

No	Document Name	Attachment
1	Oncor Connell 345/138-kV Switch and Connell – Rockhound 345-kV Double-Circuit Line Project	 Oncor Connell - Rockhound RPG Project