



## Status Update: Evaluation of Voltage Ride Through Requirements Proposed by ERCOT


Sun Wook Kang  
Dynamic Studies, ERCOT

LLWG, December 11, 2025

# Background and Objectives

- Background

- As presented at the October LLWG meeting, [ERCOT's study results](#) indicated that significant load reduction could occur under various fault conditions if Large Electronic Loads (LELs) are unable to ride through faults
- ERCOT submitted [NOGRR282](#), proposing operating requirements for LELs to ride through faults and support overall system reliability
- Based on the scope introduced at the [September LLWG](#), ERCOT is conducting additional study on the proposed VRT requirements and will provide status update at this meeting




- Objectives

- Assess load reduction for LELs with VRT capability and evaluate system response by varying momentary-cessation thresholds and LEL reconnection times, in support of NOGRR282

# Assumption and Methodology

- As presented at the October LLWG, the study base case and area are the same as those used to assess the transmission-upgrade effectiveness in reducing load loss
- Dynamic Model Updates for LELs within the study region
  - Replaced the LEL dynamic models with the enhanced User Defined Model (UDM)\*
  - The UDM, which incorporates momentary cessation and reconnection settings with time delay during and after a fault, is considered adequate for assessing the proposed VRT requirements

\* The EV model developed by EPRI has been enhanced to include additional features based on ERCOT's feedback. This model is available as a user-defined model (UDM) in PSS/E version 34 and 35. Thanks to significant and continued support from Dr. Sreenivasachar ([ksreenivasachar@iso-ne.com](mailto:ksreenivasachar@iso-ne.com)) in developing the UDM.



Source: [EPRI presentation at the July LLWG meeting](#)

# Key Questions and Scenario Studied



- Q1: Do any LELs trip under the proposed voltage ride-through capability?
- Q2: Should temporary current blocking (i.e., momentary cessation from 100% to 0%) be permitted during shallow voltage dips (e.g., down to 0.8 pu)?
- Q3 (**Under Study**): What are the appropriate reconnection times after the fault is cleared




## Scenarios Considered

- **Assessment of voltage threshold sensitivity for momentary cessation (MC)**
  - Case: Study base case
    - Scenario 1: MC voltage threshold at 0.8 pu
    - Scenario 2: MC voltage threshold at 0.5 pu
    - Scenario 3: MC voltage threshold at 0.2 pu
- **Assessment of reconnection time sensitivity after fault cleared (**Under Study**)**
  - Case 1: Study base case
  - Case 2: Lower system inertia condition (~174 GW-s)
  - Case 3: Increased LEL condition (additional total 4 GW at selected critical locations)

# Results for Question #1: LEL Equipped with Voltage Ride-Through Capability

- Do any LELs trip with the proposed voltage ride-through capability?



*Example: LEL behavior with assumed VRT capability*

- Key critical faults were tested, including over 30 representative events identified in the [transmission effectiveness study](#) presented at the October 2025 LLWG.
- Results showed that all LELs with NOGRR282-like ride-through capability rode through the critical faults


## Results for Question #2: Temporary Current Blocking

- Should temporary current blocking (i.e., momentary cessation) be allowed during shallow voltage dips?
  - Sensitivity analysis was performed for the temporary current blocking thresholds of voltage 0.8 pu, 0.5 pu, and 0.2 pu
  - It is assumed that LELs that do not go into full current blocking reduced consumption proportional to the voltage sag

**Total Load in Momentary Cessation (MC) under Certain Critical Fault**

Voltage Threshold	0.8 pu	0.5 pu	0.2 pu
LEL (MW) in MC	7,251	3,100	1,750


Note: A complete reduction to 0 MW was assumed immediately when voltage fell below the momentary-cessation thresholds.




- Dots are approximate, high-level future LELs locations assumed in the study
- This is a hypothetical example of wide-spread voltage dip. It is not relevant to this study or reflective of actual system conditions

## Results for Question #2: Temporary Current Blocking (continued)

Frequency Response with Momentary Cessation at Varying Voltage Threshold



Voltage Response with Momentary Cessation at Varying Voltage Threshold



- Better stable response (e.g. frequency swing) were observed at the lower voltage thresholds (i.e., 0.5 and 0.2 pu)
- No significant difference in voltage response was observed
- The study results support the operating requirements proposed in NOGRR282, recommending LEL to draw current from the grid at the deeper voltage dips

### Summary of MC Sensitivity Study Results

	MC=0.8	MC=0.5	MC=0.2
Voltage	Good	Good	Good
Frequency	Worse	Good	Good

## Key Findings

- ERCOT conducted a study to assess proposed VRT requirements by evaluating system response across different voltage thresholds that trigger LEL momentary cessation
- Results indicate more stable system performance under lower momentary-cessation voltage thresholds (0.5 pu and 0.2 pu)
- Findings suggest LELs should continue drawing current under deeper voltage dips, where feasible
- The study results supports the momentary-cessation voltage threshold (i.e., 0.5 pu) and the proportional load reduction relative to voltage sag, as proposed in NOGRR282



## Next Steps

- ERCOT is currently conducting additional study for appropriate LEL reconnection time and will provide status update at the future LLWG meeting

# Questions?



Tareq Hossen, [tareq.hossen@ercot.com](mailto:tareq.hossen@ercot.com)  
Christian Danielson, [christian.danielson@ercot.com](mailto:christian.danielson@ercot.com)  
Sun Wook Kang, [Sunwook.Kang@ercot.com](mailto:Sunwook.Kang@ercot.com)