



Status Update: Evaluation of Voltage Ride Through Requirements Proposed by ERCOT

Sun Wook Kang
Dynamic Studies, ERCOT

LLWG, January 22, 2026


Background and Objectives

- Background
 - As presented at the [December 2025 LLWG](#) meeting, ERCOT assessed different voltage thresholds for momentary cessation
 - Lower cessation thresholds (0.5 pu & 0.2 pu) → relatively better frequency response
 - Supports continued current draw during deeper voltage sags
 - Aligns with [NOGRR282](#) proposed requirements
 - Additionally, ERCOT has conducted assessment on LEL reconnection time and would like to share the results in this presentation based on the scope introduced at the [September 2025 LLWG](#)
- Objectives
 - Assess system response by varying LEL reconnection times, in support of NOGRR282

Assumption and Methodology

- As presented at the December LLWG, the study base case and area are the same as those used to assess the transmission-upgrade effectiveness in reducing load loss
- Dynamic Model Updates for LELs within the study region
 - Replaced the LEL dynamic models with the enhanced User Defined Model (UDM)*
 - The UDM, which incorporates momentary cessation and reconnection settings with time delay during and after a fault, is considered adequate for assessing the proposed VRT requirements

* The model and associated documentations are available at the NERC LMWG resources website ([link](#))



Source: [EPRI presentation at the July LLWG meeting](#)

Assessment of Reconnection Time and Scenario Considered

- Scenarios Evaluated:
 - Scenario 1: Study base case* (~201 GW-s)
 - Scenario 2: Lower system inertia condition (~174 GW-s, About 22 synchronous generators were gneted)
 - Scenario 3: Increased LEL condition (additional total 4 GW at selected critical locations)

* Note: As presented in the [September LLWG meeting](#), approximately 15.2 GW of LELs assumed in the study base case
- Compared the relative system responses for LEL reconnection times of 1 second and 2 seconds:
 - Frequency settling
 - Trends in rate of change of frequency (RoCoF)
 - Voltage settling
 - Any major load or generator trips during the reconnections

Overview of Study Results




	Scenario 1 (Study Base Case)		Scenario 2 (Lower Inertia)		Scenario 3 (Higher LEL)	
Reconnection Time	R1*	R2**	R1	R2	R1	R2
Frequency Settling	Better	Better	Better	Better	Good	Good
RoCoF Trends	Good	Better	Good	Better	Good	Better
Voltage Settling	Good	Good	Good	Good	Good	Good

* R1: LEL Reconnection within 1 second

** R2: LEL Reconnection within 2 seconds

Results of Reconnection Time Test: Study Base Case


- Scenario 1: Study Base Case




Results of Reconnection Time Test: Study Base Case (Continued)

- Scenario 1: Study Base Case

RoCoF Trends Associated with Reconnection Time





Zoomed-In RoCoF Trends During the Post-Fault Period



Results of Reconnection Time Test: Study Base Case (Continued)

- Scenario 1: Study Base Case



Key Findings

- ERCOT conducted a study for the planning horizon to evaluate the system response under multiple scenarios with varying LEL reconnection times during the post-fault recovery period
- Across the scenario evaluated, the results indicate better system performance when LELs were reconnected within 2 seconds after voltage recovery

Questions?




Tareq Hossen, tareq.hossen@ercot.com
Christian Danielson, christian.danielson@ercot.com
Sun Wook Kang, Sunwook.Kang@ercot.com


Appendix - Results of Reconnection Time Test: Lower System Inertia Case

- Scenario 2: Lower System Inertia Case

Absolute Frequency Deviation (Hz) from Nominal




Zoomed-In RoCoF Trends During the Post-Fault Period



Appendix - Results of Reconnection Time Test: Lower System Inertia Case


- Scenario 2: Lower System Inertia Case




Appendix - Results of Reconnection Time Test: Higher LEL Case

- Scenario 3: Higher LEL Case

Absolute Frequency Deviation (Hz) from Nominal



Zoomed-In RoCoF Trends During the Post-Fault Period



Appendix - Results of Reconnection Time Test: Higher LEL Case

- Scenario 3: Higher LEL Case

