



**Combined CPS Energy Reactive Power
Planning Project & CPS Energy Helotes
345/138-kV Switching Station and
Autotransformer Addition at Eastside
Switching Station Project – ERCOT
Independent Review (EIR) Status
Update**

Travis Head

RPG Meeting
February 2, 2026


Introduction

- CPS Energy Reactive Power Planning Project (25RPG013) for Regional Planning Group (RPG) review in May 2025
 - This is a Tier 1 project with an estimated cost of \$116.50 million and will not require a Certificate of Convenience and Necessity (CCN)
 - Estimated in-service date (ISD) is December 2029
 - This project is needed to address post-contingency voltage violations in the Bexar County
- CPS Energy Helotes 345/138-kV Switching Station and Autotransformer Addition at Eastside Switching Station Project (25RPG017) for Regional Planning Group (RPG) review in May 2025
 - This is a Tier 1 project with an estimated cost of \$110.0 million and will not require a Certificate of Convenience and Necessity (CCN)
 - Estimated ISD is Summer 2028 and Summer 2029
 - This project is needed to address post-contingency thermal violations in the Bexar County

Introduction

- CPS presented a project overview and ERCOT provided a project scope at the July 2025 RPG Meeting
 - <https://www.ercot.com/calendar/07292025-RPG-Meeting>
- ERCOT provided a project update at the August, October, December 2025, and the January 2026 RPG Meetings
 - <https://www.ercot.com/calendar/08262025-RPG-Meeting>
 - <https://www.ercot.com/calendar/10282025-RPG-Meeting>
 - <https://www.ercot.com/calendar/12162025-RPG-Meeting>
 - <https://www.ercot.com/calendar/01162026-RPG-Meeting>
- ERCOT is currently conducting a single ERCOT Independent Review (EIR) by combining these two projects (25RPG013 and 25RPG017)

Recap – Study Area Map with Project Needs Seen by CPS




Recap – Preliminary Results of Reliability Assessment – Updated Base Case

| Contingency Category | Unsolved Power Flow | Voltage Violations | Thermal Overloads |
|----------------------|---------------------|--------------------|-------------------|
| P1 | 10* | None | 8* |
| P2, P4, P5 | 5 | None | None |
| P3 (G-1+N-1)** | 85 | 150+ | 25+ |
| P6.2 (X-1+N-1)** | 85 | 150+ | 25+ |
| P7 | 8* | 150+* | 12* |
| Total | 100+ | 150+ | 25+ |

*Violations seen in the basecase under P1 and P7 events were also seen under G-1+N-1 and/or X-1+N-1 events

**See Appendix D for list of G-1 generators and X-1 transformers tested

Recap – Study Area Map with Project Needs Seen by ERCOT




Option 1 – Combined CPS Project

- Construct a new Helotes 345-kV substation;
- Convert the existing Helotes 138-kV substation to a new 345/138-kV switching substation;
- Install two new 345/138-kV autotransformers at the new Helotes 345/138-kV switching substation with normal and emergency ratings of at least 600 MVA;
- Loop in the existing Hill Country to Cagnon 345-kV transmission line into the new Helotes 345-kV substation;
- Install a new 345/138-kV autotransformer at the existing Eastside 345/138-kV substation with normal and emergency ratings of at least 600 MVA; and

Option 1 – Combined CPS Project

- Install the following sized capacitors at the following 138-kV substations:
 - 50 MVAR, Hill Country
 - 50 MVAR, Anderson
 - 25 MVAR, Legend Falls
 - 50 MVAR, Howard
 - 25 MVAR, Talley Rd
- Install the following STATCOMs at the following 138-kV substations:
 - 300 MVAR, Grissom
 - 300 MVAR, Eastside Switch

Option 1 – Combined CPS Project



Option 2 – ERCOT Proposed Option

- Construct a new Helotes 345-kV substation;
- Convert the existing Helotes 138-kV substation to a new 345/138-kV switching substation;
- Install two new 345/138-kV autotransformers at the new Helotes 345/138-kV switching substation with normal and emergency ratings of at least 600 MVA;
- Loop in the existing Hill Country to Cagnon 345-kV transmission line into the new Helotes 345-kV substation;
- Install a new 345/138-kV autotransformer at the existing Eastside 345/138-kV substation with normal and emergency ratings of at least 600 MVA;
- Construct a new Kendall to Helotes 345-kV transmission line on double-circuit structures with normal and emergency ratings of at least 1980 MVA, approximately 39.1-mile;


Option 2 – ERCOT Proposed Option

- Construct a new Elm Creek to Eastside 345-kV transmission line on double-circuit structures with normal and emergency ratings of at least 1980 MVA, approximately 23.4-mile;
- Rebuild the existing Kirby to St_Hedwg 138-kV transmission line on double-circuit structures with normal and emergency ratings of at least 478 MVA, approximately 2.67-mile;
- Rebuild the existing Leon Creek to Palo Alto 138-kV transmission line on double-circuit structures with normal and emergency ratings of at least 478 MVA, approximately 3.64-mile; and

Option 2 – ERCOT Proposed Option

- Install the following sized capacitors at the following 138-kV substations:
 - 50 MVAR, Grissom
 - 50 MVAR, Helotes
 - 50 MVAR, Bandera
 - 50 MVAR, Anderson
 - 50 MVAR, Hill Country
 - 50 MVAR, Stonegat

Option 2 – ERCOT Proposed Option



Option 3 – ERCOT Proposed Option

- Construct a new Helotes 345-kV substation;
- Convert the existing Helotes 138-kV substation to a new 345/138-kV switching substation;
- Install two new 345/138-kV autotransformers at the new Helotes 345/138-kV switching substation with normal and emergency ratings of at least 600 MVA;
- Loop in the existing Hill Country to Cagnon 345-kV transmission line into the new Helotes 345-kV substation;
- Install a new 345/138-kV autotransformer at the existing Eastside 345/138-kV substation with normal and emergency ratings of at least 600 MVA;


Option 3 – ERCOT Proposed Option

- Construct a new Hill Country to Bergheim 345-kV transmission line on double-circuit structures with normal and emergency ratings of at least 1980 MVA, approximately 14.28-mile;
- Rebuild the existing Castle to Dresden 138-kV transmission line on double-circuit structures with normal and emergency ratings of at least 478 MVA, approximately 3.79-mile;
- Rebuild the existing Cagnon to Potranco 138-kV transmission line on double-circuit structures with normal and emergency ratings of at least 478 MVA, approximately 5.87-mile;
- Rebuild the existing Leon Creek to Palo Alto 138-kV transmission line on double-circuit structures with normal and emergency ratings of at least 478 MVA, approximately 3.64-mile; and

Option 3 – ERCOT Proposed Option

- Install the following sized capacitors at the following 138-kV substations:
 - 50 MVAR, Grissom
 - 50 MVAR, Helotes
 - 50 MVAR, Bandera
 - 50 MVAR, Anderson
 - 50 MVAR, Hill Country
 - 50 MVAR, Stonegat

Option 3 – ERCOT Proposed Option



Recap – Preliminary Results of Reliability Assessment – Options

| Option | N-1 | | G-1+N-1* | | X-1+N-1* | |
|--------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| | Thermal Violations | Voltage Violations | Thermal Violations | Voltage Violations | Thermal Violations | Voltage Violations |
| 1 | None | None | 7 | None | None | None |
| 2 | None | None | None | None | None | None |
| 3 | None | None | None | None | None | None |

*See Appendix D for list of G-1 generators and X-1 transformers tested

Preliminary Results of Planned Maintenance Outage Evaluation


- ERCOT conducted planned maintenance outage evaluation on the options
 - Load level in the South-Central Weather Zone was scaled down to 80.3% of their summer peak loads in the study base case, respectively based on ERCOT load forecast and historical load, in order to mimic the off-peak load condition
 - N-2 contingencies were tested as a proxy for N-1-1. Any applicable violating contingencies were further tested with system adjustments
 - The transmission elements in the Bexar County were monitored in the maintenance outage evaluation
- Planned maintenance outage analysis results

| Option | Voltage Violations | Thermal Overloads | Unsolved Power Flow |
|--------|--------------------|-------------------|---------------------|
| Base | None | 12 | None |
| 1 | None | 18 | None |
| 2 | None | 5 | None |
| 3 | None | 5 | None |

Next Steps and Tentative Timeline

- ERCOT will evaluate options and provide status updates at future RPG meetings
 - Conduct Planned Maintenance Outage Evaluation
 - Conduct Long-Term Load-Serving Capability Assessment
 - Request TSPs to conduct Cost Estimate and Feasibility Assessment
- Generation Addition and Load Scaling Sensitivity Analyses
 - Planning Guide Section 3.1.3(4)
- Subsynchronous Oscillation (SSO) Assessment
 - Nodal Protocol Section 3.22.1.3(2)
- Dynamics Assessment to ensure that the identified transmission upgrades do not result in system instability within the study area
- Congestion Analysis
 - Congestion analysis may be performed based on the recommended transmission upgrades to ensure that the identified transmission upgrades do not result in new congestion within the study area
- Tentative Timelines
 - Status updates at the future RPG meetings
 - Final recommendation – Q1 2026

Thank you!



Stakeholder comments also welcomed through:

Travis.Head@ercot.com

Robert.Golen@ercot.com

Appendix A – Transmission Projects Added

| TPIT/RPG No | Project Name | Tier | Project ISD | TSP | County(s) |
|-------------|--------------------------------------|--------|----------------|------|-----------|
| 89912 | GVEC_Olmos to Wilson 138 kV TL, T297 | Tier 4 | 12/01/26 | GVEC | Guadalupe |

Appendix B – Transmission Projects Removed

| RTP Project ID | Project Name | TSP(s) | County(s) |
|----------------|--|-----------------------|---|
| 2024-SC19 | Hillje (44200) to Zorn (7042) 345-kV Line Upgrades | CNP, AEN, LCRA TSC | Wharton, Fayette, Bastrop, Caldwell, Guadalupe |
| 2024-SC26 | Shaula (5380) to Elm Creek (5133) to Cachena (5068) 345-kV Line Upgrades | CPS | Wilson, Guadalupe, Dewitt |

Appendix C – Generation Added

| GINR | Project Name | Fuel | Project COD | Max Capacity (~MW) | County |
|-----------|---------------------------------|------|-------------|--------------------|------------|
| 20INR0162 | Diamondback Solar | SOL | 12/31/2027 | 203.8 | Starr |
| 21INR0359 | Hickerson Solar | SOL | 11/21/2025 | 311.1 | Bosque |
| 22INR0220 | Lamkin Solar | SOL | 08/08/2027 | 101.5 | Comanche |
| 22INR0239 | Rockefeller Storage | BESS | 06/01/2027 | 206.8 | Schleicher |
| 22INR0437 | TORMES SOLAR | SOL | 03/31/2027 | 382.1 | Navarro |
| 22INR0457 | Anson BAT | BESS | 08/01/2026 | 150.6 | Jones |
| 22INR0605 | Camino Santiago Solar | SOL | 02/18/2027 | 196.3 | Milam |
| 23INR0078 | Shaw Solar | SOL | 04/29/2026 | 124.7 | Bandera |
| 23INR0181 | Starling Storage | BESS | 05/15/2027 | 63.6 | Gonzales |
| 23INR0225 | MRG GOODY SOLAR | SOL | 05/02/2026 | 170.8 | Lamar |
| 23INR0479 | Taormina Storage | BESS | 05/26/2029 | 231.9 | Bexar |
| 23INR0538 | Roadrunner Crossing BESS SLF | BESS | 12/31/2025 | 150.4 | Eastland |
| 24INR0126 | High Noon Storage | BESS | 05/09/2028 | 94.0 | Hill |
| 24INR0181 | Bynum Solar Project | SOL | 12/01/2025 | 56.0 | Coryell |
| 24INR0188 | Tehuacana Creek Solar SLF | SOL | 03/10/2027 | 505.5 | Navarro |

Appendix C – Generation Added Cont.

| GINR | Project Name | Fuel | Project COD | Max Capacity (~MW) | County |
|-----------|----------------------------------|------|-------------|--------------------|-----------|
| 24INR0189 | Tehuacana Creek BESS SLF | BESS | 03/10/2027 | 419.0 | Navarro |
| 24INR0305 | MRG Goody Storage | BESS | 05/02/2026 | 52.3 | Lamar |
| 24INR0355 | Anatole Renewable Energy Storage | BESS | 03/31/2027 | 207.8 | Henderson |
| 24INR0364 | Pitts Dudik II | SOL | 02/04/2026 | 30.2 | Hill |
| 24INR0386 | Black & Gold Energy Storage | BESS | 06/30/2027 | 254.6 | Menard |
| 24INR0453 | Longfellow BESS I | BESS | 01/31/2026 | 55.0 | Pecos |
| 24INR0455 | Longfellow BESS II | BESS | 01/31/2026 | 105.8 | Pecos |
| 24INR0493 | Crowned Heron BESS 2 | BESS | 03/31/2026 | 154.2 | Fort Bend |
| 24INR0528 | Blanquilla BESS | BESS | 05/15/2026 | 200.8 | Nueces |
| 24INR0533 | Padua Grid BESS Unit 2 | BESS | 03/15/2026 | 150.9 | Bexar |
| 24INR0584 | Houston IV BESS | BESS | 06/03/2026 | 164.6 | Harris |
| 25INR0018 | Yellow Cat Wind | WIN | 04/01/2027 | 262.0 | Navarro |
| 25INR0046 | Blue Skies BESS | BESS | 12/31/2027 | 306.3 | Hill |
| 25INR0199 | Bonham Solar 1 | SOL | 08/31/2026 | 138.4 | Limestone |
| 25INR0229 | OCI Cobb Creek Solar | SOL | 12/01/2026 | 203.1 | Hill |

Appendix C – Generation Added Cont.

| GINR | Project Name | Fuel | Project COD | Max Capacity (~MW) | County |
|-----------|------------------------|------|-------------|--------------------|---------|
| 25INR0233 | OCI Cobb Creek ESS | BESS | 12/01/2026 | 201.6 | Hill |
| 25INR0391 | Purple Sage BESS 1 | BESS | 05/30/2027 | 156.0 | Collin |
| 25INR0392 | Purple Sage BESS 2 | BESS | 05/30/2027 | 156.0 | Collin |
| 26INR0034 | Bracero Pecan Storage | BESS | 04/01/2027 | 232.0 | Reeves |
| 26INR0296 | Sherbino II BESS SLF | BESS | 02/08/2026 | 77.4 | Pecos |
| 26INR0543 | Three Canes Solar SLF | SOL | 03/10/2027 | 333.0 | Navarro |
| 28INR0024 | Padua Grid BESS Unit 3 | BESS | 05/15/2026 | 201.4 | Bexar |

Appendix D – G-1 Generators and X-1 Transformers

| G-1 Generators | X-1 Transformers |
|-------------------------------|----------------------------|
| Leon Creek U1 | Cagnon X1 345/138-kV |
| Guadalupe Energy Center CTG 1 | Howard Road X1 345/138-kV |
| | Hill Country X1 345/138-kV |
| | Martinez X1 345/138-kV |