



Large Load Power Variation Requirement Consideration


Jimmy Zhang, Jonathan Rose
Grid Stability Analysis

ERCOT Large Load Working Group
February 19, 2026

Recap

- ERCOT discussed the impact of Large Load active power variation on synchronous generators in July 2025 LLWG [Large-Load-SSO-Primer.pptx](#)
- ERCOT worked with Electranix to demonstrate the impact, develop technical framework and requirements. Regular status updates were provided to LLWG
 - [Investigation into Vulnerability of Synchronous Machines to Large Load Subsynchronous Active Power Variation](#) (October 2025)
 - [Progress Update LEL SSO and Power Variation Criteria](#) (January 2026)

Unrestricted Load Variation



Could cause

Catastrophic generator damage




Preliminary Impact Assessment

- ERCOT performed a screening assessment
 - Tested power variations at each ERCOT bus (≥ 100 kV) for impact on existing synchronous generators
 - Checked for MCTV violation (*Maximum Continuous Terminal Variation* corresponding to endurance limits)
 - Evaluated system wide impacts
- Observations
 - As the load MW variation increases, the affected synchronous generators increases significantly

Key Takeaway: Active power variation by Large Loads needs to be managed to minimize the impact to synchronous generators

Impacts vs. Injected Power Variation
(excluding Gen<20MVA)



Note: In this screening assessment, an MCTV of 0.01 was assumed, limiting generator terminal power variation to 1% of MVA rating to avoid torque violations

ERCOT's Proposed Requirement

Proposed Requirement:



Load power shall not repetitively exceed 10 MW change in a sliding time window of 5 seconds

- This is selected to
 - **Maintain reliability**
 - Per previous slide, increasing this number, even modestly, *drastically* increases the “reach” where larger areas of the system and many more generators are affected by a single large load.
 - **Facilitate future interconnections**
 - A straightforward, simple criteria that addresses concerns means future large loads can avoid time-consuming generator interaction SSO studies. This is especially helpful considering that the information required for a detailed study may be very difficult to obtain.
 - Widening this requirement would quickly make process unmanageable → studies would become very large and need to consider very large areas of the system, resulting in complicated, overlapping criteria and objectives.



Image source: <https://stockcake.com/i/vast-data-center-1467301-878882>

Proposed Method to Evaluate Performance



- ERCOT will focus on **repetitive** power cycling behavior above 10 MW
 - (Infrequent power steps over 10 MW would not violate this criteria)
 - ERCOT will work to further define details
- High resolution measurement like PMU will be needed

Next Steps

- Submit the revision request in Q2 2026
- Welcome stakeholders' input and suggestions
Jimmy.Zhang@ercot.com and Jonathan.Rose@ercot.com

Recap from January 22 LLWG: Methodology for Gen Variation (MCTV) Limit

- **Step 1: Determine the maximum continuous terminal variation (MCTV) in active power for synchronous generators** (mechanical limit → electrical limit)
 - **Endurance Limit (EL):**
Maximum continuous cyclic shaft torque a synchronous generator can safely tolerate
 - **Load Shape Ratio (LSR):**
Amplification factor between terminal active-power variation and resulting shaft torque
 - **Maximum Continuous Terminal Variation (MCTV):**
The maximum amount of continuous active power variation at the SG terminals without exceeding the given mechanical endurance capability. $MCTV = LE / LSR$
- **Example:**
If $EL = 0.1$ pu and $LSR = 10 \rightarrow MCTV = 0.01$ pu
For a 100 MW generator → allowable continuous oscillatory power at SG terminal is 1 MW
- **Step 2: Calculate the maximum allowable power variation at LEL terminal**
 - Use a load-flow or impedance-based approach to calculate the Interaction Factor–Based Limit (IFBL)
 - maximum LEL power variation such that no nearby generator exceeds its MCTV
 - The most limiting generator sets the IFBL for that load location