

PUBLIC



**Oncor Electric Delivery Company LLC
(Oncor) – Combined Set 1 North and
Central Texas Reliability Project
(25RPG040) & Set 2 North and Central
Texas Reliability Project (25RPG042) –
ERCOT Independent Review (EIR) –
Status Update**

Ying Li

Regional Planning Group (RPG) Meeting
April 13, 2026

Introduction

Oncor Electric Delivery Company LLC (Oncor) submitted the Set 1 North and Central Texas Reliability Project (25RPG040) for Electric Reliability Council of Texas' (ERCOT) Regional Planning Group (RPG) review in November 2025

- This is a Tier 1 project with an estimated cost of approximately \$1.798 billion and will require a Certificate of Convenience and Necessity (CCN)
- Estimated in-service dates (ISDs) planned in phases between 2028 and 2034
- This project is needed to address the thermal overloads and voltage violations in the Ellis, Navarro, Franklin, Hopkins, Collin, Hunt, Grayson, Johnson, Hill, Dallas, Henderson, Kaufman, Delta, Fannin, and Lamar counties in the North, North Central, and East Weather Zones
- This project was identified and included in the both 2024 and 2025 Regional Transmission Plan (RTP)
- This project aligns with the transmission upgrades proposed in the 2024 RTP 765-kV Strategic Transmission Expansion Plan (STEP) Core Plan

Introduction (continued)

Oncor submitted the Set 2 North and Central Texas Reliability Project (25RPG042) for ERCOT's RPG review in November 2025

- This is a Tier 1 project with an estimated cost of approximately \$1.330 billion and will require a CCN
- Expected ISDs planned in phases between 2028 and 2034
- This project is needed to address the thermal overloads and voltage violations in the Dallas, Henderson, Kaufman, Ellis, Freestone, Leon, Navarro, Tarrant, Collin, Denton, Lamar, Red River, Delta, Fannin, Hunt, and Hopkins counties in the North, North Central, and East Weather Zones
- This project was identified and included in the 2024 RTP
- A subset of this project was identified and included in the 2025 RTP
- This project aligns with the transmission upgrades proposed in the 2024 RTP 765-kV STEP Core Plan

Introduction (continued)

This project is currently under a single ERCOT Independent Review (EIR) by combining these two projects (25RPG040 and 25RPG042) and ERCOT is presenting its status update

- Oncor presented a project overview for these two projects at the [January 2026 RPG Meeting](#)
- ERCOT provided the EIR scope at the [February 2026 RPG Meeting](#)
- ERCOT provided the EIR scope updates at the [March 2026 RPG Meeting](#)

Recap: Highlights of the Set 1 North and Central Texas Reliability Project

| Oncor Project Description | RTP Project Number | Counties |
|--|----------------------------|--|
| Rebuild the Venus Switch to Old Country Switch 345-kV double-circuit line, ~ 15.9 miles; and Rebuild the Notus Switch to Old Country Switch 345-kV double-circuit Line. ~ 14.8 miles | 2024-NC56 and 2024-NC42 | Ellis and Navarro |
| Rebuild the Hagansport (fka Monticello Tap) Switch to Sulphur Springs East Tap 138-kV line, ~ 20.6 miles | 2024-E8 | Franklin and Hopkins |
| Reconductor the Monticello Switch to Cash Switch 345-kV line, ~ 62.3 miles | 2024-E9 | Collin, Hopkins, Hunt and Franklin |
| Rebuild the Valley Switch to Progress Park Switch 138-kV line, 15.6 miles | 2024-N07 | Grayson |
| Rebuild the Cleburne 138-kV Switch; Rebuild the Cleburne Switch to Venus 138-kV line, ~ 19.5 miles; and Rebuild the Red Hill Switch to Rio Vista Tap 138-kV line, ~ 6.6 miles | 2024-NC04 | Johnson, Ellis and Hill |
| Rebuild the Tri Corner 345-kV Switch; Rebuild the Watermill Switch to Tri Corner Switch 345-kV double-circuit line between structure 102/3 and Tri Corner Switch, ~ 8.4 miles; and Rebuild the Trinidad Switch to Tri Corner 345-kV double-circuit line, ~ 40.40 miles | 2024-NC11 | Dallas, Henderson, and Kaufman |
| Rebuild the Commerce Switch to Crossroads Switch 138-kV line, ~ 22.1 miles | 2024-NC36 | Hunt and Delta |
| Rebuild the Valley Switch to Valley South Switch 345-kV line, ~ 0.9 miles; Rebuild the Valley 345-kV Switch; Rebuild the Anna 345-kV Switch; Rebuild the Saltillo Switch to Farmersville Switch 345-kV line, ~ 59.9 miles; Rebuild the Anna Switch to Valley Switch 345-kV line, ~ 26.6 miles; and Reconductor the Paris Switch to Valley South Switch 345-kV line, ~ 46.3 miles | 2024-NC31 | Collin, Fannin, Grayson, Hunt and Lamar |
| Establish a new Lavon 345-kV Switch; Terminate the Allen Switch to Royse Switch/Stouts Creek Switch 345-kV double-circuit line into Lavon 345-kV Switch; Install one 600 MVA (nameplate) 345/138-kV autotransformer at Lavon Switch; and Construct a new Lavon Switch to Allen Switch 138-kV line, ~ 12.7 miles | 2024-NC59 | Collin |
| Rebuild the Batchler Road Switch to Stainback Switch 345-kV double-circuit line, ~ 3.2 miles | 2024-NC68 | Dallas and Ellis |
| Install a second circuit by rebuilding the existing Gunter Switch to Collin Switch 138-kV line to create the Gunter Switch to Collin 138-kV double-circuit line, ~ 16.4 miles | 2024-NC76 | Collin and Grayson |

Key Takeaway: Projects highlighted in yellow have been evaluated in the EIR for the Oncor Southern DFW Load Interconnection and General Grid Strengthening Project (25RPG004)

Recap: Highlights of the Set 2 North and Central Texas Reliability Project

| Oncor Project Description | RTP Project Number | Counties |
|--|-------------------------|--|
| Rebuild DeSoto 345/138 kV Switch; Add one new 345/138-kV autotransformer at DeSoto; and New DeSoto to Loop Nine 138-kV line, ~ 3.82 miles | 2024-NC80 | Dallas |
| Rebuild the south circuit of Loop Nine – Watermill 345 kV double-circuit line, ~ 4.0 miles | 2024-NC16 | Dallas |
| Rebuild the Kaufman Northwest – Seven Point 138-kV line, ~ 20.8 miles | 2024-NC53 | Henderson and Kaufman |
| New Greene to Wilmer 345-kV double-circuit line, ~ 3.0 miles | 2024-NC86 | Dallas |
| New Jewett to Greene 345-kV double-circuit line, ~ 112.5 miles | 2024-NC63 | Dallas, Ellis, Freestone, Leon and Navarro |
| Upgrade the Benbrook 345/138-kV Autotransformer #1 | 2024-NC79 | Tarrant |
| Add a second 345/138-kV autotransformer at Gunter; and Add two 37.5 MVar reactors | 2024-NC76 | Collin |
| Rebuild Argyle 138-kV Switch; Rebuild the Argyle to Highlands (TNMP) 138-kV line, ~ 7.5 miles; Rebuild the Argyle to Corinth 138-kV line, ~ 2.9 miles; and Rebuild the Argyle to Krum 138-kV line, ~ 8.54 miles | 2024-NC72 and 2024-NC40 | Denton |
| Rebuild the Rivercrest to Hawk Hollow 138-kV line, ~ 25.5 miles; and Rebuild the Hagansport (fka Monticello tap) to Rivercrest 138-kV line, ~ 9.5 miles | 2024-N14 | Lamar and Red River |
| Rebuild the Paris to Valley 138-kV line, ~ 46.1 miles; and Rebuild the Paris to Commerce 138-kV line, ~ 14.0 miles | 2024-N16 | Delta, Fannin, Hunt and Lamar |
| Reconductor the Allen to Stouts Creek 345-kV line, ~ 80.9 miles | 2024-NC29 | Collin, Hopkins, Hunt |


Key Takeaway: Project highlighted in yellow has been evaluated in the EIR for the Oncor Southern DFW Load Interconnection and General Grid Strengthening Project (25RPG004)

Recap: Summary of the Two Projects Proposed by Oncor

Summary of Upgrades

- New 345-kV and 138-kV lines
 - Two 345-kV double-circuit lines, approximately 115.5 miles
 - Three 138-kV single-circuit lines, approximately 32.9 circuit miles
- Upgrade of existing 345-kV and 138-kV lines
 - 345-kV lines, approximately 446.3 circuit miles
 - 138-kV lines, approximately 233.4 circuit miles
- New substation and transformers
 - One 345-kV substation and three 345/138-kV transformers
- Rebuild of existing substations and transformers
 - Four 345-kV substations and one 345/138-kV transformer
 - Three 138-kV substations

Total combined estimated cost is approximately \$3.128 billion



Recap: Load Evaluation

With the current method of including full Officer Letter Loads in the EIR review, the study area will have over 16 GW of large loads than the 2025 RTP load level (over 13 GW than the 2024 RTP load level)

| Weather Zone | Study Load Level (MW) | 2025 RTP 2031 Load (MW) | 2024 RTP 2030 Load (MW) |
|---------------|-----------------------|-------------------------|-------------------------|
| East | 3,599 | 3,269 | 3,756 |
| North | 12,889* | 12,526 | 8,103 |
| North Central | 55,410 | 39,606 | 46,424 |
| Total | 71,898 | 55,401 | 58,283 |

* This load does not include the Panhandle area full Officer Letter Load

Key Takeaway:

- This indicates the reliability need still exists for all the transmission projects proposed in the Oncor Set 1 and Set 2 North and Central Texas Reliability Projects
- In addition to the proposed Set 1 and Set 2 projects, substantial amounts of new transmission upgrades would also be needed to serve these additional loads which is beyond the study scope of this EIR

Recap: Study Evaluation

Group 1

- ERCOT has evaluated and included the overlapping upgrades (highlighted on slides 5 and 6) in the EIR for the Oncor Southern DFW Load Interconnection and General Grid Strengthening Project (25RPG004) and these upgrades will not be evaluated as part of this EIR evaluation

Group 2

- ERCOT proposes to confirm and approve the remaining transmission upgrades proposed in the Oncor Set 1 and Set 2 North and Central Texas Reliability Projects based on the reliability need identified in the 2024 and 2025 RTP evaluations to expedite the RPG review process except for the one which Transmission Service Providers (TSPs) commented for alternative

Group 3

- ERCOT is conducting an independent review for the upgrades that TSPs commented for alternative

Status Update

Studies performed since March RPG meeting

- Generation addition sensitivity analysis for Group 2 upgrades
- Load scaling sensitivity analysis for Group 2 upgrades
- Reliability need analysis for Group 3 upgrade
- Options evaluation for Group 3 upgrade
- Cost estimate and feasibility assessment for Group 3 upgrade

Ongoing Assessments

- Subsynchronous Oscillations (SSO) Assessment for Group 2 upgrades
- Long-term load-serving capability assessment for Group 3 upgrade
- Final recommendation for both Group 2 and Group 3 upgrades


Recap: Group 1 Upgrades Evaluated in Other Project

Group 1 Summary of Upgrades

- Build two existing 345-kV Switches
- Rebuild existing 345-kV lines, ~157.5 circuit miles

Total estimated cost is approximately \$763.58 million

- Detailed component list in [Appendix A1](#)



Key Takeaway: Upgrades identified as Group 1 have been evaluated in the recent EIR for the Oncor Southern DFW Load Interconnection and General Grid Strengthening Project (25RPG004) and will not be evaluated as part of this EIR evaluation


Recap: Group 2 Upgrades for Expedited Evaluation

Group 2 Summary of Upgrades

- Build new 345-kV double-circuit lines, ~ 115.5 miles
- Build new 138-kV lines, ~ 16.5 circuit miles
- Rebuild existing 345-kV lines, ~288.8 circuit miles
- Rebuild existing 138-kV lines, ~233.4 circuit miles
- Build one new 345-kV substation and three 345/138-kV transformers
- Rebuild existing two 345-kV substations and one 345/138-kV transformer
- Rebuild existing three 138-kV substations

Total estimated cost is approximately \$2.307 billion

- Detailed component list in [Appendix A2](#)



Key Takeaway: Upgrades identified as Group 2 are being considered for expedited evaluation

Group 2 Upgrades - Additional Analyses

Generation Addition Sensitivity Analysis

- ERCOT performed a generation addition sensitivity using the Final 2025 RTP 2031 summer peak load case with the Group 2 upgrades modelled, per ERCOT Planning Guide Section 3.1.3(4)(a), by adding new the generation listed in [Appendix B](#) to the case. The additional 29 resources were modeled following the 2025 RTP methodology. ERCOT determined relevant generators do not impact the Group 2 upgrades

Load Scaling Sensitivity Analysis

- ERCOT Planning Guide Section 3.1.3(4)(b) requires an evaluation of the potential impact of load scaling on the criteria violations seen in this EIR. Starting 2024, ERCOT RTP adopted a new methodology of having one summer peak case for each study year with non-coincident peaks for each of the Weather Zones, which would eliminate the load scaling impact. The study case did not include load scaling as such load scaling sensitivity analysis is no longer needed

ERCOT is currently evaluating the SSO Assessment


Recap: Group 3 Upgrade for EIR Evaluation

Group 3 Upgrade

- Install a second circuit by rebuilding the existing Gunter Switch to Collin Switch 138-kV line to create the Gunter Switch to Collin 138-kV double-circuit line, ~ 16.4 miles

Estimated cost is approximately \$56.4 million

- Detailed component list in [Appendix A3](#)



Key Takeaway: ERCOT is currently conducting an independent review for the upgrade identified for Group 3 and the alternative commented by TSPs

Group 3 Study Assumptions

Study Region

- The project is located in Collin and Denton counties in the North Central Weather Zone and all transmission elements in counties that are electrically close will be monitored

Steady-State Base Case

- Final [2025 RTP](#) 2031 summer peak load case, published on Market Information System (MIS) on December 22, 2025, was updated to construct the study base case

Transmission Updates

- No new transmission project (listed in [Appendix C1](#)), based on the February 2026 [Transmission Project and Information Tracking \(TPIT\) report](#) and/or recently approved RPG project, was added to the base case
- Transmission project (listed in [Appendix C2](#)) identified in the 2025 RTP in the study area that has not been approved by RPG was removed

Generation Updates

- New generation that met ERCOT Planning Guide Section 6.9(1) (listed in [Appendix D](#)) based on the [February 2026 Generator Interconnection Status \(GIS\) report](#) will be added to the study base case
- All generation will be dispatched consistent with the 2025 RTP methodology

Load and Reserve Updates

- Load was maintained consistent with the 2025 RTP
- The reserve was maintained consistent with the 2025 RTP

Group 3 Contingencies & Criteria

Contingencies for Study Region

- North American Electric Reliability Corporation (NERC) Reliability Standard TPL-001-5.1 and [ERCOT Planning Criteria](#)
 - P0 (System Intact)
 - P1, P2-1, P7 (N-1 conditions)
 - P2-2, P2-3, P4, and P5 (EHV only)
 - P3: G-1+N-1 (G-1: list in [Appendix E](#))
 - P6-2: X-1+N-1 (X-1: list in [Appendix E](#))

Criteria

- Monitor all 60-kV and above busses, transmission lines, and transformers in the study region (excluding generator step-up transformers)
- Thermal
 - Use Rate A for normal conditions
 - Use Rate B for emergency conditions
- Voltage
 - Voltages exceeding their pre-contingency and post-contingency limits
 - Voltage deviations exceeding 8% on non-radial load buses

Group 3 Procedure

Need Analysis

- The reliability analysis was performed to identify the need to serve the projected area load using the study base case

Project Evaluation

- Project alternatives were developed and tested to satisfy the NERC and ERCOT reliability requirements
- ERCOT may also perform the following studies
 - Maintenance Outage Evaluation
 - Long-Term Load-Serving Capability Assessment
- TSP(s) provided Cost Estimate and Feasibility Assessment


Group 3 Preliminary Results of Reliability Assessment – Base Case

ERCOT conducted steady-state load flow analysis for the study base case according to the NERC Reliability Standard TPL-001-5.1 and ERCOT Planning Criteria to identify the project need

| Contingency Category | Thermal Overloads | Voltage Violations | Unsolved Power Flow |
|----------------------|-------------------|--------------------|---------------------|
| P1 | 3 | None | None |
| P2, P4, P5 | None | None | None |
| P3: (G-1+N-1)* | None | None | None |
| P6-2: (X-1+N-1)* | None | None | None |
| P7 | None | None | None |
| Total | 3 | None | None |

* See [Appendix E](#) for list of G-1 generators and X-1 transformers tested


Group 3 Study Area Map with Project Need Seen by ERCOT



Group 3 Option 1 – Oncor Proposed Project

Option 1 Upgrade Details


- Install a second circuit by rebuilding the existing Gunter Switch to Collin Switch 138-kV transmission line to create the Gunter Switch to Collin 138-kV double-circuit transmission line, with normal and emergency ratings of least 764 MVA, approximately 16.4 miles



Group 3 Option 2 – Alternative from Brazos and TNMP

Option 2 Upgrade Details

- Construct a new Pilot Point to Parvin 138-kV single-circuit transmission line, on double-circuit-capable structures with one circuit in place, with normal and emergency ratings of least 717 MVA, which would require a new ROW, approximately 18.4 miles



Group 3 Preliminary Results of Reliability Assessment – Options

ERCOT conducted steady-state load flow analysis for the study options according to the NERC Reliability Standard TPL-001-5.1 and ERCOT Planning Criteria to evaluate the options

| Option | N-1 | | G-1+N-1* | | X-1+N-1* | | Unsolved Power Flow |
|--------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|---------------------|
| | Thermal Violations | Voltage Violations | Thermal Violations | Voltage Violations | Thermal Violations | Voltage Violations | |
| 1 | None | None | None | None | None | None | None |
| 2 | None | None | None | None | None | None | None |

* See [Appendix E](#) for list of G-1 generators and X-1 transformers tested

Key Takeaway: Both Option 1 and Option 2 observed no reliability violations

Group 3 Preliminary Results of Maintenance Outage Evaluation

ERCOT conducted maintenance outage analysis on both study options to compare relative performance of the options

- Load level in the North Central Weather Zone was scaled down based on the historical non-summer peak data to 82%, in order to mimic the non-summer peak load condition
- Based on the review of system topology of the area, ERCOT tested N-2 contingency combinations, and then tested all applicable contingency violations with system adjustments (N-1-1)

| Option | Thermal Violation | Voltage Violation | Unsolved Power Flow |
|--------|-------------------|-------------------|---------------------|
| 1 | None | None | None |
| 2 | None | None | None |

Key Takeaway: No reliability violations were observed in the N-1-1 analysis for Option 1 and Option 2

Group 3 Cost Estimate and Feasibility Assessment

TSPs performed feasibility assessments and provided cost estimates for the two options

| Option | Cost Estimates (~\$Million) | CCN Required (~miles) | Feasibility | Expected ISD |
|--------|-----------------------------|-----------------------|-------------|---------------|
| 1 | \$56.4 | 0 | Yes | TBD |
| 2 | \$80.8 | 18.4 | Yes | November 2030 |

Key Takeaway: The CCN filing may result in a longer route and a later ISD

Group 2 and Group 3 Deliverables or Next Step

Tentative Timelines

- ERCOT recommendation at the May RPG meeting
- EIR report (single report including Group 2 and Group 3 Upgrades) to be posted in the MIS in May 2026
- EIR recommendation to Technical Advisory Committee (TAC) in May 2026
- Seek ERCOT Board of Directors (BOD) endorsement in June 2026

Key Takeaway: Seek ERCOT BOD endorsement in June 2026

Thank you!

Questions/Comments?

Ying.Li@ercot.com

Robert.Golen@ercot.com

Learn More

www.ercot.com

Download ERCOT Mobile App



Connect With Us



facebook.com/ERCOTISO



x.com/ercot_iso



linkedin.com/company/ercot



instagram.com/ercot_iso

Appendix

- Appendix A1: Group 1 Upgrades
- Appendix A2: Group 2 Upgrades
- Appendix A3: Group 3 Upgrade
- Appendix B: New Generation Projects Added for Generation Addition Sensitivity Analysis for Group 2
- Appendix C1: Transmission Projects to Add to Group 3 Base Case
- Appendix C2: Transmission to Remove from Group 3 Base Case
- Appendix D: Generation to Add to Group 3 Base Case
- Appendix E: G-1 Generators and X-1 Transformers List for Group 3 Analyses

Learn More

www.ercot.com

Download ERCOT Mobile App



Connect With Us



facebook.com/ERCOTISO



x.com/ercot_iso



linkedin.com/company/ercot



instagram.com/ercot_iso

Appendix A1: Group 1 Upgrades

| Oncor Project Description | RTP Project Number | Counties |
|--|--------------------|---|
| Rebuild the Tri Corner 345-kV Switch; Rebuild the Watermill Switch to Tri Corner Switch 345-kV double-circuit line between structure 102/3 and Tri Corner Switch, ~ 8.4 miles; and Rebuild the Trinidad Switch to Tri Corner 345-kV double-circuit line, ~ 40.40 miles | 2024-NC11 | Dallas, Henderson, and Kaufman |
| Rebuild the Saltillo Switch to Farmersville Switch 345-kV line, ~ 59.9 miles | 2024-NC31 | Collin, Fannin, Grayson, Hunt and Lamar |
| Rebuild the DeSoto 345/138 kV Switch | 2024-NC80 | Dallas |

Appendix A2: Group 2 Upgrades

| Oncor Project Description | RTP Project Number | Counties |
|--|-------------------------|---|
| Rebuild the Venus Switch to Old Country Switch 345-kV double-circuit line , ~ 15.9 miles; and Rebuild the Notus Switch to Old Country Switch 345-kV double-circuit Line. ~ 14.8 miles | 2024-NC56 and 2024-NC42 | Ellis and Navarro |
| Rebuild the Hagansport (fka Monticello Tap) Switch to Sulphur Springs East Tap 138-kV line, ~ 20.6 miles | 2024-E8 | Franklin and Hopkins |
| Reconductor the Monticello Switch to Cash Switch 345-kV line, ~ 62.3 miles | 2024-E9 | Collin, Hopkins, Hunt and Franklin |
| Rebuild the Valley Switch to Progress Park Switch 138-kV line, 15.6 miles | 2024-N07 | Grayson |
| Rebuild the Cleburne 138-kV Switch; Rebuild the Cleburne Switch to Venus 138-kV line, ~ 19.5 miles; and Rebuild the Red Hill Switch to Rio Vista Tap 138-kV line, ~ 6.6 miles | 2024-NC04 | Johnson, Ellis and Hill |
| Rebuild the Commerce Switch to Crossroads Switch 138-kV line, ~ 22.1 miles | 2024-NC36 | Hunt and Delta |
| Rebuild the Valley Switch to Valley South Switch 345-kV line, ~ 0.9 miles; Rebuild the Valley 345-kV Switch; Rebuild the Anna 345-kV Switch; Rebuild the Anna Switch to Valley Switch 345-kV line, ~ 26.6 miles; and Reconductor the Paris Switch to Valley South Switch 345-kV line, ~ 46.3 miles | 2024-NC31 | Collin, Fannin, Grayson, Hunt and Lamar |
| Establish a new Lavon 345-kV Switch; Terminate the Allen Switch to Royse Switch/Stouts Creek Switch 345-kV double-circuit line into Lavon 345-kV Switch; Install one 600 MVA (nameplate) 345/138-kV autotransformer at Lavon Switch; and Construct a new Lavon Switch to Allen Switch 138-kV line, ~ 12.7 miles | 2024-NC59 | Collin |
| Rebuild the Batchler Road Switch to Stainback Switch 345-kV double-circuit line, ~ 3.2 miles | 2024-NC68 | Dallas and Ellis |

Appendix A2: Group 2 Upgrades (continued)

| Oncor Project Description | RTP Project Number | Counties |
|--|----------------------------|---|
| Add one new 345/138-kV autotransformer at DeSoto; and New DeSoto to Loop Nine 138-kV line, ~ 3.82 miles | 2024-NC80 | Dallas |
| Rebuild the south circuit of Loop Nine – Watermill 345 kV double-circuit line, ~ 4.0 miles | 2024-NC16 | Dallas |
| Rebuild the Kaufman Northwest – Seven Point 138-kV line, ~ 20.8 miles | 2024-NC53 | Henderson and Kaufman |
| New Greene to Wilmer 345-kV double-circuit line, ~ 3.0 miles | 2024-NC86 | Dallas |
| New Jewett to Greene 345-kV double-circuit line, ~ 112.5 miles | 2024-NC63 | Dallas, Ellis, Freestone, Leon and Navarro |
| Upgrade the Benbrook 345/138-kV Autotransformer #1 | 2024-NC79 | Tarrant |
| Add a second 345/138-kV autotransformer at Gunter; and Add two 37.5 MVar reactors | 2024-NC76 | Collin |
| Rebuild Argyle 138-kV Switch; Rebuild the Argyle to Highlands (TNMP) 138-kV line, ~ 7.5 miles; Rebuild the Argyle to Corinth 138-kV line, ~ 2.9 miles; and Rebuild the Argyle to Krum 138-kV line, ~ 8.54 miles | 2024-NC72 and 2024-NC40 | Denton |
| Rebuild the Rivercrest to Hawk Hollow 138-kV line, ~ 25.5 miles; and Rebuild the Hagansport (fka Monticello tap) to Rivercrest 138-kV line, ~ 9.5 miles | 2024-N14 | Lamar and Red River |
| Rebuild the Paris to Valley 138-kV line, ~ 46.1 miles; and Rebuild the Paris to Commerce 138-kV line, ~ 14.0 miles | 2024-N16 | Delta, Fannin, Hunt and Lamar |
| Reconductor the Allen to Stouts Creek 345-kV line, ~ 80.9 miles | 2024-NC29 | Collin, Hopkins, Hunt |

Appendix A3: Group 3 Upgrade

| Oncor Project Description | RTP Project Number | Counties |
|---|--------------------|--------------------|
| Install a second circuit by rebuilding the existing Gunter Switch to Collin Switch 138-kV line to create the Gunter Switch to Collin 138-kV double-circuit line, ~ 16.4 miles | 2024-NC76 | Collin and Grayson |

Appendix B: New Generation Projects Added for Generation Addition Sensitivity Analysis for Group 2

| GINR | Project Name | County | Project COD | Fuel Type | Max Capacity (~MW) |
|-----------|----------------------------|-----------|-------------|-----------|--------------------|
| 24INR0075 | Blue Bird Solar | Johnson | 6/27/2028 | SOL | 773.0 |
| 24INR0117 | Utley Solar | Freestone | 5/11/2028 | SOL | 221.8 |
| 24INR0412 | Camino Ranch Solar SLF | Houston | 12/9/2028 | SOL | 296.4 |
| 24INR0420 | Camino Ranch Storage SLF | Houston | 12/9/2028 | OTH | 298.1 |
| 25INR0204 | Claxton Solar | Hopkins | 9/17/2027 | SOL | 150.6 |
| 25INR0247 | Bluebonnet Prairie Wind | Navarro | 7/15/2027 | WIN | 173.0 |
| 25INR0616 | Bobcat Bluff Storage SLF | Archer | 4/15/2027 | OTH | 0.0 |
| 25INR0661 | McCrae Energy Storage | Erath | 9/25/2028 | OTH | 306.4 |
| 26INR0033 | Fairway Storage | Freestone | 9/24/2027 | OTH | 120.3 |
| 26INR0252 | Neutron Storage | McLennan | 4/29/2028 | OTH | 104.5 |
| 26INR0256 | Camino Ranch Solar 2 SLF | Houston | 12/9/2028 | SOL | 237.2 |
| 26INR0257 | Camino Ranch Storage 2 SLF | Houston | 12/9/2028 | OTH | 238.5 |
| 26INR0409 | Lucky 7 Solar | Hopkins | 9/20/2027 | SOL | 101.4 |
| 26INR0531 | West Munday Wind | Knox | 6/30/2028 | WIN | 351.9 |
| 27INR0022 | Panhandle Flagship Solar 1 | Carson | 6/30/2031 | SOL | 439.4 |
| 27INR0025 | Panhandle Flagship Storage | Carson | 6/30/2031 | OTH | 371.7 |

Appendix B: New Generation Projects Added for Generation Addition Sensitivity Analysis for Group 2 (continued)

| GINR | Project Name | County | Project COD | Fuel Type | Max Capacity (~MW) |
|-----------|-------------------------|-------------|-------------|-----------|--------------------|
| 27INR0105 | Starlight Solar | Mills | 5/9/2030 | SOL | 130.7 |
| 27INR0107 | Starlight Storage | Mills | 5/9/2030 | OTH | 104.7 |
| 27INR0140 | Kingsmill Wind SLF | Carson | 9/1/2029 | WIN | 606.3 |
| 27INR0173 | Trenno BESS | Johnson | 9/13/2027 | OTH | 202.6 |
| 27INR0181 | Elk Unit 4 | Hale | 2/28/2027 | GAS | 210.0 |
| 27INR0313 | Spindletop Solar | Nacogdoches | 12/29/2027 | SOL | 286.0 |
| 27INR0314 | Spindletop Storage | Nacogdoches | 6/30/2027 | OTH | 142.6 |
| 27INR0581 | Limitless Energy Hub I | Wilbarger | 12/1/2028 | GAS | 1,238.3 |
| 27INR0582 | Limitless Energy Hub II | Wilbarger | 12/1/2028 | GAS | 1,238.3 |
| 28INR0008 | Oriole Solar | Knox | 12/29/2028 | SOL | 503.9 |
| 28INR0009 | Oriole BES | Knox | 12/29/2028 | OTH | 150.4 |
| 29INR0003 | Aurelius Solar | Deaf Smith | 6/30/2028 | SOL | 1,124.2 |
| 29INR0004 | Aurelius Wind | Deaf Smith | 6/30/2028 | WIN | 621.6 |

Appendix C1: Transmission Projects Added

| TPIT | Project Name | Tier | Project ISD | County(s) |
|------|--------------|------|-------------|-----------|
| None | | | | |

Appendix C2: Transmission Project Removed

| RTP Project ID | Project Name | County(s) |
|----------------|---|-----------------|
| 2025-NNC01 | Gunter Switch (2236) to Collin Switch (2370) 138-kV Line Addition | Collin, Grayson |

Appendix D: New Generation Project Added

| GINR | Project Name | Fuel | Project COD | Max Capacity (~MW) | County |
|-----------|--------------|------|-------------|--------------------|--------|
| 25INR0101 | Drake BESS | OTH | 7/14/2026 | 257.3 | Collin |

Appendix E: G-1 Generators and X-1 Transformers List for Group 3 Analyses

| Generator | Transformer |
|-----------------------------|--------------------------|
| Denton Energy Center Unit A | Collin 345/138-kV |
| Spencer Unit 5 | Gunter Switch 345/138-kV |