




# **Implementation Considerations for Negative- Sequence Current Injection (NSCI) Requirements for IBRs in ERCOT**

*Jimmy Zhang  
Grid Stability Analysis, ERCOT*

ERCOT System Protection Working Group  
June 16, 2026


## Background and Purpose

- ERCOT presented the background, problem statement, and objectives for evaluating implementation gaps associated with Negative-Sequence Current Injection (NSCI) at the November 2025 SPWG meeting. [SPWG Survey on Protection System Practices for IBR Negative Sequence Current Injection Implementation](#)
- NSCI is required for applicable new and modified IBR projects under the ERCOT Nodal Operating Guide.
- Detailed NSCI performance characteristics must be defined based on transmission system needs, including protection performance, ride-through requirements, and modeling capabilities.
- ERCOT conducted a TSP survey through SPWG in December 2025 to support this effort.
- Identify key implementation gaps and recommended actions to ensure NSCI requirements improve transmission protection performance and support system reliability.



# Fault Response of Generating Resources

Synchronous Generators: behavior is governed by the negative-sequence impedance of the generator, and the surrounding power system.







Reference: EPRI Report- Impact of Inverter-Based Resources on Protection Schemes Based on Negative Sequence Components

**Key Takeaway:** IBRs generally provide lower and more control dependent  $I_2$  than synchronous generators, and the  $V_2$ – $I_2$  angle may not match the assumptions used in legacy protection schemes.

IBRs: behavior depends on site-specific settings such as:

- Control mode (grid-following vs grid-forming),
- Current priority logic,
- OEM-specific implementations
- Current limits in the hardware
- Balance of plant impedances



# Protection Impacts with NSCI from IBRs

- Protection functions (selected) potentially impacted include:
  - 50Q/51Q (negative sequence overcurrent)
  - 67Q (negative sequence directional)
  - Communication assisted pilot schemes (POTT, PUTT, DCB/DCUB, rely on directional supervision)
  - Phase selection / Fault identification (FID)
- Example Protection Misoperation

A publicly reported Dominion Energy event on September 22, 2022

  - A single-line-to-ground fault occurred on a radial system with IBR facilities
  - IBR-side relays did not operate to clear the fault
  - Directionality elements did not pick up the fault due to insignificant negative-sequence current

**Key Takeaway:** Adequate and predictable NSCI is important to support overall protection coordination in weak-source or high-IBR areas.

## Key Findings from TSP Survey Feedback

- 14 TSP responses received
- Feedback shows converging protection practices and common NSCI implementation gaps:
  1. Shift Toward Weak-Source-Tolerant Protection
  2. Legacy Directional Elements Need Review
  3. NSCI Performance Must Be Explicitly Defined
  4. Utility Guidance Remains Limited
  5. Model and Data Gaps Remain a Barrier

# Recommended Action Items

| # | Owner | Action Item                                                     | Description                                                                                                                                                                                         |
|---|-------|-----------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | SPWG  | Develop TSP-informed NSCI performance guidance                  | Define acceptable NSCI profiles based on local protection needs, including $I_2(V_2)$ magnitude, phase-angle window, response time, duration, and current-priority behavior.                        |
| 2 | ERCOT | Update short-circuit modeling and data collection processes     | Update ERCOT modeling practices and data submittal requirements to support Type-3 WTG, CIR, and black-box model representation of NSCI behavior in ASPEN and related tools.                         |
| 3 | SPWG  | Establish NSCI-related misoperation monitoring and reassessment | Track protection misoperations, identify NSCI-related root causes, and trigger reassessment of NSCI profiles and model performance using field event data.                                          |
| 4 | ERCOT | Coordinate industry implementation through working groups       | Use SPWG, IBRWG, and related forums to align ERCOT, TSPs, GOs, developers, OEMs, and relay manufacturers on NSCI profiles, modeling requirements, validation methods, and implementation timelines. |

## Summary and Next Steps

- Distributed the draft white paper on NSCI implementation considerations to SPWG on June 9
- SPWG to review and provide comments by June 30 to support final revisions.
- Publish the finalized white paper on the ERCOT public website.
- SPWG to consider adopting recommended action items.
- Send input or suggestions to: [Jimmy.Zhang@ercot.com](mailto:Jimmy.Zhang@ercot.com).